

=====

ACME PETROCHEMICAL DEMO COMPLEX - UNIT 2300

PIPING & INSTRUMENTATION DIAGRAM: MASTER DRAWING LIST & EQUIPMENT REGISTER

Drawing Number: PID-23-0000 | Revision: Z1 | Unit: 2300

1. MASTER P&ID DRAWING INDEX FOR UNIT 2300

- PID-23-0000: Unit 2300 P&ID Master Drawing List, Legend & Equipment Register (Rev Z1)
- PID-23-0002: Unit 2300 Safety Instrumented System (SIS) Cause & Effect Interlock Matrix (Rev Z1)
- PID-23-0004: Unit 2300 Preflash Column V-2301 & Bottoms Pump P-2301A/B P&ID (Rev Z1 - Vector CAD)
- PID-23-0013: Unit 2300 Decomposer Reactor D-2304 & Circulation Cooler E-2307 P&ID (Rev Z1)
- PID-23-0022: Unit 2300 Pressure Relief Header & Acid Aromatics Knock-Out Drum D-2320 P&ID (Rev Z1)

=====							
PID-23-0000 PAGE 2 OF 3 - UNIT 2300 MASTER EQUIPMENT REGISTER							
Equipment Tag	Equipment Name	Equipment Class	Design Pressure	Design Temp	Material	Primary Data Sheet	
V-2301	Preflash Column	Column / Vessel	FV / 3.5 kg/cm2g	165 degC	SA-516 Gr.70 + 316L Clad	DS-V2301	
P-2301A/B	Preflash Bottoms Pump	Centrifugal Pump	10.0 kg/cm2g	165 degC	ASTM A351 CF3M (316L)	DS-P2301	
X-2301	Flash Column Vacuum Package	Vacuum Ejector System	FV / 3.5 kg/cm2g	195 degC	SA-240 Type 316L	DS-X2301	
D-2304	Decomposer Reactor	Chemical Reactor	11.0 kg/cm2g (DS) / 12.2 kg/cm2g (PID)	250 degC	SA-240 Type 316L	DS-D2304	
E-2307	Reactor Circulation Cooler	Heat Exchanger	11.0 kg/cm2g (Tube) / 7.0 kg/cm2g (Shell)	250 degC	SA-240 Type 316L	DS-E2307	
D-2310	Cleavage Neutralization Drum	Mixing Vessel	7.0 kg/cm2g	150 degC	SA-240 Type 316L	PFD-23-0000	
D-2320	Acid Aromatics Relief KO Drum	Flare Knock-Out Drum	3.5 kg/cm2g	200 degC	SA-240 Type 316L	PID-D2320	

=====

PID-23-0000 PAGE 3 OF 3 - PIPING LINE CLASS & SYMBOL LEGEND

- Line Class 316L-150: ASME B16.5 Class 150, Schedule 10S/40S ASTM A312 TP316L (Vacuum & Low-Pressure Peroxide Se
- Line Class 316L-300: ASME B16.5 Class 300, Schedule 40S ASTM A312 TP316L (Decomposer Reactor Loop & Relief Inle