

RICS Home Survey - Level 3

Property: 14 Oak Street, Leeds LS1 2AB. Surveyor: Hannah Briggs MRICS. Inspection date: 25 September 2026.

Market value and reinstatement cost

In my opinion the market value of the property is £420,000. The reinstatement cost for insurance is £285,000.

Condition ratings summary

Element	Rating	Summary
D2 Roof coverings	3	Slipped and missing slates to the rear slope; water staining in the loft.
E4 Walls (dampness)	3	High damp meter readings to the base of the rear wall of the kitchen extension.
F2 Electricity	1	No repair is currently needed.

Recommendations

R1. Roof: a roofing contractor should repair the rear slope before exchange of contracts and quote for full re-covering.

R2. Damp: a damp and timber specialist who is a member of the PCA should investigate the rear wall of the extension before exchange.

Issues for your legal advisers

L1. Building regulations: no completion certificate has been seen for the rear extension built around 2011. Your legal adviser should confirm approval was given.

L2. The front boundary wall is over 1 metre high next to the pavement. Your legal adviser should check whether planning permission was needed.