

LASAL™ 66

Page : 1 / 9

Revised edition no : 2 - 01

Date: 19 / 3 / 2013

Supersedes: 14 / 11 / 2012

217014

In case of emergency: +49 (0)2151 398668

SECTION 1. Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

Trade name: LASAL™ 66SDS Nr: 217014

1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : Industrial and professional. Perform risk assessment prior to use.

Laser gas. Contact supplier for more uses information.

1.3. Details of the supplier of the safety data sheet

Company identification : AIR LIQUIDE Deutschland GmbH

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY

Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

E-Mail address (competent person) : Info.SDB@AirLiquide.de

1.4. Emergency telephone number

Emergency telephone number : +49 (0)2151 398668

- Availability : (24 / 7)

SECTION 2. Hazards identification

2.1. Classification of the substance or mixture

Hazard Class and Category Code(s), Regulation (EC) No 1272/2008 (CLP)

• Physical hazards : Gases under pressure - Compressed gas - Warning - (CLP : Press. Gas) - H280

Classification EC 67/548 or EC 1999/45

Classification : Not classified as dangerous substance/mixture.

2.2. Label elements

Labelling Regulation EC 1272/2008 (CLP)

Hazard pictograms



Hazard pictograms code Signal words GHS04 Warning

• Hazard statements : H280 - Contains gas under pressure; may explode if heated.

Precautionary statements

- Storage : P403 - Store in a well-ventilated place.

2.3. Other hazards

Other hazards : Asphyxiant in high concentrations.



LASAL™ 66

Page: 2 / 9

Revised edition no: 2 - 01

Date: 19 / 3 / 2013

Supersedes : 14 / 11 / 2012

217014

SECTION 3. Composition/information on ingredients

3.1. Substance / 3.2. Mixture

Mixture.

Substance name		Content [Vol-%]	CAS No EC No Index No Registration no.	Classification(DSD)	Classification(CLP)
Carbon dioxide	:	5 %	124-38-9	Not classified (DSD/DPD)	Liq. Gas (H280)
			204-696-9		
			*1		
Nitrogen	:	35 %	7727-37-9	Not classified (DSD/DPD)	Press. Gas (H280)
			231-783-9		
			*1		
Helium	:	60 %	7440-59-7	Not classified (DSD/DPD)	Press. Gas (H280)
			231-168-5		
			* 1		

Contains no other components or impurities which will influence the classification of the product.

- * 1: Listed in Annex IV / V REACH, exempted from registration.
- * 2: Registration deadline not expired.
- * 3: Registration not required: Substance manufactured or imported < 1t/y

Full text of R-phrases see chapter 16. Full text of H-statements see chapter 16

SECTION 4. First aid measures

4.1. Description of first aid measures

- Inhalation : Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep

victim warm and rested. Call a doctor. Apply artificial respiration if breathing stopped.

Skin contact
 Eye contact
 Adverse effects not expected from this product.
 Adverse effects not expected from this product.

- Ingestion : Ingestion is not considered a potential route of exposure.

4.2. Most important symptoms and effects, both acute and delayed

: In high concentrations may cause asphyxiation. Symptoms may include loss of mobility/

In case of emergency: +49 (0)2151 398668

consciousness. Victim may not be aware of asphyxiation.

Refer to section 11.

4.3. Indication of any immediate medical attention and special treatment needed

: None.



Re

Revised edition no : 2 - 01

Date: 19 / 3 / 2013
Supersedes: 14 / 11 / 2012

Page: 3/9

Duperseues . 147 1177

LASAL™ 66

217014

SECTION 5. Fire-fighting measures

5.1. Extinguishing media

Extinguishing media : All known extinguishants can be used.

- Suitable extinguishing media : Water spray or fog.

- Unsuitable extinguishing media : Do not use water jet to extinguish.

5.2. Special hazards arising from the substance or mixture

Specific hazards : Exposure to fire may cause containers to rupture/explode.

Hazardous combustion products : None.

5.3. Advice for firefighters

Specific methods : If possible, stop flow of product.

Use fire control measures appropriate to the surrounding fire. Exposure to fire and heat radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering

sewers and drainage systems.

Use water spray or fog to knock down fire fumes if possible.

Special protective equipment for fire

fighters

In confined space use self-contained breathing apparatus.

Standard EN 137 - self-contained open-circuit compressed air breathing apparatus with full

face mask.

Standard protective clothing and equipment (Self Contained Breathing Apparatus) for fire

fighters.

EN 469: Protective clothing for firefighters. EN 659: Protective gloves for firefighters.

SECTION 6. Accidental release measures

6.1. Personal precautions, protective equipment and emergency procedures

: Wear self-contained breathing apparatus when entering area unless atmosphere is proved to

be safe.

Ensure adequate air ventilation.

Evacuate area. Try to stop release.

Monitor concentration of released product.

6.2. Environmental precautions

: Try to stop release.

6.3. Methods and material for containment and cleaning up

: Ventilate area.

6.4. Reference to other sections

Reference to other sections : See also sections 8 and 13.

SECTION 7. Handling and storage

7.1. Precautions for safe handling

Safe use of the product : Use only properly specified equipment which is suitable for this product, its supply pressure

and temperature. Contact your gas supplier if in doubt.

Do not smoke while handling product.

Only experienced and properly instructed persons should handle gases under pressure. Ensure the complete gas system was (or is regularily) checked for leaks before use. The product must be handled in accordance with good industrial hygiene and safety

procedures.

Consider pressure relief device(s) in gas installations.

AIR LIQUIDE Deutschland GmbH

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

In case of emergency: +49 (0)2151 398668



LASAL™ 66

Page: 4 / 9
Revised edition no: 2 - 01

Date: 19/3/2013

Supersedes: 14 / 11 / 2012

217014

SECTION 7. Handling and storage (continued)

Safe handling of the gas receptacle

: Secure gas cylinder against overturning.

Refer to supplier's container handling instructions.

Do not allow backfeed into the container.

Replace valve outlet caps or plugs and container caps where supplied as soon as container is

disconnected from equipment.

Protect cylinders from physical damage; do not drag, roll, slide or drop.

Do not remove or deface labels provided by the supplier for the identification of the cylinder

When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.)

designed to transport cylinders.

Leave valve protection caps in place until the container has been secured against either a wall

or bench or placed in a container stand and is ready for use.

If user experiences any difficulty operating cylinder valve discontinue use and contact

supplier.

Close container valve after each use and when empty, even if still connected to equipment.

Never attempt to repair or modify container valves or safety relief devices.

Keep container valve outlets clean and free from contaminants particularly oil and water.

Never attempt to transfer gases from one cylinder/container to another.

Never use direct flame or electrical heating devices to raise the pressure of a container.

Damaged valves should be reported immediately to the supplier.

7.2. Conditions for safe storage, including any incompatibilities

Storage

: Keep container below 50°C in a well ventilated place.

Store containers in location free from fire risk and away from sources of heat and ignition. Stored containers should be periodically checked for general condition and leakage. Observe all regulations and local requirements regarding storage of containers. Containers should not be stored in conditions likely to encourage corrosion.

Containers should be stored in the vertical position and properly secured to prevent toppling.

Container valve guards or caps should be in place.

Keep away from combustible materials.

7.3. Specific end use(s)

: None.

SECTION 8. Exposure controls/personal protection

8.1. Control parameters

Occupational Exposure Limits

Carbon dioxide : ILV (EU) - 8 H - [mg/m³] : 9000 : ILV (EU) - 8 H - [ppm] : 5000

: AGW (8h) - Germany [mg/m³] TRGS 900 : 9100 : AGW (8h) - Germany [ppm] TRGS 900 : 5000

: Exceeding factor AGW - Germany TRGS 900 : 2

DNEL: Derived no effect level (

Workers)

· No data available

PNEC: Predicted no effect

concentration

: No data available.

8.2. Exposure controls

8.2.1. Appropriate engineering

controls

: Provide adequate general and local exhaust ventilation.

Systems under pressure shoud be regularily checked for leakages.

Ensure exposure is below occupational exposure limits (where available).

Oxygen detectors should be used when asphixiating gases may be released.

Consider work permit system e.g. for maintenance activities.

AIR LIQUIDE Deutschland GmbH

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

In case of emergency: +49 (0)2151 398668



Page: 5/9 Revised edition no: 2 - 01

Date: 19/3/2013

Supersedes: 14 / 11 / 2012

LASAL™ 66

217014

In case of emergency: +49 (0)2151 398668

SECTION 8. Exposure controls/personal protection (continued)

e.g. personal protective equipment

8.2.2. Individual protection measures, : A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk.

The following recommendations should be considered.

PPE compliant to the recommended EN / ISO standards should be selected.

· Eye / face protection

: Wear safety glasses with side shields Standard EN 166 - Personal eye-protection.

Skin protection

- Hand protection : Wear working gloves when handling gas containers.

Standard EN 388 - Protective gloves against mechanical risk.

- Other

Wear safety shoes while handling containers.

Standard EN ISO 20345 Personal protective equipment - Safety footwear.

· Respiratory protection

Self contained breathing apparatus (SCBA) or positive pressure airline with mask are to be

used in oxygen-deficient atmosphere.

Standard EN 137 - self-contained open-circuit compressed air breathing apparatus with full

face mask.

Thermal hazards

: None necessary.

8.2.3. Environmental exposure controls

Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for

specific methods for waste gas treatment.

SECTION 9. Physical and chemical properties

9.1. Information on basic physical and chemical properties

Appearance

Physical state at 20°C / 101.3kPa : Gas. Colour · Colourless

Odour : Odourless. No odour warning properties.

Odour threshold : Odour threshold is subjective and inadequate to warn for overexposure.

: Not applicable for gas-mixtures. pH value

Molar mass [g/mol] : Not applicable for gases and gas-mixtures.

Melting point [°C] : Not applicable for gas-mixtures. Boiling point [°C] : Not applicable for gas-mixtures. Flash point [°C] : Not applicable for gas-mixtures. Evaporation rate (ether=1) : Not applicable for gas-mixtures. : Not applicable for gas-mixtures. Flammability range [vol% in air]

Vapour pressure [20°C] : Not applicable.

Relative density, gas (air=1) : Lighter or similar to air.

: • Helium : 1.5 • Nitrogen : 20 • Carbon dioxide : Completely soluble. Solubility in water [mg/l]

Solubility in water of component(s) of the mixture :

Partition coefficient n-octanol/water [: Not applicable for gas-mixtures.

log Pow]

Viscosity at 20°C [mPa.s] : Not applicable. : Not applicable. **Explosive Properties**

9.2. Other information

Other data : None.



Revised edition no : 2 - 01

Date : 19 / 3 / 2013

Page: 6/9

Supersedes : 14 / 11 / 2012

LASAL™ 66

217014

In case of emergency: +49 (0)2151 398668

SECTION 10. Stability and reactivity

10.1. Reactivity

: No reactivity hazard other than the effects described in sub-sections below.

10.2. Chemical stability

: Stable under normal conditions.

10.3. Possibility of hazardous reactions

: None.

10.4. Conditions to avoid

· None

10.5. Incompatible materials

: None.

For additional information on compatibility refer to ISO 11114

10.6. Hazardous decomposition products

: Under normal conditions of storage and use, hazardous decomposition products should not be produced

SECTION 11. Toxicological information

11.1. Information on toxicological effects

Acute toxicity : No known toxicological effects from this product.

Rat inhalation LC50 [ppm/4h] : No data available.

Skin corrosion/irritation : No known effects from this product. : No known effects from this product. Serious eye damage/irritation Respiratory or skin sensitisation : No known effects from this product. : No known effects from this product. Carcinogenicity Germ cell mutagenicity : No known effects from this product. : No known effects from this product. Toxic for reproduction : Fertility Toxic for reproduction: unborn child: No known effects from this product. STOT-single exposure : No known effects from this product. STOT-repeated exposure : No known effects from this product. Aspiration hazard : Not applicable for gases and gas-mixtures.

SECTION 12. Ecological information

12.1. Toxicity

: No data available.

12.2. Persistence and degradability

: No data available.

12.3. Bioaccumulative potential

: No data available.

12.4. Mobility in soil

: No data available.



Page: 7 / 9

Revised edition no: 2 - 01

Date: 19 / 3 / 2013

Supersedes : 14 / 11 / 2012

In case of emergency: +49 (0)2151 398668

LASAL™ 66

217014

SECTION 12. Ecological information (continued)

12.5. Results of PBT and vPvB assessment

: No data available.

12.6. Other adverse effects

Effect on ozone layer : None.

Effect on the global warming : Contains greenhouse gas(es) not covered by 842/2006/EC

SECTION 13. Disposal considerations

13.1. Waste treatment methods

: Contact supplier if guidance is required.

Do not discharge into any place where its accumulation could be dangerous.

Refer to the code of practice of EIGA (Doc. 30/10 "Disposal of Gases, downloadable at http://

www.eiga.org) for more guidance on suitable disposal methods Ensure that the emission levels from local regulations or operating permits are not exceeded.

: 16 05 05 - gases in pressure containers other than those mentioned in 16 05 04.

List of hazardous waste

13.2. Additional information

: None.

SECTION 14. Transport information

UN number : 1956

Labelling ADR, IMDG, IATA



: 2.2 : Non flammable, non toxic gas.

Land transport (ADR/RID)

H.I. nr : 20

UN proper shipping name : COMPRESSED GAS, N.O.S. (Nitrogen, Helium)

Transport hazard class(es) : 2
Classification code : 1 A
Packing Instruction(s) : P200

Tunnel Restriction : E : Passage forbidden through tunnels of category E.

Environmental hazards : None.

Sea transport (IMDG)

Proper shipping name : COMPRESSED GAS, N.O.S. (Nitrogen, Helium)

Class : 2.2
Emergency Schedule (EmS) - Fire : F-C
Emergency Schedule (EmS) - Spillage : S-V
Packing instruction : P200
IMDG-Marine pollutant : -

Air transport (ICAO-TI / IATA-DGR)

Proper shipping name (IATA) : COMPRESSED GAS, N.O.S. (Nitrogen, Helium)



Page: 8/9 Revised edition no: 2 - 01 Date: 19/3/2013

Supersedes: 14 / 11 / 2012

LASAL™ 66

217014

SECTION 14. Transport information (continued)

: 2.2 Class Passenger and Cargo Aircraft : Allowed. Packing instruction - Passenger and . 200

Cargo Aircraft

Cargo Aircraft only Allowed Packing instruction - Cargo Aircraft . 200

Special precautions for user

: - Ensure there is adequate ventilation.

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the event of an accident or an emergency.

Before transporting product containers:

- Ensure that containers are firmly secured. - Ensure cylinder valve is closed and not leaking.
- Ensure valve outlet cap nut or plug (where provided) is correctly fitted.

- Ensure valve protection device (where provided) is correctly fitted.

Avoid transport on vehicles where the load space is not separated from the driver's compartment.

SECTION 15. Regulatory information

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

EU legislation

Seveso directive 96/82/EC : Not covered.

National legislation

: Ensure all national/local regulations are observed.

- Water hazard class WGK (Germany) : Not hazardous to waters. - Other regulations and technical rules : [German regulations]

(not complete)

GefahrstoffV, BetriebssicherheitsV, BGRegel 500 Teil 2.33: Umgang mit Gasen, Technische Regel Gase TRG 280, Technische Regeln Gefährliche Stoffe TRGS 400, 500, 510, 900.

15.2. Chemical safety assessment

: A CSA does not need to be carried out for this product.

SECTION 16. Other information

Indication of changes : Revised safety data sheet in accordance with commisssion regulation (EU) No 453/2010

Training advice : Receptacle under pressure.

List of full text of H-statements in

section 3.

: H280 - Contains gas under pressure; may explode if heated.

: This Safety Data Sheet has been established in accordance with the applicable European **Further information**

Union legislation.

Classification in accordance with calculation methods of regulation (EC) 1272/2008 CLP / (

EC) 1999/45 DPD.

DISCLAIMER OF LIABILITY : Before using this product in any new process or experiment, a thorough material compatibility

and safety study should be carried out.

Details given in this document are believed to be correct at the time of going to press. Whilst proper care has been taken in the preparation of this document, no liability for injury or

damage resulting from its use can be accepted.

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

In case of emergency: +49 (0)2151 398668



LASAL™ 66

Page: 9 / 9

Revised edition no: 2 - 01

Date: 19 / 3 / 2013

Supersedes : 14 / 11 / 2012

217014

In case of emergency: +49 (0)2151 398668

SECTION 16.	Other information	(continued)	1
--------------------	-------------------	-------------	---

End of document