

Page: 1 / 9

Revised edition no: 2 - 02

Date: 6 / 10 / 2016

Supersedes: 14/2/2013

206016

In case of emergency: +49 (0)2151 398668

ARCAL™ 33N

SECTION 1. Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

 Trade name
 : ARCAL™ 33N

 SDS no
 : 206016

1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : Industrial and professional. Perform risk assessment prior to use. Contact supplier for more

uses information.

Shield gas for welding processes.

1.3. Details of the supplier of the safety data sheet

Company identification : AIR LIQUIDE Deutschland GmbH

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY

Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

E-Mail address (competent person) : Info.SDB@AirLiquide.de

1.4. Emergency telephone number

Emergency telephone number : +49 (0)2151 398668

- Availability : (24 / 7)

SECTION 2. Hazards identification

2.1. Classification of the substance or mixture

Hazard Class and Category Code(s), Regulation (EC) No 1272/2008 (CLP)

• Physical hazards : Gases under pressure - Compressed gas - Warning - (CLP: Press. Gas) - H280

: P403 - Store in a well-ventilated place.

2.2. Label elements

Labelling Regulation EC 1272/2008 (CLP)

Hazard pictograms



Hazard pictograms codeSignal wordsGHS04Warning

Hazard statements : H280 - Contains gas under pressure; may explode if heated.

Precautionary statements

2.3. Other hazards

- Storage

Other hazards : Asphyxiant in high concentrations.



Page: 2 / 9

Revised edition no: 2 - 02

Date: 6 / 10 / 2016

Supersedes: 14 / 2 / 2013

206016

ARCAL™ 33N

SECTION 3. Composition/information on ingredients

3.1. Substance / 3.2. Mixture

Mixture.

Substance name		Content [Vol-%]	CAS No EC No Index No Registration no.	Classification(DSD)	Classification(CLP)
Helium	:	30 %	7440-59-7		Press. Gas (H280)
			231-168-5		
			*1		
Argon	:	69.985 %	7440-37-1		Press. Gas (H280)
			231-147-0		
			*1		
Nitrogen	:	0.015 %	7727-37-9		Press. Gas (H280)
			231-783-9		
			*1		

Contains no other components or impurities which will influence the classification of the product.

- * 1: Listed in Annex IV / V REACH, exempted from registration.
- * 2: Registration deadline not expired.
- * 3: Registration not required: Substance manufactured or imported < 1t/y

Full text of R-phrases see chapter 16. Full text of H-statements see chapter 16

SECTION 4. First aid measures

4.1. Description of first aid measures

- Inhalation : Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep

victim warm and rested. Call a doctor. Apply artificial respiration if breathing stopped.

Skin contact
 Eye contact
 Adverse effects not expected from this product.
 Adverse effects not expected from this product.

- Ingestion : Ingestion is not considered a potential route of exposure.

4.2. Most important symptoms and effects, both acute and delayed

: In high concentrations may cause asphyxiation. Symptoms may include loss of mobility/

In case of emergency: +49 (0)2151 398668

consciousness. Victim may not be aware of asphyxiation.

Refer to section 11.

4.3. Indication of any immediate medical attention and special treatment needed

: None.



Page: 3 / 9

Revised edition no: 2 - 02

Date: 6 / 10 / 2016

Supersedes : 14 / 2 / 2013

206016

ARCAL™ 33N

SECTION 5. Fire-fighting measures

5.1. Extinguishing media

Extinguishing media : All known extinguishants can be used.

- Suitable extinguishing media : Water spray or fog.

- Unsuitable extinguishing media : Do not use water jet to extinguish.

5.2. Special hazards arising from the substance or mixture

Specific hazards : Exposure to fire may cause containers to rupture/explode.

Hazardous combustion products : None.

5.3. Advice for firefighters

Specific methods : Move containers away from the fire area if this can be done without risk.

If possible, stop flow of product.

Use fire control measures appropriate to the surrounding fire. Exposure to fire and heat radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering

sewers and drainage systems.

Use water spray or fog to knock down fire fumes if possible.

Special protective equipment for fire

fighters

: In confined space use self-contained breathing apparatus.

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full

face mask.

Standard protective clothing and equipment (Self Contained Breathing Apparatus) for fire

fighters.

Standard EN 469 - Protective clothing for firefighters. Standard - EN 659: Protective gloves for

firefighters.

SECTION 6. Accidental release measures

6.1. Personal precautions, protective equipment and emergency procedures

: Act in accordance with local emergency plan.

Stay upwind.

Wear self-contained breathing apparatus when entering area unless atmosphere is proved to

In case of emergency: +49 (0)2151 398668

be safe.

Ensure adequate air ventilation.

Evacuate area.

Try to stop release.

Monitor concentration of released product.

6.2. Environmental precautions

: Try to stop release.

6.3. Methods and material for containment and cleaning up

: Ventilate area.

6.4. Reference to other sections

Reference to other sections : See also sections 8 and 13.



Page: 4/9 Revised edition no: 2 - 02 Date: 6 / 10 / 2016

Supersedes: 14 / 2 / 2013

206016

ARCAL™ 33N

SECTION 7. Handling and storage

7.1. Precautions for safe handling

Safe use of the product

: Do not breathe gas.

Avoid release of product into atmosphere.

Use only properly specified equipment which is suitable for this product, its supply pressure

and temperature. Contact your gas supplier if in doubt. Do not smoke while handling product.

Only experienced and properly instructed persons should handle gases under pressure. Ensure the complete gas system was (or is regularily) checked for leaks before use. The product must be handled in accordance with good industrial hygiene and safety

procedures.

Consider pressure relief device(s) in gas installations.

Safe handling of the gas receptacle

Secure gas cylinder against overturning.

Refer to supplier's container handling instructions.

Do not allow backfeed into the container.

Replace valve outlet caps or plugs and container caps where supplied as soon as container is

disconnected from equipment.

Protect cylinders from physical damage; do not drag, roll, slide or drop.

Do not remove or deface labels provided by the supplier for the identification of the cylinder contents.

When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.)

designed to transport cylinders.

Leave valve protection caps in place until the container has been secured against either a wall

or bench or placed in a container stand and is ready for use.

If user experiences any difficulty operating cylinder valve discontinue use and contact

Close container valve after each use and when empty, even if still connected to equipment.

Never attempt to repair or modify container valves or safety relief devices.

Keep container valve outlets clean and free from contaminants particularly oil and water.

Never attempt to transfer gases from one cylinder/container to another.

Never use direct flame or electrical heating devices to raise the pressure of a container.

Damaged valves should be reported immediately to the supplier.

7.2. Conditions for safe storage, including any incompatibilities

Keep container below 50°C in a well ventilated place.

Store containers in location free from fire risk and away from sources of heat and ignition. Stored containers should be periodically checked for general condition and leakage. Observe all regulations and local requirements regarding storage of containers. Containers should not be stored in conditions likely to encourage corrosion.

Containers should be stored in the vertical position and properly secured to prevent toppling.

In case of emergency: +49 (0)2151 398668

Container valve guards or caps should be in place.

Keep away from combustible materials.

7.3. Specific end use(s)

: None.

SECTION 8. Exposure controls/personal protection

8.1. Control parameters

DNEL: Derived no effect level (Workers)

No data available

PNEC: Predicted no effect

concentration

: No data available.



Page: 5/9 Revised edition no: 2 - 02 Date: 6 / 10 / 2016

Supersedes: 14 / 2 / 2013

206016

In case of emergency: +49 (0)2151 398668

ARCAL™ 33N

SECTION 8. Exposure controls/personal protection (continued)

8.2. Exposure controls

8.2.1. Appropriate engineering

controls

: Provide adequate general and local exhaust ventilation.

Systems under pressure shoud be regularily checked for leakages. Ensure exposure is below occupational exposure limits (where available). Oxygen detectors should be used when asphixiating gases may be released.

Consider work permit system e.g. for maintenance activities.

8.2.2. Individual protection measures. :

e.g. personal protective equipment

A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk.

The following recommendations should be considered. PPE compliant to the recommended EN/ISO standards should be selected.

: Wear safety glasses with side shields · Eye/face protection

Standard EN 166 - Personal eye-protection.

Skin protection

- Hand protection : Wear working gloves when handling gas containers.

Standard EN 388 - Protective gloves against mechanical risk.

- Other : Wear safety shoes while handling containers.

Standard EN ISO 20345 - Personal protective equipment - Safety footwear.

· Respiratory protection : Self contained breathing apparatus (SCBA) or positive pressure airline with mask are to be

used in oxygen-deficient atmospheres.

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full

face mask. : None necessary.

Thermal hazards

8.2.3. Environmental exposure

controls

: Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for

specific methods for waste gas treatment.

SECTION 9. Physical and chemical properties

9.1. Information on basic physical and chemical properties

Appearance

Physical state at 20°C / 101.3kPa : Gas. Colour : Colourless.

Odour Odourless. No odour warning properties.

Odour threshold : Odour threshold is subjective and inadequate to warn for overexposure.

pH value : Not applicable for gas-mixtures.

Molar mass [g/mol] : Not applicable for gases and gas-mixtures.

Melting point [°C] : Not applicable for gas-mixtures. Boiling point [°C] : Not applicable for gas-mixtures. Flash point [°C] : Not applicable for gas-mixtures. Evaporation rate (ether=1) : Not applicable for gas-mixtures. Flammability range [vol% in air] : Not applicable for gas-mixtures.

Vapour pressure [20°C] : Not applicable. Relative density, gas (air=1) : Lighter or similar to air.

Solubility in water [mg/l] : • Argon : 67 • Helium : 1.5 • Nitrogen : 20 Solubility in water of component(s) of the mixture :

Partition coefficient n-octanol/water [: Not applicable for gas-mixtures.

loa Powl

Viscosity at 20°C [mPa.s] : Not applicable. **Explosive Properties** : Not applicable.



Page: 6 / 9

Revised edition no: 2 - 02

Date: 6 / 10 / 2016

Supersedes: 14 / 2 / 2013

206016

ARCAL™ 33N

SECTION 9. Physical and chemical properties (continued)

Oxidising properties : None.

9.2. Other information

Other data : None.

SECTION 10. Stability and reactivity

10.1. Reactivity

: No reactivity hazard other than the effects described in sub-sections below.

10.2. Chemical stability

: Stable under normal conditions.

10.3. Possibility of hazardous reactions

: None.

10.4. Conditions to avoid

: None.

10.5. Incompatible materials

: None

For additional information on compatibility refer to ISO 11114

10.6. Hazardous decomposition products

Under normal conditions of storage and use, hazardous decomposition products should not be produced.

In case of emergency: +49 (0)2151 398668

SECTION 11. Toxicological information

11.1. Information on toxicological effects

Acute toxicity : No known toxicological effects from this product.

Rat inhalation LC50 [ppm/4h] : No data available.

: No known effects from this product. Skin corrosion/irritation Serious eye damage/irritation : No known effects from this product. Respiratory or skin sensitisation : No known effects from this product. : No known effects from this product. Carcinogenicity : No known effects from this product. Germ cell mutagenicity Toxic for reproduction : Fertility : No known effects from this product. Toxic for reproduction: unborn child : No known effects from this product. : No known effects from this product. STOT-single exposure STOT-repeated exposure : No known effects from this product. Aspiration hazard : Not applicable for gases and gas-mixtures.



Page: 7 / 9
Revised edition no: 2 - 02

Date : 6 / 10 / 2016

Supersedes: 14 / 2 / 2013

206016

ARCAL™ 33N

SECTION 12. Ecological information

12.1. Toxicity

Assessment

:

Classification criteria are not met.

12.2. Persistence and degradability

Assessment : No data available.

12.3. Bioaccumulative potential

Assessment : No data available.

12.4. Mobility in soil

Assessment : No data available.

12.5. Results of PBT and vPvB assessment

: No data available.

12.6. Other adverse effects

Effect on ozone layer : None.

Effect on the global warming : No known ecological damage caused by this product.

SECTION 13. Disposal considerations

13.1. Waste treatment methods

: Contact supplier if guidance is required.

Do not discharge into any place where its accumulation could be dangerous.

Refer to the code of practice of EIGA (Doc. 30/10 "Disposal of Gases, downloadable at http://

In case of emergency: +49 (0)2151 398668

www.eiga.org) for more guidance on suitable disposal methods Ensure that the emission levels from local regulations or operating permits are not exceeded.

List of hazardous waste codes (from Commission Decision 2001/118/EC)

: 16 05 05 - gases in pressure containers other than those mentioned in 16 05 04.

13.2. Additional information

: None.

SECTION 14. Transport information

Labelling ADR, IMDG, IATA

14.1. UN number

UN number

: 1956



: 2.2 : Non flammable, non toxic gas.

14.2. UN proper shipping name

Transport by road/rail (ADR/RID) : COMPRESSED GAS, N.O.S. (Helium, Argon)
Transport by air (ICAO-TI / IATA-DGR) : COMPRESSED GAS, N.O.S. (Helium, Argon)
Transport by sea (IMDG) : COMPRESSED GAS, N.O.S. (Helium, Argon)

14.3. Transport hazard class(es)



Page: 8/9 Revised edition no: 2 - 02 Date: 6 / 10 / 2016

Supersedes: 14 / 2 / 2013

206016

ARCAL™ 33N

SECTION 14. Transport information (continued)

Transport by road/rail (ADR/RID)

Class : 2 : 1 A Classification code H.I. nr : 20

Tunnel Restriction : E : Passage forbidden through tunnels of category E.

Transport by air (ICAO-TI / IATA-DGR)

Transport by sea (IMDG)

Emergency Schedule (EmS) - Fire : F-C Emergency Schedule (EmS) - Spillage : S-V

14.4. Packing group

Transport by road/rail (ADR/RID) : Not applicable. Transport by air (ICAO-TI / IATA-DGR) : Not applicable. : Not applicable. Transport by sea (IMDG)

14.5. Environmental hazards

Transport by road/rail (ADR/RID) : None. Transport by air (ICAO-TI / IATA-DGR) : None. Transport by sea (IMDG)

14.6 Special precautions for user

Packing Instruction(s) : P200 Transport by road/rail (ADR/RID) : P200

Transport by air (ICAO-TI / IATA-DGR)

Passenger and Cargo Aircraft : Allowed. Packing instruction - Passenger and : 200

Cargo Aircraft

: Allowed. Cargo Aircraft only Packing instruction - Cargo Aircraft : 200

Transport by sea (IMDG) : P200

Special precautions for user : - Ensure there is adequate ventilation.

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the

event of an accident or an emergency. Before transporting product containers: - Ensure that containers are firmly secured. - Ensure cylinder valve is closed and not leaking.

- Ensure valve outlet cap nut or plug (where provided) is correctly fitted. - Ensure valve protection device (where provided) is correctly fitted.

Avoid transport on vehicles where the load space is not separated from the driver's

In case of emergency: +49 (0)2151 398668

compartment.

14.7 Transport in bulk according to Annex II of MARPOL 73/78 and the IBC Code

Transport in bulk according to Annex : Not applicable. II of MARPOL 73/78 and the IBC Code



Page: 9 / 9

Revised edition no: 2 - 02

Date: 6 / 10 / 2016

Supersedes: 14/2/2013

206016

ARCAL™ 33N

SECTION 15. Regulatory information

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

EU legislation

Seveso directive 96/82/EC

National legislation

: Not covered.

: Ensure all national/local regulations are observed.

: [German regulations]

BetriebssicherheitsV mit TRBSen insbesondere TRBS 3145 / TRGS 725 "Ortsbewegliche Druckgasbehälter", TRBS 2141, BGRegel 500 Teil 2.33: "Umgang mit Gasen", GefahrstoffV mit Technischen Regeln Gefährliche Stoffe TRGS insbesondere TRGS 407 "Tätigkeiten mit

Gasen - Gefährdungsbeurteilung", TRGS 400, 500, 510, 900.

- Water hazard class (WGK)

15.2. Chemical safety assessment

: A CSA does not need to be carried out for this product.

: WGK Germany: Not hazardous to waters.

SECTION 16. Other information

Indication of changes

Training advice

Further information

: Revised safety data sheet in accordance with commisssion regulation (EU) No 453/2010

: Receptacle under pressure.

: This Safety Data Sheet has been established in accordance with the applicable European

Union legislation.

Classification in accordance with calculation methods of regulation (EC) 1272/2008 CLP.

List of full text of H-statements in

section 3.

DISCLAIMER OF LIABILITY

: H280 - Contains gas under pressure; may explode if heated.

: Before using this product in any new process or experiment, a thorough material compatibility

and safety study should be carried out.

Details given in this document are believed to be correct at the time of going to press. Whilst proper care has been taken in the preparation of this document, no liability for injury or

damage resulting from its use can be accepted.

End of document

In case of emergency: +49 (0)2151 398668