

Page: 1 / 11

Revised edition no: 1 - 00

Date: 5 / 9 / 2013

Supersedes: 0/0/0

301113

In case of emergency: +49 (0)2151 398668

## **PGC Calibration gas 11D**

## SECTION 1. Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

Trade name : PGC Calibration gas 11D

**SDS Nr** : 301113

1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : Industrial and professional. Perform risk assessment prior to use.

Test gas / Calibration gas. Laboratory use. Contact supplier for more uses information.

1.3. Details of the supplier of the safety data sheet

Company identification : AIR LIQUIDE Deutschland GmbH

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY

Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

E-Mail address (competent person) : Info.SDB@AirLiquide.de

1.4. Emergency telephone number

Emergency telephone number : +49 (0)2151 398668

- Availability : (24 / 7)

#### **SECTION 2. Hazards identification**

## 2.1. Classification of the substance or mixture

Hazard Class and Category Code(s), Regulation (EC) No 1272/2008 (CLP)

• Physical hazards : Flammable gases - Category 1 - Danger - (CLP : Flam. Gas 1) - H220

Gases under pressure - Compressed gas - Warning - (CLP : Press. Gas) - H280

Classification EC 67/548 or EC 1999/45

Classification : F+; R12

2.2. Label elements

Labelling Regulation EC 1272/2008 (CLP)

Hazard pictograms





• Hazard pictograms code : GHS02 - GHS04

• Signal words : Danger

• Hazard statements : H220 - Extremely flammable gas.

H280 - Contains gas under pressure; may explode if heated.

Precautionary statements

- Prevention
 - Response
 : P210 - Keep away from heat, sparks, open flames or hot surfaces. – No smoking.
 - Response
 : P377 - Leaking gas fire: Do not extinguish, unless leak can be stopped safely.

P381 - Eliminate all ignition sources if safe to do so.

- Storage : P403 - Store in a well-ventilated place.

2.3. Other hazards

Other hazards : None.



Page : 2 / 11

Revised edition no : 1 - 00

Date : 5 / 9 / 2013

Supersedes: 0/0/0

301113

In case of emergency: +49 (0)2151 398668

# **PGC Calibration gas 11D**

## **SECTION 3. Composition/information on ingredients**

## 3.1. Substance / 3.2. Mixture

Mixture.

Substance name		Content [Vol-%]	CAS No EC No Index No Registration no.	Classification(DSD)	Classification(CLP)
Hexane	:	0.0501517 %	110-54-3 203-777-6 601-037-00-0 *2	F; R11 Repr. Cat. 3; R62 Xn; R65-48/20 R67 Xi; R38 N; R51-53	Flam. Liq. 1 (H224) Asp. Tox 1 (H304) Repr. 2 (H361F) Skin Irrit. 2* (H315) STOT RE 2 (H373) STOT RE 3 (H336) Aquatic Chronic 2 (H411)
Isopentane	;	0.0501517 %	78-78-4 201-142-8 601-006-00-1 *2	F+; R12 Xn; R65 R66 R67 N; R51-53	Flam. Liq. 2 (H225) Asp. Tox 1 (H304) STOT RE 3 (H336) STOT RE (EUH066) Aquatic Chronic 2 (H411)
N-Pentane	:	0.0501517 %	109-66-0 203-692-4 601-006-00-1 *2	F+; R12 Xn; R65 R66 R67 N; R51-53	Asp. Tox 1 (H304) STOT RE 3 (H336) STOT RE (EUH066) Aquatic Chronic 2 (H411)
Neopentane	:	0.0501517 %	463-82-1 207-343-7 601-005-00-6 * 2	F+; R12 N; R51-53	Flam. Gas 1 (H220) Liq. Gas (H280) Aquatic Chronic 2 (H411)
Butane n-	:	0.1920255 %	106-97-8 203-448-7 601-004-00-0 01-2119474691-32-	F+; R12	Flam. Gas 1 (H220) Liq. Gas (H280)
Isobutane	:	0.1929832 %	75-28-5 200-857-2 601-004-00-0 01-2119485395-27-	F+; R12	Flam. Gas 1 (H220) Liq. Gas (H280)
Propane	:	0.9818763 %	74-98-6 200-827-9 601-003-00-5 01-2119486944-21-	F+; R12	Flam. Gas 1 (H220) Liq. Gas (H280)
Carbon dioxide	;	1.4944962 %	124-38-9 204-696-9  *1	Not classified (DSD/DPD)	Liq. Gas (H280)
Ethane	;	3.972077 %	74-84-0 200-814-8 601-002-00-X * 2	F+; R12	Flam. Gas 1 (H220) Press. Gas (H280)
Nitrogen	:	4.0102047 %	7727-37-9 231-783-9  *1	Not classified (DSD/DPD)	Press. Gas (H280)
Methane	:	88.9557303 %	74-82-8 200-812-7 601-001-00-4 * 1	F+; R12	Flam. Gas 1 (H220) Press. Gas (H280)



Page: 3 / 11 Revised edition no : 1 - 00 Date: 5 / 9 / 2013 Supersedes: 0/0/0

301113

## **PGC Calibration gas 11D**

#### SECTION 3. Composition/information on ingredients (continued)

Contains no other components or impurities which will influence the classification of the product.

- 1: Listed in Annex IV / V REACH, exempted from registration.
- \* 2: Registration deadline not expired.
- \* 3: Registration not required: Substance manufactured or imported < 1t/y

Full text of R-phrases see chapter 16. Full text of H-statements see chapter 16

### **SECTION 4. First aid measures**

#### 4.1. Description of first aid measures

- Inhalation Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep

victim warm and rested. Call a doctor. Apply artificial respiration if breathing stopped.

- Skin contact : Adverse effects not expected from this product. - Eye contact : Adverse effects not expected from this product.

: Ingestion is not considered a potential route of exposure. - Ingestion

#### 4.2. Most important symptoms and effects, both acute and delayed

: In high concentrations may cause asphyxiation. Symptoms may include loss of mobility/

consciousness. Victim may not be aware of asphyxiation.

Refer to section 11

#### 4.3. Indication of any immediate medical attention and special treatment needed

· None

## **SECTION 5. Fire-fighting measures**

#### 5.1. Extinguishing media

Extinguishing media : All known extinguishants can be used.

- Suitable extinguishing media : Water spray or fog.

- Unsuitable extinguishing media : Do not use water jet to extinguish.

#### 5.2. Special hazards arising from the substance or mixture

Specific hazards : Exposure to fire may cause containers to rupture/explode.

Hazardous combustion products : Incomplete combustion may form carbon monoxide. Carbon monoxide.

#### 5.3. Advice for firefighters

Specific methods : Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive

re-ignition may occur. Extinguish any other fire.

If possible, stop flow of product.

Use fire control measures appropriate to the surrounding fire. Exposure to fire and heat radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering

In case of emergency: +49 (0)2151 398668

sewers and drainage systems.

Use water spray or fog to knock down fire fumes if possible.

Special protective equipment for fire : In confined space use self-contained breathing apparatus.

fiahters



Page: 4 / 11 Revised edition no : 1 - 00 Date: 5 / 9 / 2013

Supersedes: 0/0/0

**PGC Calibration gas 11D** 

301113

## SECTION 6. Accidental release measures

#### 6.1. Personal precautions, protective equipment and emergency procedures

Ensure adequate air ventilation. Eliminate ignition sources.

Evacuate area Try to stop release.

Consider the risk of potentially explosive atmospheres.

6.2. Environmental precautions

: Try to stop release.

#### 6.3. Methods and material for containment and cleaning up

: Ventilate area

6.4. Reference to other sections

Reference to other sections : See also sections 8 and 13.

#### **SECTION 7. Handling and storage**

#### 7.1. Precautions for safe handling

Safe use of the product

Take precautionary measures against static discharge.

Keep away from ignition sources (including static discharges).

Use only properly specified equipment which is suitable for this product, its supply pressure

and temperature. Contact your gas supplier if in doubt. Purge air from system before introducing gas.

Do not smoke while handling product.

Only experienced and properly instructed persons should handle gases under pressure. Ensure the complete gas system was (or is regularily) checked for leaks before use. Assess the risk of potentially explosive atmosphere and the need for explosion-proof

equipment.

Consider the use only non-sparking tools.

The product must be handled in accordance with good industrial hygiene and safety

procedures.

Consider pressure relief device(s) in gas installations.

Safe handling of the gas receptacle

Secure gas cylinder against overturning.

Refer to supplier's container handling instructions.

Do not allow backfeed into the container.

Replace valve outlet caps or plugs and container caps where supplied as soon as container is

disconnected from equipment.

Protect cylinders from physical damage; do not drag, roll, slide or drop.

Do not remove or deface labels provided by the supplier for the identification of the cylinder

contents.

When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders.

Leave valve protection caps in place until the container has been secured against either a wall

or bench or placed in a container stand and is ready for use

If user experiences any difficulty operating cylinder valve discontinue use and contact

Close container valve after each use and when empty, even if still connected to equipment. Never attempt to repair or modify container valves or safety relief devices

Keep container valve outlets clean and free from contaminants particularly oil and water.

Never attempt to transfer gases from one cylinder/container to another.

Never use direct flame or electrical heating devices to raise the pressure of a container.

Damaged valves should be reported immediately to the supplier.

#### 7.2. Conditions for safe storage, including any incompatibilities

Storage

Keep container below 50°C in a well ventilated place.

Segregate from oxidant gases and other oxidants in store.

Store containers in location free from fire risk and away from sources of heat and ignition.

In case of emergency: +49 (0)2151 398668

#### **AIR LIQUIDE Deutschland GmbH**



Page: 5 / 11 Revised edition no : 1 - 00 Date: 5 / 9 / 2013

Supersedes: 0/0/0

301113

In case of emergency: +49 (0)2151 398668

## **SECTION 7. Handling and storage (continued)**

Stored containers should be periodically checked for general condition and leakage. Observe all regulations and local requirements regarding storage of containers. Containers should not be stored in conditions likely to encourage corrosion.

Containers should be stored in the vertical position and properly secured to prevent toppling. Container valve guards or caps should be in place.

All electrical equipment in the storage areas should be compatible with the risk of potentially explosive atmosphere.

Keep away from combustible materials.

7.3. Specific end use(s)

: None.

**PGC Calibration gas 11D** 

#### SECTION 8. Exposure controls/personal protection

#### 8.1. Control parameters

**Occupational Exposure Limits** 

Butane n-: AGW (8h) - Germany [mg/m3] TRGS 900 : 2400

> : AGW (8h) - Germany [ppm] TRGS 900 : 1000 : Exceeding factor AGW - Germany TRGS 900 : 4

**N-Pentane** : ILV (EU) - 8 H - [mg/m<sup>3</sup>] : 3000

: ILV (EU) - 8 H - [ppm] : 1000

: AGW (8h) - Germany [mg/m³] TRGS 900 : 3000 : AGW (8h) - Germany [ppm] TRGS 900 : 1000 : Exceeding factor AGW - Germany TRGS 900 : 2

Hexane : ILV (EU) - 8 H - [mg/m³] : 72

: ILV (EU) - 8 H - [mg/m3]: 72 : ILV (EU) - 8 H - [ppm] : 20 : ILV (EU) - 8 H - [ppm] : 20

: AGW (8h) - Germany [mg/m³] TRGS 900 : 180 : AGW (8h) - Germany [ppm] TRGS 900 : 50 : Exceeding factor AGW - Germany TRGS 900 : 8

: ILV (EU) - 8 H - [mg/m<sup>3</sup>] : 3000 Neopentane

: ILV (EU) - 8 H - [ppm] : 1000

: AGW (8h) - Germany [mg/m3] TRGS 900 : 3000 : AGW (8h) - Germany [ppm] TRGS 900 : 1000 : Exceeding factor AGW - Germany TRGS 900 : 2 : AGW (8h) - Germany [mg/m³] TRGS 900 : 1000 : AGW (8h) - Germany [ppm] TRGS 900 : 1800

: Exceeding factor AGW - Germany TRGS 900 : 4 : AGW (8h) - Germany [mg/m3] TRGS 900 : 2400

: AGW (8h) - Germany [ppm] TRGS 900 : 1000 : Exceeding factor AGW - Germany TRGS 900 : 4

Carbon dioxide : ILV (EU) - 8 H - [mg/m<sup>3</sup>] : 9000

: ILV (EU) - 8 H - [ppm] : 5000

: AGW (8h) - Germany [mg/m³] TRGS 900 : 9100 : AGW (8h) - Germany [ppm] TRGS 900 : 5000 : Exceeding factor AGW - Germany TRGS 900 : 2

**Propane** 

Isobutane



Page: 6 / 11 Revised edition no : 1 - 00 Date: 5 / 9 / 2013

Supersedes: 0/0/0

**PGC Calibration gas 11D** 

301113

#### SECTION 8. Exposure controls/personal protection (continued)

DNEL: Derived no effect level (

Workers)

· No data available

PNEC: Predicted no effect

concentration

: No data available.

8.2. Exposure controls

8.2.1. Appropriate engineering

controls

: Provide adequate general and local exhaust ventilation.

Systems under pressure shoud be regularily checked for leakages. Ensure exposure is below occupational exposure limits (where available).

Keep concentrations well below lower explosion limits.

Gas detectors should be used when flammable gases/vapours may be released.

Consider work permit system e.g. for maintenance activities.

8.2.2. Individual protection measures, :

e.g. personal protective equipment

A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk.

The following recommendations should be considered.

PPE compliant to the recommended EN/ISO standards should be selected.

· Eye/face protection Wear safety glasses with side shields

Standard EN 166 - Personal eye-protection.

· Skin protection

: Wear working gloves when handling gas containers. - Hand protection

Standard EN 388 - Protective gloves against mechanical risk. Consider the use of flame resistant anti-static safety clothing.

- Other Standard EN ISO 14116 - Limited flame spread materials.

Standard EN ISO 1149-5 - Protective clothing: Electrostatic properties.

Wear safety shoes while handling containers.

Standard EN ISO 20345 - Personal protective equipment - Safety footwear.

: Self contained breathing apparatus (SCBA) or positive pressure airline with mask are to be Respiratory protection

used in oxygen-deficient atmospheres.

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full face mask.

None necessary.

Thermal hazards

8.2.3. Environmental exposure

controls

Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for

specific methods for waste gas treatment.

## SECTION 9. Physical and chemical properties

#### 9.1. Information on basic physical and chemical properties

**Appearance** 

Physical state at 20°C / 101.3kPa : Gas. Colour · Colourless

Odour Ethereal. Sweetish. Gasoline.

Mixture contains one or more component(s) which have the following odour(s):

There may be no odour warning properties, odour is subjective and inadequate to warn of

In case of emergency: +49 (0)2151 398668

Odour threshold : Odour threshold is subjective and inadequate to warn for overexposure.

pH value : Not applicable for gas-mixtures.

Molar mass [g/mol] : Not applicable for gases and gas-mixtures.

: Not applicable for gas-mixtures. Melting point [°C] Boiling point [°C] : Not applicable for gas-mixtures.



Page: 7 / 11 Revised edition no : 1 - 00 Date: 5 / 9 / 2013

Supersedes: 0/0/0

301113

## **PGC Calibration gas 11D**

#### SECTION 9. Physical and chemical properties (continued)

Flash point [°C] : Not applicable for gas-mixtures. Evaporation rate (ether=1) : Not applicable for gas-mixtures. Flammability range [vol% in air] : Flammability range not available.

Vapour pressure [20°C] : Not applicable.

Relative density, gas (air=1) : Lighter or similar to air.

• Methane : 26 • Nitrogen : 20 • Ethane : 61 • Carbon dioxide : Completely soluble. • Propane : 75 • Isobutane : 54 • Butane n- : 88 • Neopentane : 52 • N-Pentane : 40 • Solubility in water [mg/l]

Isopentane: 48 • Hexane: Not known, but considered to have low solubility.

Solubility in water of component(s) of the mixture :

Partition coefficient n-octanol/water [ : Not applicable for gas-mixtures.

log Pow]

Viscosity at 20°C [mPa.s] : Not applicable. **Explosive Properties** : Not applicable.

9.2. Other information

Other data : None.

#### **SECTION 10. Stability and reactivity**

10.1. Reactivity

: No reactivity hazard other than the effects described in sub-sections below.

10.2. Chemical stability

: Stable under normal conditions.

10.3. Possibility of hazardous reactions

: Can form explosive mixture with air. May react violently with oxidants.

10.4. Conditions to avoid

: Keep away from heat/sparks/open flames/hot surfaces. - No smoking.

10.5. Incompatible materials

: Air, Oxidiser.

For additional information on compatibility refer to ISO 11114

10.6. Hazardous decomposition products

: Under normal conditions of storage and use, hazardous decomposition products should not be produced.

In case of emergency: +49 (0)2151 398668

#### **SECTION 11. Toxicological information**

#### 11.1. Information on toxicological effects

Acute toxicity : No known toxicological effects from this product.

Rat inhalation LC50 [ppm/4h] : No data available

Skin corrosion/irritation : No known effects from this product. Serious eye damage/irritation : No known effects from this product. Respiratory or skin sensitisation : No known effects from this product. : No known effects from this product. Carcinogenicity Germ cell mutagenicity : No known effects from this product.



Page: 8 / 11
Revised edition no: 1 - 00

Date: 5 / 9 / 2013

Supersedes: 0/0/0

# PGC Calibration gas 11D

301113

In case of emergency: +49 (0)2151 398668

#### **SECTION 11. Toxicological information (continued)**

Toxic for reproduction: Fertility

Toxic for reproduction: unborn child

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

Toxic for reproduction: No known effects from this product.

#### **SECTION 12. Ecological information**

#### 12.1. Toxicity

: Classification criteria are not met.

EC50 48h - Daphnia magna [mg/l] : • Methane : 69.4

Ethane: 46.6Propane: 27.1Isobutane: 16.3Butane n-: 14.2: Methane: 19.4

EC50 72h - Algae [mg/l] : • Methane : 19.4 • Ethane : 16.5 • Propane : 11.9 • Isobutane : 8.6 • Butane n- : 7.7 LC50-96h - fish [mg/l] : • Methane : 147.5

Ethane: 91.4Propane: 49.9Isobutane: 28Butane n-: 24.1

## 12.2. Persistence and degradability

: No data available.

## 12.3. Bioaccumulative potential

: No data available.

## 12.4. Mobility in soil

: No data available.

#### 12.5. Results of PBT and vPvB assessment

: No data available.

## 12.6. Other adverse effects

Effect on ozone layer : None.

Effect on the global warming : Contains greenhouse gas(es) not covered by 842/2006/EC



Page: 9 / 11
Revised edition no: 1 - 00

Date: 5 / 9 / 2013

Supersedes: 0/0/0

## **PGC Calibration gas 11D**

301113

#### **SECTION 13. Disposal considerations**

#### 13.1. Waste treatment methods

Do not discharge into areas where there is a risk of forming an explosive mixture with air.

Waste gas should be flared through a suitable burner with flash back arrestor.

Contact supplier if guidance is required.

Do not discharge into any place where its accumulation could be dangerous.

Refer to the code of practice of EIGA (Doc. 30/10 "Disposal of Gases, downloadable at http://

www.eiga.org) for more guidance on suitable disposal methods

Ensure that the emission levels from local regulations or operating permits are not exceeded. : 16 05 04 - gases in pressure containers (including halons) containing dangerous substances.

List of hazardous waste

13.2. Additional information

: None.

#### **SECTION 14. Transport information**

UN number : 1954

Labelling ADR, IMDG, IATA



: 2.1 : flammable gas.

#### Land transport (ADR/RID)

H.I. nr : 23

UN proper shipping name : COMPRESSED GAS, FLAMMABLE, N.O.S. (Ethane, Methane)

Transport hazard class(es) : 2
Classification code : 1 F
Packing Instruction(s) : P200

**Tunnel Restriction** : B/D Tank carriage: Passage forbidden through tunnels of category B, C, D

Environmental hazards : None.

Sea transport (IMDG)

Proper shipping name : COMPRESSED GAS, FLAMMABLE, N.O.S. (Ethane, Methane)

Class : 2.1
Emergency Schedule (EmS) - Fire : F-D
Emergency Schedule (EmS) - Spillage : S-U
Packing instruction : P200
IMDG-Marine pollutant : No

Air transport (ICAO-TI / IATA-DGR)

Proper shipping name (IATA) : COMPRESSED GAS, FLAMMABLE, N.O.S. (Ethane, Methane)

Class : 2.

Passenger and Cargo Aircraft : DO NOT LOAD IN PASSENGER AIRCRAFT.

Cargo Aircraft only : Allowed Packing instruction - Cargo Aircraft : 200

only

#### Special precautions for user

: - Ensure there is adequate ventilation.

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the

event of an accident or an emergency. Before transporting product containers :

#### **AIR LIQUIDE Deutschland GmbH**

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

In case of emergency: +49 (0)2151 398668



Page: 10 / 11 Revised edition no : 1 - 00 Date: 5 / 9 / 2013

Supersedes: 0/0/0

301113

# **PGC Calibration gas 11D**

#### **SECTION 14. Transport information (continued)**

- Ensure that containers are firmly secured.
- Ensure cylinder valve is closed and not leaking.
- Ensure valve outlet cap nut or plug (where provided) is correctly fitted.
- Ensure valve protection device (where provided) is correctly fitted.

Avoid transport on vehicles where the load space is not separated from the driver's compartment.

## **SECTION 15. Regulatory information**

#### 15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

#### **EU** legislation

Seveso directive 96/82/EC Covered

National legislation

: Ensure all national/local regulations are observed.

- 4. BlmschV (Germany)

- Water hazard class (WGK) : WGK Germany: Not hazardous to waters.

- Other regulations and technical rules : [German regulations]

(not complete)

GefahrstoffV, BetriebssicherheitsV, BGRegel 500 Teil 2.33: Umgang mit Gasen, Technische Regel Gase TRG 280, Technische Regeln Gefährliche Stoffe TRGS 400, 500, 510, 900.

BGR 104, TRBS 2152.

#### 15.2. Chemical safety assessment

: A CSA does not need to be carried out for this product.

### **SECTION 16. Other information**

Indication of changes : Revised safety data sheet in accordance with commisssion regulation (EU) No 453/2010

: Ensure operators understand the flammability hazard. Training advice

Receptacle under pressure.

List of full text of R-phrases in section : R11 : Highly flammable

R12: Extremely flammable.

R38: Irritating to skin.

R48/20: Harmful: danger of serious damage to health by prolonged exposure through

inhalation.

R51/53: Toxic to aquatic organisms, may cause long-term adverse effects in the aquatic

environment.

R62: Possible risk of impaired fertility.

R65: Harmful: may cause lung damage if swallowed. R66: Repeated exposure may cause skin dryness or cracking.

R67: Vapours may cause drowsiness and dizziness.

List of full text of H-statements in

section 3.

EUH066 - Repeated exposure may cause skin dryness or cracking.

H220 - Extremely flammable gas.

H224 - Extremely flammable liquid and vapour. H225 - Highly flammable liquid and vapour.

H280 - Contains gas under pressure; may explode if heated. H304 - May be fatal if swallowed and enters airways

H315 - Causes skin irritation.

H336 - May cause drowsiness or dizziness. H361F - Suspected of damaging fertility.

H373 - May cause damage to organs through prolonged or repeated exposure.

H411 - Toxic to aquatic life with long lasting effects.

This Safety Data Sheet has been established in accordance with the applicable European **Further information** 

Union legislation.

Classification in accordance with calculation methods of regulation (EC) 1272/2008 CLP / (

#### **AIR LIQUIDE Deutschland GmbH**

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

In case of emergency: +49 (0)2151 398668



Page: 11 / 11

Revised edition no: 1 - 00

Date: 5 / 9 / 2013

**PGC Calibration gas 11D** 

301113

Supersedes: 0/0/0

#### **SECTION 16. Other information (continued)**

EC) 1999/45 DPD.

**DISCLAIMER OF LIABILITY** 

: Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out.

Details given in this document are believed to be correct at the time of going to press. Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted.

End of document

In case of emergency: +49 (0)2151 398668