

Page: 1 / 9

Revised edition no: 3 - 00

Date: 2 / 5 / 2013

Supersedes: 1 / 5 / 2007

LASAL™ 4636

217010

In case of emergency: +49 (0)2151 398668

### SECTION 1. Identification of the substance/mixture and of the company/undertaking

#### 1.1. Product identifier

 Trade name
 : LASAL™ 4636

 SDS Nr
 : 217010

### 1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : Industrial and professional. Perform risk assessment prior to use.

Laser gas.

Contact supplier for more uses information.

### 1.3. Details of the supplier of the safety data sheet

Company identification : AIR LIQUIDE Deutschland GmbH

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY

Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

E-Mail address (competent person) : Info.SDB@AirLiquide.de

1.4. Emergency telephone number

Emergency telephone number : +49 (0)2151 398668

- Availability : (24 / 7)

### **SECTION 2. Hazards identification**

### 2.1. Classification of the substance or mixture

Hazard Class and Category Code(s), Regulation (EC) No 1272/2008 (CLP)

• Physical hazards : Gases under pressure - Compressed gas - Warning - (CLP: Press. Gas) - H280

Classification EC 67/548 or EC 1999/45

Classification : Not classified as dangerous substance/mixture.

### 2.2. Label elements

### Labelling Regulation EC 1272/2008 (CLP)

Hazard pictograms



• Hazard pictograms code : GHS04 • Signal words : Warning

• Hazard statements : H280 - Contains gas under pressure; may explode if heated.

Precautionary statements

- Storage : P403 - Store in a well-ventilated place.

2.3. Other hazards

Other hazards : Asphyxiant in high concentrations.



Page: 2 / 9

Revised edition no: 3 - 00

Date: 2 / 5 / 2013

Supersedes: 1/5/2007

217010

LASAL™ 4636

### **SECTION 3. Composition/information on ingredients**

### 3.1. Substance / 3.2. Mixture

#### Mixture.

Substance name		Content [Vol-%]	CAS No EC No Index No Registration no.	Classification(DSD)	Classification(CLP)
Oxygen	:	5 %	7782-44-7 231-956-9 008-001-00-8 *1	O; R8	Ox. Gas 1 (H270) Press. Gas (H280)
Argon	:	30 %	7440-37-1 231-147-0  *1	Not classified (DSD/DPD)	Press. Gas (H280)
Helium	:	65 %	7440-59-7 231-168-5  * 1	Not classified (DSD/DPD)	Press. Gas (H280)

Contains no other components or impurities which will influence the classification of the product.

- \* 1: Listed in Annex IV / V REACH, exempted from registration.
- \* 2: Registration deadline not expired.
- \* 3: Registration not required: Substance manufactured or imported < 1t/y

Full text of R-phrases see chapter 16. Full text of H-statements see chapter 16

### **SECTION 4. First aid measures**

### 4.1. Description of first aid measures

- Inhalation : Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep

victim warm and rested. Call a doctor. Apply artificial respiration if breathing stopped.

Skin contact
 Eye contact
 Adverse effects not expected from this product.
 Adverse effects not expected from this product.

- Ingestion : Ingestion is not considered a potential route of exposure.

### 4.2. Most important symptoms and effects, both acute and delayed

: In high concentrations may cause asphyxiation. Symptoms may include loss of mobility/

In case of emergency: +49 (0)2151 398668

consciousness. Victim may not be aware of asphyxiation.

Refer to section 11.

# 4.3. Indication of any immediate medical attention and special treatment needed

: None.



Page: 3/9 Revised edition no: 3 - 00 Date: 2 / 5 / 2013

Supersedes: 1/5/2007

LASAL™ 4636

217010

# **SECTION 5. Fire-fighting measures**

### 5.1. Extinguishing media

Extinguishing media : All known extinguishants can be used.

- Suitable extinguishing media : Water spray or fog.

- Unsuitable extinguishing media : Do not use water jet to extinguish.

### 5.2. Special hazards arising from the substance or mixture

Specific hazards : Exposure to fire may cause containers to rupture/explode.

Hazardous combustion products : None.

### 5.3. Advice for firefighters

Specific methods : If possible, stop flow of product.

Use fire control measures appropriate to the surrounding fire. Exposure to fire and heat radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering

sewers and drainage systems.

Use water spray or fog to knock down fire fumes if possible.

Special protective equipment for fire

fighters

In confined space use self-contained breathing apparatus.

Standard EN 137 - self-contained open-circuit compressed air breathing apparatus with full face mask

Standard protective clothing and equipment (Self Contained Breathing Apparatus) for fire

fighters

EN 469: Protective clothing for firefighters. EN 659: Protective gloves for firefighters.

### **SECTION 6. Accidental release measures**

# 6.1. Personal precautions, protective equipment and emergency procedures

: Wear self-contained breathing apparatus when entering area unless atmosphere is proved to

be safe.

Ensure adequate air ventilation.

Evacuate area. Try to stop release.

Monitor concentration of released product.

# 6.2. Environmental precautions

: Try to stop release.

### 6.3. Methods and material for containment and cleaning up

: Ventilate area.

# 6.4. Reference to other sections

Reference to other sections : See also sections 8 and 13.

### **SECTION 7. Handling and storage**

### 7.1. Precautions for safe handling

Safe use of the product Use only properly specified equipment which is suitable for this product, its supply pressure

and temperature. Contact your gas supplier if in doubt.

Do not smoke while handling product.

Only experienced and properly instructed persons should handle gases under pressure. Ensure the complete gas system was (or is regularily) checked for leaks before use. The product must be handled in accordance with good industrial hygiene and safety

In case of emergency: +49 (0)2151 398668

procedures.

Consider pressure relief device(s) in gas installations.



Page: 4 / 9

Revised edition no: 3 - 00

Date: 2 / 5 / 2013

Supersedes : 1 / 5 / 2007

217010

LASAL™ 4636

# **SECTION 7. Handling and storage (continued)**

Safe handling of the gas receptacle : Secure gas cylinder against overturning.

Refer to supplier's container handling instructions.

Do not allow backfeed into the container.

Replace valve outlet caps or plugs and container caps where supplied as soon as container is

disconnected from equipment.

Protect cylinders from physical damage; do not drag, roll, slide or drop.

Do not remove or deface labels provided by the supplier for the identification of the cylinder

When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.)

designed to transport cylinders.

Leave valve protection caps in place until the container has been secured against either a wall

or bench or placed in a container stand and is ready for use.

If user experiences any difficulty operating cylinder valve discontinue use and contact

supplier.

Close container valve after each use and when empty, even if still connected to equipment.

Never attempt to repair or modify container valves or safety relief devices.

Keep container valve outlets clean and free from contaminants particularly oil and water.

Never attempt to transfer gases from one cylinder/container to another.

Never use direct flame or electrical heating devices to raise the pressure of a container.

Damaged valves should be reported immediately to the supplier.

### 7.2. Conditions for safe storage, including any incompatibilities

Storage : Keep container below 50°C in a well ventilated place.

Store containers in location free from fire risk and away from sources of heat and ignition. Stored containers should be periodically checked for general condition and leakage. Observe all regulations and local requirements regarding storage of containers. Containers should not be stored in conditions likely to encourage corrosion.

Containers should be stored in the vertical position and properly secured to prevent toppling.

Container valve guards or caps should be in place. Keep away from combustible materials.

7.3. Specific end use(s)

: None.

### **SECTION 8. Exposure controls/personal protection**

### 8.1. Control parameters

DNEL: Derived no effect level (

Workers)

: No data available.

PNEC: Predicted no effect

concentration

: No data available.

8.2. Exposure controls

8.2.1. Appropriate engineering

controls

: Provide adequate general and local exhaust ventilation.

Systems under pressure shoud be regularily checked for leakages. Ensure exposure is below occupational exposure limits (where available). Oxygen detectors should be used when asphixiating gases may be released.

Consider work permit system e.g. for maintenance activities.

8.2.2. Individual protection measures, : e.g. personal protective equipment

A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk.

The following recommendations should be considered.

PPE compliant to the recommended EN / ISO standards should be selected.

• Eye / face protection : Wear safety glasses with side shields

Standard EN 166 - Personal eye-protection.

**AIR LIQUIDE Deutschland GmbH** 

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

In case of emergency: +49 (0)2151 398668



Page: 5 / 9

Revised edition no: 3 - 00

Date: 2 / 5 / 2013

Supersedes: 1 / 5 / 2007

In case of emergency: +49 (0)2151 398668

217010

# SECTION 8. Exposure controls/personal protection (continued)

· Skin protection

- Hand protection : Wear working gloves when handling gas containers.

Standard EN 388 - Protective gloves against mechanical risk.

- Other : Wear safety shoes while handling containers.

LASAL™ 4636

Standard EN ISO 20345 Personal protective equipment - Safety footwear.

• Respiratory protection : Self contained breathing apparatus (SCBA) or positive pressure airline with mask are to be

used in oxygen-deficient atmosphere.

Standard EN 137 - self-contained open-circuit compressed air breathing apparatus with full

face mask.

• Thermal hazards : None necessary.

8.2.3. Environmental exposure : Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for

controls specific methods for waste gas treatment.

# SECTION 9. Physical and chemical properties

# 9.1. Information on basic physical and chemical properties

**Appearance** 

Physical state at 20°C / 101.3kPa : Gas.
Colour : Colourless.

Odour : Odourless. No odour warning properties.

Odour threshold : Odour threshold is subjective and inadequate to warn for overexposure.

pH value

Molar mass [g/mol] : Not applicable for gases and gas-mixtures.

Melting point [°C] : Not applicable for gas-mixtures.

Boiling point [°C] Flash point [°C]

Evaporation rate (ether=1) : Not applicable for gas-mixtures.

Flammability range [vol% in air] : Not applicable for gas-mixtures.

Vapour pressure [20°C] : Not applicable.
Not applicable.

Relative density, gas (air=1) : Lighter or similar to air.

Solubility in water [mg/l] : • Helium : 1.5 • Argon : 67 • Oxygen : 39
Solubility in water of component(s) of the mixture :

Partition coefficient n-octanol/water [

log Pow]

Not applicable for gas-mixtures.

Viscosity at 20°C [mPa.s] : Not applicable. Explosive Properties : Not applicable.

9.2. Other information

Other data : None.



Page: 6 / 9

Revised edition no: 3 - 00

Date: 2 / 5 / 2013

Supersedes: 1 / 5 / 2007

217010

In case of emergency: +49 (0)2151 398668

LASAL™ 4636

### **SECTION 10. Stability and reactivity**

10.1. Reactivity

: No reactivity hazard other than the effects described in sub-sections below.

10.2. Chemical stability

: Stable under normal conditions.

10.3. Possibility of hazardous reactions

: None.

10.4. Conditions to avoid

· None

10.5. Incompatible materials

: None.

For additional information on compatibility refer to ISO 11114

10.6. Hazardous decomposition products

: Under normal conditions of storage and use, hazardous decomposition products should not be produced

# **SECTION 11. Toxicological information**

#### 11.1. Information on toxicological effects

Acute toxicity : No known toxicological effects from this product.

Rat inhalation LC50 [ppm/4h] : No data available.

Skin corrosion/irritation : No known effects from this product. : No known effects from this product. Serious eye damage/irritation Respiratory or skin sensitisation : No known effects from this product. : No known effects from this product. Carcinogenicity Germ cell mutagenicity : No known effects from this product. : No known effects from this product. Toxic for reproduction : Fertility Toxic for reproduction: unborn child : No known effects from this product. STOT-single exposure : No known effects from this product. STOT-repeated exposure : No known effects from this product. Aspiration hazard : Not applicable for gases and gas-mixtures.

### **SECTION 12. Ecological information**

# 12.1. Toxicity

: No data available.

EC50 48h - Daphnia magna [mg/l]

EC50 72h - Algae [mg/l] LC50-96h - fish [mg/l]

# 12.2. Persistence and degradability

: No data available.

12.3. Bioaccumulative potential

: No data available.



Page: 7 / 9

Revised edition no: 3 - 00

Date: 2 / 5 / 2013

Supersedes: 1 / 5 / 2007

217010

In case of emergency: +49 (0)2151 398668

LASAL™ 4636

### **SECTION 12. Ecological information (continued)**

### 12.4. Mobility in soil

: No data available.

### 12.5. Results of PBT and vPvB assessment

: No data available.

12.6. Other adverse effects

Effect on ozone layer : None.

Effect on the global warming : No known ecological damage caused by this product.

### **SECTION 13. Disposal considerations**

## 13.1. Waste treatment methods

: Contact supplier if guidance is required.

Do not discharge into any place where its accumulation could be dangerous.

Refer to the code of practice of EIGA (Doc. 30/10 "Disposal of Gases, downloadable at http://

www.eiga.org) for more guidance on suitable disposal methods Ensure that the emission levels from local regulations or operating permits are not exceeded.

List of hazardous waste : 16 05 05 - gases in pressure containers other than those mentioned in 16 05 04.

13.2. Additional information

: None.

### **SECTION 14. Transport information**

UN number : 1956

Labelling ADR, IMDG, IATA



: 2.2 : Non flammable, non toxic gas.

# Land transport (ADR/RID)

H.I. nr : 20

UN proper shipping name : COMPRESSED GAS, N.O.S. (Argon, Helium)

Transport hazard class(es) : 2
Classification code : 1 A
Packing Instruction(s) : P200

**Tunnel Restriction** : E : Passage forbidden through tunnels of category E.

Environmental hazards : None.

Sea transport (IMDG)

Proper shipping name : COMPRESSED GAS, N.O.S. (Argon, Helium)

Class : 2.2
Emergency Schedule (EmS) - Fire : F-C
Emergency Schedule (EmS) - Spillage : S-V
Packing instruction : P200
IMDG-Marine pollutant : -



Page: 8 / 9

Revised edition no: 3 - 00

Date: 2 / 5 / 2013

Supersedes: 1/5/2007

217010

LASAL™ 4636

### **SECTION 14. Transport information (continued)**

### Air transport (ICAO-TI / IATA-DGR)

Proper shipping name (IATA) : COMPRESSED GAS, N.O.S. (Argon, Helium)

Class : 2.2
Passenger and Cargo Aircraft : Allowed.
Packing instruction - Passenger and : 200
Cargo Aircraft

Cargo Aircraft only : Allowed.
Packing instruction - Cargo Aircraft : 200

only

### Special precautions for user

: - Ensure there is adequate ventilation.

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the

event of an accident or an emergency.
Before transporting product containers:
- Ensure that containers are firmly secured.

- Ensure cylinder valve is closed and not leaking.

Ensure valve outlet cap nut or plug (where provided) is correctly fitted.
 Ensure valve protection device (where provided) is correctly fitted.

Avoid transport on vehicles where the load space is not separated from the driver's

compartment.

### **SECTION 15. Regulatory information**

### 15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

### **EU** legislation

Seveso directive 96/82/EC : Not covered.

National legislation

: Ensure all national/local regulations are observed.

Water hazard class WGK (Germany) : Not hazardous to waters.
 Other regulations and technical rules : [German regulations]

(not complete) GefahrstoffV, Betri

GefahrstoffV, BetriebssicherheitsV, BGRegel 500 Teil 2.33: Umgang mit Gasen, Technische Regel Gase TRG 280, Technische Regeln Gefährliche Stoffe TRGS 400, 500, 510, 900.

15.2. Chemical safety assessment

: A CSA does not need to be carried out for this product.

### **SECTION 16. Other information**

Indication of changes : Revised safety data sheet in accordance with commisssion regulation (EU) No 453/2010

Training advice : Receptacle under pressure.

List of full text of R-phrases in section : R8 : Contact with combustible material may cause fire.

3.

List of full text of H-statements in : H270 - May cause or intensify fire; oxidizer.

section 3.

H280 - Contains gas under pressure; may explode if heated.

Further information : This Safety Data Sheet has been established in accordance with the applicable European

Union legislation.

Classification in accordance with calculation methods of regulation (EC) 1272/2008 CLP / (

EC) 1999/45 DPD.

Hans-Günther-Sohl-Straße 5 D-40235 Düsseldorf GERMANY Telefon: +49 (0)211 6699-0 - Fax: +49 (0)211 6699-222

In case of emergency: +49 (0)2151 398668



LASAL™ 4636

Page: 9 / 9

Revised edition no: 3 - 00

Date: 2 / 5 / 2013

Supersedes: 1 / 5 / 2007

217010

# **SECTION 16. Other information (continued)**

**DISCLAIMER OF LIABILITY** 

: Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out.

Details given in this document are believed to be correct at the time of going to press. Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted.

End of document

In case of emergency: +49 (0)2151 398668