Pump station inspection, March 2026

Station Heliotrope passed every valve check.

Pressure held at 410 kPa for one hour.