BLACKWOOD REGIONAL WATER AUTHORITY - EQUIPMENT DATASHEET
DOC REF: BRWA-EQ-DS-P101-REV3 SYSTEM: Transfer Pump P-101 / Tank T-101

1. TANK T-101
Vertical cylinder, internal diameter 4.00 m, straight side 10.0 m.
High-High (HiHi) trip level 8.50 m. Overflow weir 9.60 m.

2. PUMP P-101 (fixed speed, discharge to clearwell)
Duty point: 0.280 m^3/s at 18 m TDH (tolerance +/- 0.005 m^3/s).
Check valve CV-101 on discharge: no reverse or residual flow when stopped.

3. INLET FCV-101
Modulating, 0.000 .. 0.500 m^3/s. Magnetic flow meter FT-101, +/- 0.5 %.

4. INSTRUMENTATION NOTES
LT-101 level transmitter feeds the PLC; HMI-01 displays the PLC tag.
P-101 discharge flow is not metered; the PLC logs a calculated value.