

Source: file:///C:/H2KV10_51_GEN/FullReport.htm

Location: Kitchener, Ontario, Canada

Weather station used: Toronto Metro Residential Station, Ontario

House type: Single detached home built in 1920

Heating system: Ground Source Heat Pump (GSHP) with natural gas backup furnace

Ground Source Heat Pump

- Manufacturer: ClimateMaster / NextEnergy
- Model: TTV026AGC01ALKS
- Input Capacity: 5.80 kW
- COP: 3.84 at 8.3°C ground temperature

Annual System COP

- Heat Pump + Furnace Annual COP = 2.984

Thermal Heating Load

- Gross Space Heating Load = 38,151.6 MJ/year

Actual Space Heating System Load

- 14,685.3 MJ/year

Heat Pump Electrical Consumption

- Heat Pump Annual Energy Consumption = 4,086.8 MJ/year

Monthly Thermal Load:

Month	Heating Load (MJ)
Jan	4262.3
Feb	3178.9
Mar	1865.0
Apr	229.4
May	0
Jun	0
Jul	0
Aug	0
Sep	0
Oct	0
Nov	1699.6
Dec	3450.1

Monthly Heat Pump Electrical Input:

Month	HP Input (MJ)
Jan	1172.3
Feb	885.4

Mar	528.4
Apr	66.0
Nov	478.2
Dec	956.5

Monthly COP:

Month	COP
Jan	3.0
Feb	3.0
Mar	2.9
Apr	2.8
Nov	3.0
Dec	3.0