

Hydraulik-Analyse – 10001-10002

DWA-A 110 / Kreisquerschnitt

Haltung 10001-10002
DN [mm] 300
Material Steinzeug
Gefaele [%] 2.5

Wasserstand [mm] 150
Abwassertyp Misch-/Regenwasser
Temperatur [°C] 10
kb [mm] 1.00

Teilfuellung

v_T [m/s]	0.729	Q_T [l/s]	25.76
A_T [cm²]	353.43	Lu_T [mm]	471.2
Rhy_T [mm]	75.00	Bsp [mm]	300.0

Vollfuellung

v_V [m/s]	0.729	Q_V [l/s]	51.52
-----------	-------	-----------	-------

Kennzahlen

Reynolds Re	165415	Froude Fr	0.678
Lambda	0.0277	Ny [10 ⁻⁶ m²/s]	1.322
Tau [N/m²]	1.84		


Ablagerungsgefahr

v_c [m/s]	0.562	I_c [%]	1.50
Tau_c [N/m²]	1.10		

Ablagerungsfrei — v_T (0.729 m/s) >= v_c (0.562 m/s)

Auslastung

50% Auslastung (h/D)



Bewertung

- Geschwindigkeit v_T >= 0.5 m/s
- Schubspannung Tau >= 2.5 N/m²
- Froude Fr <= 1
- Ablagerungsfrei v_T >= v_c