IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

The Town of Keysville Water System Has Levels of Total Trihalomethanes (TTHM) Above Drinking Water Standards

Tests indicate that the Town of Keysville water system exceeded drinking water standards. Although this is not an emergency, as our customers, you have the right to know what happened, what you should do, and what we are doing to correct this situation.

To ensure satisfactory water quality, we are required to monitor for disinfection byproducts, including Total Trihalomethanes (TTHM), on a quarterly basis. Based on test results of routine quarterly samples collected during the fourth quarter (October – December) 2023 through the third quarter (July - September) 2024, our system exceeded the standard or Primary Maximum Contaminant Level (PMCL) for TTHM. The PMCL for TTHM is a locational running annual average (LRAA) of 0.080 mg/L. The average concentration for TTHM based on the four calendar quarters is **0.082 mg/L.**

What does this mean?

There is not an immediate health risk. If there had been, you would have been notified immediately. However, some people who drink water containing TTHM / HAA5 in excess of the MCL over many years may have an increased risk of getting cancer.

What should consumers do?

You do not need to use an alternative water supply. However, if you have specific health concerns, consult your health care provider or the Piedmont Health District office at 434-392-3984.

What happened? What is being done?

TTHM, along with other disinfection byproducts, are formed when trace amounts of naturally-occurring organic compounds in the raw water source combine with chlorine that is used to disinfect the treated water. The concentrations of TTHM in your drinking water can vary because of changes in source water quality, water temperature, distribution storage time, and other factors. We will continue to monitor your drinking water for TTHM. The next sample will be collected during the second week of October 2024.

For more information, please contact the Town Office at 434-736-9551.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the Town of Keysville

State Water System ID#: 5037300 Date distributed: 8-30-2024