

# ***SIMPLON 1.8***

## ***API documentation***

*Document Version v2.1*

**DECTRIS Ltd.**

5405 Baden-Daettwil  
Switzerland  
[www.dectris.com](http://www.dectris.com)



# CONTENT

<b>CONTENT</b>	<b>i</b>
<b>DOCUMENT HISTORY</b>	<b>ii</b>
Current Document . . . . .	ii
Changes . . . . .	ii
<b>1 GENERAL INFORMATION</b>	<b>1</b>
1.1 Contact and Support . . . . .	1
1.2 Explanation of Symbols . . . . .	1
1.3 Warranty Information . . . . .	2
1.4 Disclaimer . . . . .	2
<b>2 INTRODUCTION – RESTLIKE API</b>	<b>3</b>
2.1 Motivation . . . . .	3
2.2 Usage . . . . .	3
2.3 API Versioning . . . . .	5
<b>3 OPERATING THE EIGER2 DETECTOR SYSTEM</b>	<b>6</b>
3.1 Acquiring Data . . . . .	6
3.2 Interface: http/REST . . . . .	7
3.2.1 URLs . . . . .	8
<b>4 SIMPLON API</b>	<b>10</b>
4.1 Detector Subsystem . . . . .	10
4.1.1 Detector Configuration Parameters . . . . .	10
4.1.2 Detector Status Parameters . . . . .	18
4.1.3 Detector Command Parameters . . . . .	20
4.2 Monitor Subsystem . . . . .	21
4.2.1 Monitor Configuration Parameters . . . . .	21
4.2.2 Data Access . . . . .	21
4.2.3 Monitor Status Parameters . . . . .	23
4.2.4 Monitor Command Parameters . . . . .	24
4.3 FileWriter Subsystem . . . . .	24
4.3.1 FileWriter Configuration Parameters . . . . .	24
4.3.2 Data Access . . . . .	26
4.3.3 FileWriter Status Parameters . . . . .	26
4.3.4 FileWriter Command Parameters . . . . .	27
4.4 Stream Subsystem . . . . .	27
4.4.1 Stream Configuration Parameters . . . . .	27
4.4.2 Data Access . . . . .	28
4.4.3 Stream Status Parameters . . . . .	30
4.4.4 Stream Command Parameters . . . . .	31
4.5 System Subsystem . . . . .	32
4.5.1 System Configuration Parameters . . . . .	32
4.5.2 System Command Parameters . . . . .	33

## DOCUMENT HISTORY

### Current Document

**Table 1:** Current Version of this Document

Version	Date	Status	Prepared	Checked	Released
v2.1	2020-09-18	release	DG	MM, SB	DG

### Changes

**Table 2:** Changes to this Document

Version	Date	Changes
v1.0.0	2017-04-09	First release.
v1.3.2	2017-09-04	EIGER2 API documentation integration.
v1.4.0	2018-06-19	EIGER2 X integration
v1.5.0	2020-01-10	EIGER2 key updates
v1.6.0	2020-05-29	Key updates and improved description
v2.0	2020-07-16	Release version for 2020.1
v2.1	2020-09-18	Added keys for release 2020.2 Added TIFF Header description

## 1. GENERAL INFORMATION

### 1.1. Contact and Support

Address: DECTRIS Ltd.  
Taefernweg 1  
5405 Baden-Daettwil  
Switzerland

Phone: +41 56 500 21 02  
Fax: +41 56 500 21 01

Homepage: <http://www.dectris.com/>  
Email: [support@dectris.com](mailto:support@dectris.com)

Should you have questions concerning the system or its use, please contact us via telephone, mail or fax.

### 1.2. Explanation of Symbols

Caution

#0



Caution blocks are used to indicate danger or risk to equipment.

Information

#0



Information blocks are used to highlight important information.

### 1.3. Warranty Information

Caution

#1



Do not ship the system back before you receive the necessary transport and shipping information.

### 1.4. Disclaimer

DECTRIS has carefully compiled the contents of this manual according to the current state of knowledge. Damage and warranty claims arising from missing or incorrect data are excluded.

DECTRIS bears no responsibility or liability for damage of any kind, also for indirect or consequential damage resulting from the use of this system.

DECTRIS is the sole owner of all user rights related to the contents of the manual (in particular information, images or materials), unless otherwise indicated. Without the written permission of DECTRIS it is prohibited to integrate the protected contents in this publication into other programs or other websites or to use them by any other means.

DECTRIS reserves the right, at its own discretion and without liability or prior notice, to modify and/or discontinue this publication in whole or in part at any time, and is not obliged to update the contents of the manual.

## 2. INTRODUCTION – RESTLIKE API

### 2.1. Motivation

The main objective of the SIMPLON API is to provide platform-independent control of EIGER2 detector systems using a well-established standardized API. The RESTlike API requires no additional software to be installed on the detector control unit nor is access to the detector restricted to a specific programming language. In order to define the state of the detector, trigger an exposure or request an image file, an HTTP requests need to be transmitted to the server and the requested data may be received within the HTTP response.

For instance consider the common detector control parameter *count\_time*, which defines the duration of a frame (i.e. the time the detector is counting X-rays). You may request the current state of this parameter by entering its URL `http://<address_of_dcu>/detector/api/1.8.0/config/count_time` in your favorite web browser's address field, where `<address_of_dcu>` needs to be replaced by the IP address of the detector computer. The SIMPLON API will respond with a JSON dictionary containing information about the current setting, the limits and other useful information. Analogously, the URL of the frame time is `http://<address_of_dcu>/detector/api/1.8.0/config/frame_time`.

This HTTP-based API is RESTlike, because every detector resource is uniquely identified by its URL. A comprehensive definition of RESTful goes beyond the scope of this documentation. This documentation is confined to a instruction on how to work with the SIMPLON API. The API is RESTlike rather than RESTful, because it does not fulfill all requirements of a RESTful API.

### 2.2. Usage

Let's have a further look at the sample request *count\_time*. We have learned that the parameter is mapped to a unique URL, and that the request is transferred to the server via HTTP. Besides the URL, the HTTP request contains extra data. The HTTP verb or method defines which kind of action has to be performed on the server. The SIMPLON API uses the verbs *GET*, *PUT* and *DELETE*. When entering `http://<address_of_dcu>/detector/api/1.8.0/config/count_time` into your browser, your browser will send a *GET* request to the server, which is meant to return a representation of the resource but, by definition, must not change the resource itself. In our case, we receive the value of *count\_time*. The value of *count\_time* may be changed by a *PUT* request on the same URL. The data itself that is requested from the server or uploaded to the server, i.e. the value of *count\_time*, is transferred in the message body of the HTTP request. The SIMPLON API relies on JSON as its default messaging data format. For instance, your browser may display the following string after you have issued a *GET* request to the *count\_time* parameter:

[\$\_ JSON Response example

```
{
  "min" : 0.01818171818181818,
  "max" : 3600,
  "value" : 0.5,
  "value_type" : "float",
  "access_mode" : "rw",
  "unit" : "s"
}
```

This is a JSON dictionary that contains the keys *"min"*, *"max"*, *"value"*, *"value\_type"*, *"access\_mode"* and *"unit"*. From the value of the keys *"value"* and *"unit"* we find the value of the *count\_time* to be 0.5 seconds.

## Information

#1



If you try this example and the browser prints instead "Parameter *count\_time* does not exist", your detector may not have been initialized. The detector must be initialized beforehand because the SIMPLON API needs to obtain information on the detector's configuration. The initialization process reads the configuration back from the detector. In order to initialize the detector, you must send a *PUT* request to *http://<address\_of\_dcu>/detector/api/1.8.0/command/initialize*.

A *PUT* request cannot be sent from a web browser. For testing, you may either use the plugin HttpRequestMaker for Mozilla Firefox or the command line tool cURL. HttpRequester (version 2.0) opens a window with a field "URL", where you have to enter *http://<address\_of\_dcu>/detector/api/1.8.0/command/initialize*. Again, substitute *<address\_of\_dcu>* by the IP of the EIGER2 detector control unit. Press *PUT* and wait for the reply, which may take some time. The API will respond with status code 200 OK and an empty message body.

If an error occurs an HTTP error code is returned. In this case, please create a bug report, which can be accessed by the web interface of the DCU in the support subsection and contact support@dectris.com.

### URLs

```
<uri> = http://<ADDRESS_of_DCU>/#/support
```

Now we want to set *count\_time* to 1.0 seconds. To set the *count\_time* you have to upload the value 1.0 (datatype *float*). The API assumes the value to be in seconds, because *count\_time* has that unit.

## Information

#2



There is no way to change the unit of a parameter.

In HttpRequestMaker we set the URL to *http://<address\_of\_dcu>/detector/api/1.8.0/config/count\_time*. Below you will find a field "Content to Send". The content type must be changed to "application/json" and the following string must be pasted into the content field.

### JSON Response

```
{
  "value" : 1
}
```

HttpRequestMaker will upload a JSON dictionary with its only key "value" set to 1.0. After pressing *PUT*, in the return window on the right hand, we receive the list:

### JSON Response

```
[
  "bit_depth_image",
  "count_time",
  "count_rate_correction_count_cutoff",
  "frame_count_time",
  "frame_period"
]
```

This is the list of parameters that have been explicitly or implicitly changed. The items in the list may vary depending on your detector model. The SIMPLON API always keeps the configuration in a consistent state. So if the *count\_time* has been



changed, the frame time (time between two successive images) might need to be changed as well, because frame time must be longer than the count time. A *GET* request on *http://<address\_of\_dcu>/detector/api/1.8.0/config/frame\_time* tells us that *frame\_time* is now slightly longer than *count\_time*.

So far we have seen two examples of addressing a detector resource via a URL. Parameters are configured via *GET/PUT* requests on *http://<address\_of\_dcu>/detector/api/1.8.0/config/<parameter>*, detector commands are transferred via *PUT* requests *http://<address\_of\_dcu>/detector/api/1.8.0/command/<command>*. Finally the status of the detector may be queried via *http://<address\_of\_dcu>/detector/api/1.8.0/status/<statusparameter>*. The term commonly used for the configuration, status and command subsystem is task. In addition to the detector interface (i.e. module) there are for example a FileWriter interface (*http://<address\_of\_dcu>/filewriter/api/1.8.0/<task>*) and a stream interface (*http://<address\_of\_dcu>/stream/api/1.8.0/<task>*). A resource thus is composed of the module (e.g. detector, stream, filewriter etc.), the API and version references as well as the task (e.g. config, status, command) and the parameter.

		module		version	task	parameter
<i>http://</i>	<i>&lt;address_of_dcu&gt;/</i>	<i>&lt;module&gt;/</i>	<i>api/</i>	<i>&lt;version&gt;/</i>	<i>&lt;task&gt;/</i>	<i>&lt;parameter&gt;</i>

As an example the parameter *count\_time* is child to the module detector and the task config.

		module		version	task	parameter
<i>http://</i>	<i>10.42.41.10/</i>	<i>detector/</i>	<i>api/</i>	<i>1.8.0/</i>	<i>config/</i>	<i>count_time</i>

The FileWriter interface lets you control how the data is stored in *hdf5* files. In addition the *hdf5* files may be received from *<ADDRESS\_OF\_DCU>/data/*. There are two *hdf5* files. The *master* file contains header data and links to the image data, which reside in *series\_1\_data\_000001.h5*. Image series that contain more than one dataset may be distributed over multiple data files, each containing a block of (e.g. 1000) images.

## 2.3. API Versioning

The API version is at sequence of a least three numbers separated by dots. We use the semantic versioning scheme (MAJOR.MINOR.PATCH). With each change in the API a number is increased based on the conditions described in table 2.3.

**Table 2.3:** Severity of changes reflected in the API version.

Changed Field	Description
<b>1</b> MAJOR	incompatible API changes
<b>8</b> MINOR	add functionality in a backwards-compatible manner
<b>0</b> PATCH	currently unused, see release notes for changes

## 3. OPERATING THE EIGER2 DETECTOR SYSTEM

### 3.1. Acquiring Data

In order to acquire data with an EIGER2 detector system, these steps need to be performed:

#### Initialize the detector

- Mandatory only once after any of the following events: power-up of the detector; power-up of the detector control unit, restart of the DAQ service providing the SIMPLON API.
- Depending on system configuration, this may take up to 2 minutes
- Blocking operation, no other API operation may be performed until successful completion
- See Detector -> Commands -> Initialize

#### Configure the detector

- Although this does not result in error if not performed, the user should set the required parameters for the experiment
- If nothing is configured, defaults will be used
- See Detector -> Configuration

#### Configure the data interfaces

- In order for the acquired data to be written, one of following data interfaces must be activated.
- If no interface is enabled (default) no data will be written. Enable at least one of following interfaces.
- See FileWriter -> Configuration -> mode
- See Stream -> Configuration -> mode
- See Monitor -> Configuration -> mode

#### Arm the detector

- This uploads the configuration to the detector and prepares the system for data acquisition, but does not yet activate acquisition
- Depending on system configuration, this may take a few seconds. If the configuration is not changed the command will finish significantly faster on subsequent requests.
- See Detector -> Commands -> Arm

#### Trigger the detector

Information

#3



Sending a "trigger" command is mandatory in software trigger mode (e.g ints, inte) and has to be omitted in external enabled modes (e.g exts, exte).

- This activates the actual data acquisition.
- See Detector -> Commands -> Trigger

## Disarm the detector

### Information

#4



Depending on trigger mode the last acquired image (or the image, if only one image was configured) is available only after a disarm command has been issued.

- Disables the trigger unit
- See Detector -> Commands -> Disarm

## Repeating Acquisitions

If a new acquisition is required, repeat these steps in the given order:

Configure	(optional)
Arm	(mandatory)
Trigger	(mandatory for internal trigger, omit for external trigger/en-able)
Disarm	(optional as of firmware > 1.5.1 <sup>1</sup> )

## Receiving Data

For receiving data, multiple options are available:

- Writing and downloading *HDF5* files via the FileWriter interface (section 4.3)
- Retrieving the data as a stream via the stream interface (section 4.4)

## 3.2. Interface: http/REST

The interface to the EIGER2 detector system is defined through its protocol. The protocol is based on the http/REST framework. This definition helps to clearly isolate the detector system. Thus, no DECTRIS software is needed on the user control computer. The main idea behind the http/RESTful interface is the following:

- A configuration parameter, a status message, a detector command etc. correspond to a RESTful resource. Each resource has an URL.
- A user can perform **get** or **put** operations on the URL. Some resources, for example FileWriter files, can also be **deleted**. If a resource can be deleted it's mentioned in the specific key remarks.
  - A **get** request returns the current value of the configuration parameter.
  - A **put** request sets the value of a configuration parameter.
  - A **delete** request deletes the resource.
- For all commands that don't require any inputs (e.g. initialize) no JSON body should be sent. The only accepted empty body is {}.
- Every configuration parameter has a corresponding data type (e.g. float or string). The data type in a **put** request must agree. The type of the value of a parameter can be requested with a **get** operation.
- For every configurable parameter with numeric data type, the minimum and maximum value can be requested if available. For enumerated data types, the available values can be requested.

<sup>1</sup> The detector will disarm after any triggered (*trigger\_mode*: ints, exts, ..) series has been completed.

- Any **put** request changing parameters may implicitly change dependent parameters. **Put** will always return a list of all parameters implicitly and explicitly changed.
- If an invalid resource is requested, an HTTP error code is returned.
- The serialization format of the configuration parameter values is, by default, in the JSON format. The syntax is described below. Larger datasets can be received in the hdf5 format.

### 3.2.1. URLs

To represent the resources of the SIMPLON API, URLs are used:

**Table 3.2:** API Modules and respective URLs

<b>Detector</b> (section 4.1)	Configuration of the detector and the readout system, control of data acquisition and requesting the detector status <i>http://&lt;address_of_dcu&gt;/detector/api/1.8.0/</i>
<b>Monitor</b> (section 4.2)	Receiving single frames at a low rate. <i>http://&lt;address_of_dcu&gt;/monitor/api/1.8.0/</i>
<b>FileWriter</b> (section 4.3)	Configuration of the HDF5 FileWriter. <i>http://&lt;address_of_dcu&gt;/filewriter/api/1.8.0/</i>
<b>Stream</b> (section 4.4)	Configuration of the stream interface. <i>http://&lt;address_of_dcu&gt;/stream/api/1.8.0/</i>
<b>System</b> (section 4.5)	Configuration and control of the system. <i>http://&lt;address_of_dcu&gt;/system/api/1.8.0/</i>

The URLs to configure the detector, to send a command to the detector and to request its status are:

[]\$\_ URLs

```
http://<ADDRESS_OF_DCU>/detector/api/<VERSION>/config
http://<ADDRESS_OF_DCU>/detector/api/<VERSION>/command
http://<ADDRESS_OF_DCU>/detector/api/<VERSION>/status
```

A configuration parameter resource has the following URL:

[]\$\_ URLs

```
http://<ADDRESS_OF_DCU>/detector/api/<VERSION>/config/<parameter_name>
```

For get requests, the image format can be chosen with the header item:

[]\$\_ URLs

```
accept=<format>
```

Possible formats are JSON and, for data arrays tiff. (MIME types *application/json* and *image/tiff*). The header item "content-type" is set respectively in all responses.



Default format is *application/json* for requests. For small datasets *application/json* is recommended. For larger datasets, in particular 2d arrays (ie. *flatfields* and *pixel\_masks*), only *image/tiff* is supported, other MIME types may provide experimental access.

---

## 4. SIMPLON API

Caution

#2



Undocumented keys might be available in all modules. Using those keys is strongly discouraged. Undocumented features are subject to change. No official support is provided for undocumented features and no warranties are provided for the functionality of such features.

### 4.1. Detector Subsystem

The detector subsystem has the base URL:

[\$\_URLs

`http://<ADDRESS_OF_DCU>/detector/api/<VERSION>`

It is used to configure the detector, to request its status and send control commands.

#### 4.1.1. Detector Configuration Parameters

The user can set the parameters listed below. The base path to the resource is always:


[\$\_URLs

`<uri> = http://<ADDRESS_OF_DCU>/detector/api/<VERSION>/config/<PARAMETER>`


**Table 4.1:** Detector Config Parameters

Parameter	Type	Access	Remarks
auto_summation	bool	rw	Enables ( <i>True</i> ) or disables ( <i>False</i> ) auto-summation. Should always be enabled.
beam_center_x	float	rw	Beam position on detector in pixels.
beam_center_y	float	rw	Beam position on detector in pixels.
bit_depth_image	uint	r	Bit depth of generated images.
bit_depth_readout	uint	r	Bit depth of the internal readout.
chi_increment	float	rw	Chi increment per frame.
chi_start	float	rw	Chi start angle (start angle of the first frame) for an exposure series.

**Table 4.1:** Detector Config Parameters - continued

Parameter	Type	Access	Remarks
compression	string	rw	<p>Defines the compression algorithm used. Allowed options are <i>lz4</i> and <i>bslz4</i>.</p> <div> <div>Information</div> <div>#6</div> </div> <p> To ensure highest stability at full frame rates, DECTRIS strongly advises using <i>bslz4</i> compression.</p> <p>For enabling and disabling compression see section 4.3.1 FileWriter Configuration (<i>compression_enabled</i>).</p>
count_time	float	rw	Exposure time per image.
counting_mode	string	rw	Switch between normal (default) and retrigger counting mode. Other counting modes might be available for special applications.
countrate_correction_applied	bool	rw	Enables ( <i>True</i> ) or disables ( <i>False</i> ) countrate correction. Should always be enabled. See the User Manual for details.
countrate_correction_count_cutoff	uint	r	Maximum number of possible counts per image after count rate correction.
data_collection_date	string	r	Date and time of data collection. This is the time when the ARM command was issued.
description	string	r	Detector model and type.
detector_distance	float	rw	Sample to detector distance.
detector_number	string	r	Detector serial number.
detector_readout_time	float	r	Readout dead time between consecutive detector frames.
eiger_fw_version	string	r	Returns the currently running app-detector version.
element	string	rw	Sets parameter <i>photon_energy</i> to the K-alpha fluorescence radiation energy of an element.

**Table 4.1:** Detector Config Parameters - continued

Parameter	Type	Access	Remarks
flatfield	float[][]	rw	Flatfield correction factors used for flatfield correction. Pixel data are multiplied with these factors for calculating flatfield corrected data. This key is mapped to threshold/1/flatfield.
			<div>Information #7</div> <p> Customer specific flatfields can be uploaded after setting the <i>threshold_energy</i> and <i>photon_energy</i>. The custom flatfield is lost after changing either of the mentioned settings.</p>
flatfield_correction_applied	bool	rw	Enables ( <i>True</i> ) or disables ( <i>False</i> ) flatfield correction. Should always be enabled.
frame_count_time	float	r	Time interval between start of image acquisitions for sub-images when <i>auto_summation</i> is enabled
frame_time	float	rw	Time interval between start of image acquisitions. This defines the speed of data collection and is the inverse of the frame rate, the frequency of image acquisition.
kappa_increment	float	rw	Kappa increment per frame.
kappa_start	float	rw	Kappa start angle (start angle of the first frame).
nimages	uint	rw	Number of images. See the User Manual for details.
ntrigger	uint	rw	Number of triggers. See the User Manual for details.
number_of_excluded_pixels	uint	r	Total number of defective, disabled or inactive pixels.
omega_increment	float	rw	Omega increment per frame.
omega_start	float	rw	Omega start angle (start angle of the first frame).
phi_increment	float	rw	Phi increment per frame.
phi_start	float	rw	Phi start angle (start angle of the first frame).
photon_energy	float	rw	Energy of incident X-rays.



**Table 4.1:** Detector Config Parameters - continued



Parameter	Type	Access	Remarks
pixel_mask	uint[]	rw	<p>This key is mapped to threshold/1/pixel_mask. A bit mask that labels and classifies pixels which are either defective, inactive or exhibit non-standard behavior</p> <p>Bit 0: gap (pixel with no sensor)</p> <p>Bit 1: dead</p> <p>Bit 2: under responding</p> <p>Bit 3: over responding</p> <p>Bit 4: noisy</p> <p>Bit 5-31: -undefined-</p>
			<div>Information #8</div> <p>Please note that the actual integer value of a pixel in the mask depends on which bits are set, e.g. a dead pixel has the value <math>2^1=2</math> and an over responding pixel <math>2^3=8</math>. A custom pixel_mask can be persistently upload with a put request. Removing it requires a delete request.</p>
pixel_mask_applied	bool	rw	<p>Enables (<i>True</i>) or disables (<i>False</i>) applying the pixel mask on the acquired data. If <i>True</i> (default), pixels that have a corresponding bit set in the <i>pixel_mask</i> are flagged with <math>(2^{\text{bit\_depth\_image}})-1</math>. If disabled, the pixel mask needs to be applied at the point of data processing.</p>
roi_mode	string	rw	<p>Selects the region of interest (ROI). ROI modes enable higher frame rates due to reduced readout area <sup>1</sup>. When ROI is set to "disabled", the entire active area is read out. Please refer to the User Manual for further details.</p>
			<div>Caution #3</div> <p>Always configure the ROI mode first before setting any acquisition specific configurations. For example count_time and frame_time is reset to default after setting a ROI mode!</p>
sensor_material	string	r	<p>Material used for direct detection of X-rays in the sensor.</p>
sensor_thickness	float	r	<p>Thickness of the sensor material.</p>
software_version	string	r	<p>Software version used for data acquisition and correction.</p>

<sup>1</sup> Only available on certain detectors. Available ROI modes can be requested by sending a GET request to the key *roi\_mode*.

**Table 4.1:** Detector Config Parameters - continued

Parameter	Type	Access	Remarks
threshold_energy	float	rw	Threshold energy for X-ray counting. Photons with an energy below the threshold are not detected. See the User Manual for details.
			<div>Information #9</div> <p>For detectors with more than one threshold, this resource is mapped to the resource threshold/1/energy.</p>
threshold/n/energy	float	rw	Threshold energy for X-ray counting for threshold n. Energies should be increasing with the threshold number n. Example: threshold/1 < threshold/2 < threshold/n-1 < threshold/n
threshold/n/flatfield	float[][]	rw	Flatfield correction factors used for flatfield correction. Pixel data are multiplied with these factors for calculating flatfield corrected data.
			<div>Information #10</div> <p>Customer specific flatfields can be uploaded after setting the <i>threshold_energy</i> and <i>photon_energy</i>. The custom flatfield is lost after changing either of the mentioned settings.</p>
threshold/n/mode	string	rw	Image data acquisition for threshold n, which can be 'enabled' or 'disabled'. When disabled, no image data from this threshold will be written to file or delivered from any other data interface.
			<div>Information #11</div> <p>If threshold/difference/mode is to be used, all threshold/n/mode have to be enabled beforehand.</p>
threshold/n/number_of_excluded_pixels	uint	r	Total number of defective, disabled or inactive pixels for threshold n.

**Table 4.1:** Detector Config Parameters - continued

Parameter	Type	Access	Remarks
threshold/n/pixel_mask	uint[]	rw	<p>A bit mask that labels and classifies pixels which are either defective, inactive or exhibit non-standard behavior</p> <p>Bit 0: gap (pixel with no sensor)</p> <p>Bit 1: dead</p> <p>Bit 2: under responding</p> <p>Bit 3: over responding</p> <p>Bit 4: noisy</p> <p>Bit 5-31: -undefined-</p>
			<div>Information #12</div> <p> Please note that the actual integer value of a pixel in the mask depends on which bits are set, e.g. a dead pixel has the value <math>2^1=2</math> and an over responding pixel <math>2^3=8</math>. A custom pixel_mask can be persistently upload with a put request. Removing it requires a delete request.</p>
threshold/difference/mode	string	rw	<p>Calculation of difference images, which can be 'enabled' or 'disabled'. When disabled, no difference images will be written to file or delivered from any other data interface. Only available for detectors with more than one threshold.</p>
			<div>Information #13</div> <p> If threshold/difference/mode is to be used, all threshold/n/mode have to be enabled beforehand.</p>
threshold/difference/lower_threshold	uint	r	<p>Lower threshold used for calculating difference images. Difference images are calculated by subtracting the counts of the upper threshold image from the counts of the lower threshold image. Only available for detectors with more than one threshold.</p>
threshold/difference/upper_threshold	uint	r	<p>Upper threshold used for calculating difference images. Difference images are calculated by subtracting the counts of the upper threshold image from the counts of the lower threshold image. Only available for detectors with more than one threshold.</p>
trigger_mode	string	rw	<p>Mode of triggering image acquisition. See the User Manual for details.</p>
trigger_start_delay	float	rw	<p>Delayed time from when the trigger comes until the configured series starts. Trigger Start Delay can be used in ints and exts mode.</p>

**Table 4.1:** Detector Config Parameters - continued

Parameter	Type	Access	Remarks
two_theta_increment	float	rw	Two theta increment per frame.
two_theta_start	float	rw	Two theta start angle (start angle of the first frame).
virtual_pixel_correction_applied	float	rw	Enables ( <i>True</i> ) or disables ( <i>False</i> ) applying the <i>virtual_pixel_correction</i> on the acquired data.
wavelength	float	rw	Wavelength of incident X-rays. See the User Manual for details.
x_pixel_size	float	r	Size of a single pixel along x-axis of the detector.
x_pixels_in_detector	uint	r	Number of pixels along x-axis of the detector.
y_pixel_size	float	r	Size of a single pixel along y-axis of the detector.
y_pixels_in_detector	uint	r	Number of pixels along y-axis of the detector.

## JSON Serialization

Meta information in the body of the request and in the reply from the HTTP server are serialized in the JSON format and described in the table below.

The returned JSON of a **get** request string contains a subset of the fields below. Only fields which are applicable for a given resource are present in the returned JSON. For hdf5 objects, the JSON metadata is stored with hdf5 attributes.

**Table 4.2:** Key Value Pairs for Detector Config Parameters (GET)

JSON Key	JSON Value	Description
"value"	<parameter_value>	The value of the configuration parameter. Data type can be int, float, string or a list of int or float. Two-dimensional arrays are returned as darrays (see text below). Invalid or unknown values are represented as "null" or as empty string, list, or array.
"value_type"	<string>	Returns the data type of a parameter. Data types are bool, float, int, string or a list of float or int. Invalid or unknown values are represented as "null" or as empty string, list, or array.
"min"	<minimal_parameter_value>	Returns the minimum of a parameter (for numerical datatypes).
"max"	<maximal_parameter_value>	Returns the maximum of a parameter (for numerical datatypes).
"allowed_values"	<list_of_allowed_values>	Returns the list of allowed values. An empty list indicates there are no restrictions.
"unit"	<string>	The unit of the parameter.
"access_mode"	<string>	String, describing read, and/or write access to resource. When not available, the <i>access_mode</i> is "rw".

**Put** requests send a body serialized in the JSON format. The HTTP header item *content-type* must be set appropriately.

The JSON string may contain the following keywords:

**Table 4.3:** Key Value Pairs for Detector Config Parameters (PUT)

JSON Key	JSON Value	Description
"value"	<parameter_value>	The value of the configuration parameter. Data type can be int, float, string or a list of int or float. Two-dimensional arrays are returned as darrays (see text below).

The return body of a **put** request is:

**Table 4.4:** Return Body of PUT Requests

JSON Key	JSON Value	Description
None	<changed_parameters>	A list of all resources that are also affected by the put configuration parameter.

## darray

Two-dimensional arrays (*pixel\_mask*, *flatfield*) are exchanged as darrays as defined below:

"\_\_darray\_\_": <VERSION>, "type": <type>, "shape": [<width>,<height>], "filters":["base64"],"data": <base 64 encoded data>

where <VERSION> is the darray version ([major, minor, patch]), <type> is either "<u4>" or "<f4>" (little endian encoded 4 byte unsigned int or float) and <base 64 encoded data> contains the base 64 encoded data.

## Example - Setting photon\_energy

As already mentioned, when setting a value, the DCU returns the names of the parameters that were explicitly or implicitly changed to maintain a consistent detector configuration in the reply to the set request.

The following example of setting the photon energy to 8040 eV uses python libraries as a web client to send HTTP requests:

[\$\_ Python Code

```
import json
# Imports "JSON" library
import requests
# Imports "requests" library
dict_data = {'value':8040.0}
# Prepare the dictionary (a "value" with the value 8040.0)
data_json = json.dumps(dict_data)
# Convert the dictionary to JSON
r = requests.put('http://<address_of_dcu>/detector/api/<version>/config/photon_energy', data=data_json)
# Execute the request on the config value "photon_energy" (REPLACE <ADDRESS_of_DCU> and <VERSION> with the values of YOUR system)
print(r.status_code)
# Print the http status code (NOTE: Only http code 200 is OK, everything else is an error)
print(r.json())
# Print the returned JSON string. (Containing the names of the subsequently changed values)
```

The code will return the following output<sup>2</sup>:

<sup>2</sup> List of changed keys clipped for readability

[]>\_ Return Value

```
200
["threshold_energy", "flatfield", "element", ...]
```

The returned HTTP code "200" indicates successful completion of the put request.

The JSON string "["threshold\_energy", "flatfield"]" indicates that, resulting from the photon energy change, the threshold energy and the applied flatfield were also changed.

#### 4.1.2. Detector Status Parameters

Status parameters are read only. The base path to the resource is:

[]\$\_ URLs

```
<uri> = http://<ADDRESS_OF_DCU>/detector/api/<VERSION>/status/<PARAMETER>
```


Status parameters are measured values which might change without user interaction. They represent the operational conditions.

#### Status Information

**Table 4.5:** Detector Status Parameters

Parameter	Type	Access	Remarks
board_000/th0_humidity	float	r	<div>Caution #4</div> <div>⚠ This parameter is deprecated, please use <i>humidity</i>.</div> <div>Relative humidity reported by humidity sensor.</div>
board_000/th0_temp	float	r	<div>Caution #5</div> <div>⚠ This parameter is deprecated, please use <i>temperature</i>.</div> <div>Temperature reported by temperature sensor.</div>
error	string[]	r	Always returns empty list. Only available for backwards compatibility
high_voltage/state	string	r	<div>Information #14</div> <div>📄 For optimal data quality acquisitions should only be started when state is <i>READY</i>.</div>

**Table 4.5:** Detector Status Parameters - continued

Parameter	Type	Access	Remarks
humidity	float	r	Humidity inside the detector module compartment.
state	string	r	<div> <div>Possible states: na (not available), ready, initialize, configure, acquire, idle, test, error.</div> <div> <div>Information</div> <div>#15</div> </div> <div>  State is "na", when the DCU is booted or the acquisition service was restarted. </div> </div>
temperature	float	r	Detector temperature.
time	string	r	Returns current system time. Formatted according to ISO 8601

## JSON Serialization

**Get** requests have no body. The returned JSON of a **get** request string contains a subset of the fields below. Only fields which are applicable for a given resource are present in the returned JSON.

**Table 4.6:** Key Value Pairs for Detector Status Parameters (GET)

JSON Key	JSON Value	Description
"value"	<parameter_value>	The value of the configuration parameter. Data type can be single type or list of int, float or string. Invalid or unknown values are represented as "null" or as empty string, list, or array.
"value_type"	<string>	Returns the data type of a parameter.
"unit"	<string>	The unit of the parameter. The returned data type may only be valid if a valid value for this parameter is known.
"time"	<date>	Timestamp for when the value was updated.
"state"	<state>	invalid, normal, critical, disabled
"critical_limits"	<list_containing_minimal_and_maximal_parameter_value>	Returns the minimum and maximum error threshold for a parameter if it is a numerical value type.
"critical_values"	<list_of_critical_values>	Returns the list of values treated as error conditions. An empty list indicates there are no states causing an error condition.

### 4.1.3. Detector Command Parameters

Command parameters are write only. The base path to the resource is:

[\$\_URLs

<uri> = http://<ADDRESS\_of\_DCU>/detector/api/<VERSION>/command/<PARAMETER>

**Table 4.7:** Detector Command Parameters

Parameter	Return Value	Access	Remarks
abort	sequence_id: uint	w	Aborts all operations and resets the system <b>immediately</b> . All data in the pipeline will be dropped.
arm	sequence_id: uint	w	Loads configuration to the detector and arms the trigger unit.
cancel	sequence_id: uint	w	Stops the data acquisition, <b>but only after the next image is finished</b> .
check_connections	Array	w	<div>Caution #6</div> <p>The detector needs to be re-initialized in order to resume operation!</p> <p>Issuing this command returns the state of the DATA interfaces along with additional readings where available.</p>
disarm	sequence_id: uint	w	Writes all data to file and disarms the trigger unit.
hv_reset	-	w	<div>Information #16</div> <p>Should only be used with CdTe detectors. See the User Manual for details.</p> <p>Resets the module high voltage for number of supplied seconds (range 1 - 600 seconds). Reset time is 30s if no time is supplied.</p>
initialize	-	w	<div>Caution #7</div> <p>Before initializing the detector only the detector state is available!</p> <p>Initializes the detector.</p>
trigger	-	w	<p>Starts data acquisition with the programmed trigger sequence.</p> <p>The trigger command can also accept an argument in the put request – the <i>count_time</i> – if used in <i>trigger_mode</i> into (internal enable).</p>



For parameters without a return value one should check whether a HTTP code 200 is returned. If an error occurs a corresponding HTTP error code is returned instead. In this case please create a bug report on the web interface of the DCU (Technical Support - Create Bug Report) and contact support@dectris.com.

## 4.2. Monitor Subsystem

The monitor interface is used to inspect single frames. This is a low performance and low bandwidth interface, and thus should only be used at low frame rates. For high frame rates (>10 Hz), usage of either the FileWriter or the streaming interface is advised. In order to use the monitor interface, it must first be configured. The base URL for the Monitor API is:

```
[$_ Python Code
```

```
http://<ADDRESS_OF_DCU>/monitor/api/<VERSION>
```

### 4.2.1. Monitor Configuration Parameters

The configuration is applied at the URL:

```
[$_ URL
```

```
<uri> = http://<ADDRESS_OF_DCU>/monitor/api/<VERSION>/config/<PARAMETER>
```

with the following commands:

**Table 4.8:** Monitor Config Parameters

Parameter	Type	Access	Remarks
buffer_size	uint	rw	Number of images that can be buffered by the monitor interface.
discard_new	bool	rw	When enabled ( <i>True</i> ) the monitor keeps old and drops new images if the buffer is running full. When disabled the monitor keeps new images and drops old ones
mode	string	rw	Operation mode of the monitor, which can be <i>enabled</i> or <i>disabled</i> . When enabled, a number of <i>buffer_size</i> images are stored in the monitor buffer. The monitor keeps old and drops new images if the buffer is running full.

### 4.2.2. Data Access

A **get** request to the URL:

```
[$_ URL
```

```
http://<ADDRESS_OF_DCU>/monitor/api/<VERSION>/images/
```

returns a list of all available frames.

[\$\_URLs

```
[[series, [id, id, ...]], ...]
```

During data taking, the frames can be accessed with a **get** operation at the URL:

[\$\_URL

```
http://<ADDRESS_of_DCU>/monitor/api/<VERSION>/images/<series>/<id>/<threshold_id>
```

## Information

#17



Whether multiple threshold IDs are available depends on the amount of thresholds enabled using *thresh-old/n/mode*

The images will be returned in .tif format. If a requested image is not available, the request will return *HTTP 404 Not Found* error. The following parameters allow special frames to be accessed in a similar way.

[\$\_URL

```
<uri> = http://<ADDRESS_OF_DCU>/monitor/api/<VERSION>/images/<PARAMETER>
```

**Table 4.9:** Monitor Images Parameters

Parameter	Type	Access	Remarks
monitor	tif	r	Gets latest image from the buffer. Default waits for 500 ms for image. Timeout via ?timeout=[ms] adjustable. Returns 408 if no image is available.
next	tif	r	Gets the oldest image (next in order) and removes it from the buffer. Default waits for 500 ms for image. Timeout via ?timeout=[ms] adjustable. Returns 408 if no image available.

## Tiff Header Data

The TIFF images include meta data listed in the table below. The information is available by accessing the DECTRIS private TIFF tag at 51192 (hex: C7F8).

Following Image File Directory (IFD) Tags are currently available:

**Table 4.10:** DECTRIS IFD Tags

Code (Hex)	Name	Type	Count	Description
0000	IfdVersion	Long	1	Indicates the Dectris IFD version. Currently 0.
0001	SeriesUniqueld	ASCII	N	The unique identifier of the series. Example: 01DC3XQ8ENM14PYCDHQ9XVZZJ8

**Table 4.10:** DECTRIS IFD Tags - continued

Code (Hex)	Name	Type	Count	Description
0002	SeriesNumber	LONG	1	The series number (id).
0003	ImageNumber	LONG	1	The image number (id) in the series.
0004	ImageDateTime	ASCII	N	The date and time when the original image data was acquired. The format is RFC 3339. Example: 2019-05-14T10:59:56.000000000Z
0005	ThresholdId	SHORT	N	The threshold identifier(s). For difference mode there are two threshold ids (N=2).
0006	ThresholdEnergy	DOUBLE	N	Threshold energy in eV. For difference mode, the two threshold energies used (N=2). Otherwise, the single threshold energy corresponding to the threshold id (N=1).
0007	ExposureTime	DOUBLE	1	The elapsed exposure (counting) time of the image. This field has the same meaning as Nexus NXDetector.count_time.
0009	IncidentEnergy	DOUBLE	1	The configured energy of incident particles (e.g. X-rays) in eV.
0012	LostPixelCount	LONG	1	The number of pixels lost due transmission (network) errors.

### 4.2.3. Monitor Status Parameters

The status of the monitor can be requested at the address:

[\$\_URLs

<uri> = http://<ADDRESS\_of\_DCU>/monitor/api/<VERSION>/status/<PARAMETER>

**Table 4.11:** Monitor Status Parameters

Parameter	Type	Access	Remarks
buffer_fill_level	uint()	r	Returns a tuple with current number of images and maximum number of images in buffer.
dropped	uint	r	Number of images which were dropped as not requested.
error	string[]	r	Returns list of status parameters causing error condition.
state	string	r	State can be <i>normal</i> or <i>overflow</i> if images have been dropped.

#### 4.2.4. Monitor Command Parameters

To clear the buffer of images, the following command can be executed at the address  
[http://<address\\_of\\_dcu>/monitor/api/1.8.0/command/clear](http://<address_of_dcu>/monitor/api/1.8.0/command/clear)

URLs

<uri> = [http://<ADDRESS\\_of\\_DCU>/monitor/api/<VERSION>/command/<PARAMETER>](http://<ADDRESS_of_DCU>/monitor/api/<VERSION>/command/<PARAMETER>)

**Table 4.12:** Monitor Command Parameters

Parameter	Return Value	Access	Remarks
clear	-	w	Drops all buffered images and resets status/-dropped to zero.
initialize	-	w	Resets the monitor to its original state.

### 4.3. FileWriter Subsystem

The data itself, the frames, are by default written to HDF5 files, where the metadata is stored in the NeXus compliant meta-data standard. These files can be accessed through the SIMPLON API.

The FileWriter subsystem writes the frames and the metadata in the NeXus format to an HDF5 file. The base URL for the FileWriter is:

URLs

[http://<ADDRESS\\_OF\\_DCU>/filewriter/api/<VERSION>/](http://<ADDRESS_OF_DCU>/filewriter/api/<VERSION>/)

#### 4.3.1. FileWriter Configuration Parameters

To configure the FileWriter, this URL is used:



URL

<uri> = [http://<ADDRESS\\_OF\\_DCU>/filewriter/api/<VERSION>/config/<PARAMETER>](http://<ADDRESS_OF_DCU>/filewriter/api/<VERSION>/config/<PARAMETER>)

**Table 4.13:** Filewriter Config Parameters

Parameter	Type	Access	Remarks
compression_enabled	bool	rw	Enables ( <i>True</i> ) or disables ( <i>False</i> ) compression of detector data written to HDF5 files. Compression is required for full detector performance, disabling compression may lead to data loss at high frame rates. For compression modes see section 4.1.1 Detector Configuration Parameters (compression).

**Table 4.13:** Filewriter Config Parameters - continued

Parameter	Type	Access	Remarks
image_nr_start	uint	rw	Sets the <i>image_nr_low</i> metadata parameter in the first HDF5 data file <i>&lt;name_pattern&gt;_data_000001.h5</i> . This parameter is useful when a data set is collected in more than one HDF5 file structures. If you collect image number <i>m</i> to <i>n</i> in the first file structure, you can set <i>image_nr_start</i> to <i>n+1</i> in the subsequent file structure.
mode	string	rw	Operation mode of the FileWriter, which can be <i>enabled</i> or <i>disabled</i> . During an active acquisition the interface remains enabled and will be disabled after receiving the end of series message.
name_pattern	string	rw	<p>The basename of the file. The pattern <i>\$id</i> will include the sequence number in the file name. <i>series_\$id</i> is the default name pattern, resulting in the following names of the HDF5 file structure created by the FileWriter:</p> <p><i>series_&lt;sequence_nr&gt;_master.h5</i>,  <i>series_&lt;sequence_nr&gt;_data_&lt;filenr&gt;.h5</i></p> <div> <div>Caution</div> <div>#8</div> </div> <p> The FileWriter will overwrite existing files with identical names of the files to be written.</p>
nimages_per_file	uint	rw	<p>Maximum number of images stored in each <i>&lt;name_pattern&gt;_data_&lt;file_nr&gt;.h5</i> file in the HDF5 file structure created by the FileWriter.</p> <p>Data files are only created when <i>&lt;nimages_per_file&gt;</i> is reached or when detector command <i>disarm</i> is sent.</p> <p>No data files are created and all images are stored in <i>&lt;name_pattern&gt;_master.h5</i> when this parameter is set to 0.</p> <div> <div>Caution</div> <div>#9</div> </div> <p> Only set to 0 when collecting a small number of images.</p>

### 4.3.2. Data Access

The files are created locally on the detector server and have to be transferred to the user computer. The master file is accessible at the URL:

```
[$_URL
```

```
http://<ADDRESS_OF_DCU>/data/<name_pattern>_master.h5
```

and the data files at:

```
[$_URL
```

```
http://<ADDRESS_OF_DCU>/data/<name_pattern>_data_<filenr>.h5
```

A **get** request to the URL:

```
[$_URL
```

```
http://<ADDRESS_OF_DCU>/filewriter/api/<VERSION>/files/
```

returns a list of all available files.

### 4.3.3. FileWriter Status Parameters

The FileWriter is automatically started when data taking is started. The status of the FileWriter can be accessed at:

```
[$_URL
```

```
<uri> = http://<ADDRESS_OF_DCU>/filewriter/api/<VERSION>/status/<PARAMETER>
```

The following FileWriter status variables are accessible:

**Table 4.14:** FileWriter Status Parameters

Parameter	Type	Access	Remarks
buffer_free	uint	r	The remaining buffer space in Bytes.
error	string[]	r	Returns list of status parameters causing error condition.
files	string[]	r	Returns list of available files on the DCU.
state	string	r	Possible states: <i>disabled</i> , <i>ready</i> , <i>acquire</i> , <i>error</i> .

#### 4.3.4. FileWriter Command Parameters

Command parameters are write only. The base path to the resource is:

```
[$_URL
```

```
<uri> = http://<ADDRESS_OF_DCU>/filewriter/api/<VERSION>/command/<PARAMETER>
```

**Table 4.15:** FileWriter Command Parameters

Parameter	Return Value	Access	Remarks
clear	-	w	Drops all data (image data and directories) on the DCU.
initialize	-	w	Resets the FileWriter to its original state.

### 4.4. Stream Subsystem

The SIMPLON API lets you configure and read out the status of the stream.

The base URL for the stream is:

```
[$_URL
```

```
http://<ADDRESS_OF_DCU>/stream/api/<VERSION>
```

#### 4.4.1. Stream Configuration Parameters

To configure the stream, this URL is used:

```
[$_URL
```

```
<uri> = http://<ADDRESS_OF_DCU>/stream/api/<VERSION>/config/<PARAMETER>
```

**Table 4.16:** Stream Config Parameters

Parameter	Type	Access	Remarks
header_appendix	string	rw	Data that is appended to the header data as <i>zero-mq</i> submessage.

**Table 4.16:** Stream Config Parameters - continued

Parameter	Type	Access	Remarks
header_detail	string	rw	Detail of header data to be sent: Either <i>"all"</i> (all header data), <i>"basic"</i> (no flatfield nor pixel mask, default setting) or <i>"none"</i> (no header data).
			<div>Information #18</div> <div>Choosing <i>"basic"</i> is recommended only if the detector configuration parameter <code>pixel_mask_applied</code> is set to <code>True</code>.</div>
			<div>Caution #10</div> <div>If header_detail <i>"none"</i> is selected, no experimental meta-data is transferred, complicating processing and archiving of the data. Therefore, usage of header_detail <i>"none"</i> is discouraged.</div>
image_appendix	string	rw	Data that is appended to the image data as <i>zeromq</i> submessage.
mode	string	rw	Operation mode of the stream, which can be <i>enabled</i> or <i>disabled</i> . During an active acquisition the interface remains enabled and will be disabled after receiving the end of series message.

#### 4.4.2. Data Access

Image and header data are transferred via *zeromq* sockets. The port is 9999, the scheme is Push/Pull, i.e. the server opens a *zeromq push socket*, whereas the client needs to open a *zeromq pull socket*.

Zeromq
9999
Push/Pull
Receiver connects to detector (this enables automatic load balancing if more than 1 client is required to receive/process the data)

There are 3 types of messages, which are defined below in more detail: **Global Header Data**, **Image Data** and **End of Series**. After passing the *"arm"* command to the detector one message containing *Global Header Data* is sent over the *zeromq socket*. After passing *"trigger"* one messages per image containing *Image Data* is sent. After passing *"disarm"*, *"cancel"* or *"abort"*, one message containing *End of Series* is sent.



## Global Header Data

Zeromq multipart message consisting of the following parts:

- **Part 1:** Json Dictionary, reading {"htype": "dheader-1.0", "series": <id>, "header\_detail": "all" | "basic" | "none"}. <id> denotes the series id of the present image series.
- **Part 2:** (only if *header\_detail* is "all" or "basic"): Detector configuration as json dictionary, reading {<config parameter>: <value>}. The keys are the configuration parameters as defined in the detector API. The values are the current configuration values. There are maximum 1 dim arrays, which are stored as json array. *Flatfield* and *Pixelmask* and *countrate\_correction\_table* are not part of the dictionary.
- **Part 3:** (only if *header\_detail* is "all"): Flatfield Header. Json Dictionary reading {"htype": "dflatfield-1.0", "shape": [x,y], "type": <data type>}. <data type> is always "float32" (32 bit float) for a flatfield.
- **Part 4:** (only if *header\_detail* is "all"): Flatfield data blob.
- **Part 5:** (only if *header\_detail* is "all"): Pixel Mask Header. Json Dictionary reading {"htype": "dpixelmask-1.0", "shape": [x,y], "type": <data type>}. <data type> is always "uint32" (32 bit unsigned integer) for a pixel mask.
- **Part 6:** (only if *header\_detail* is "all"): Pixel Mask data blob.
- **Part 7:** (only if *header\_detail* is "all"): Countrate Table Header. Json Dictionary reading {"htype": "dcountrate\_table-1.0", "shape": [x,y], "type": <data type>}. <data type> is always "float32" (32 bit float).
- **Part 8:** (only if *header\_detail* is "all"): Countrate Table data blob.
- **Appendix** (only if *header\_detail* is "all"): Content of API parameter *header\_appendix* if not empty.

Example:

```
{"htype": "dheader-1.0", "series": 1, "header_detail": "all"}
{"auto_summation": true, "photon_energy": 8000, ...}
```

```
{"htype": "dflatfield-1.0", "shape": [1030,1065], "type": "float32"}
DATA BLOB (Flatfield)
```

```
{"htype": "dpixelmask-1.0", "shape": [1030,1065], "type": "uint32"}
DATA BLOB (Pixel Mask)
```

```
{"htype": "dcountrate_table-1.0", "shape": [2,1000], "type": "float32"}
DATA BLOB (countratecorrection table)
```

## Image Data

Zeromq multipart message consisting of the following parts:

- **Part 1:** Json Dictionary, reading {"htype": "dimage-1.0", "series": <series id>, "frame": <frame id>, "hash": <md5>}, <series id> is the number identifying the series, <frame id> is the frame id, i.e. the image number. <md5> is the md5 hash of the next message part.
- **Part 2:** {"htype": "dimage\_d-1.0", "shape": [x,y,z], "type": <data type>, "encoding": <encoding>, "size": <size of data blob>}.
  - <data type>: "uint8", "uint16" or "uint32".
  - <encoding>: String of the form "[bs<BIT>][[-]lz4][<|>]". bs<BIT> stands for bit shuffling with <BIT> bits, lz4 for lz4 compression and <|> for little (big) endian. E.g. "bs8-lz4<" stands for 8bit bitshuffling, lz4 compression and little endian. lz4 data is written as defined at <https://code.google.com/p/lz4/> without any additional data like block size etc.
  - <size of data blob>: Size in bytes of the following data blob
- **Part 3:** Data Blob

- **Part 4:** {"htype": "dconfig-1.0", "start\_time": <start\_time>, "stop\_time": <stop\_time>, "real\_time": <real\_time>}. Begin, end and duration of the exposure of the current image in nano seconds. The start time of first image of the series is by definition zero. The value of start\_time and stop\_time is set to zero when initializing the detector system.

#### Information

#19



- The time values are based on the clock quartz on the detector control board.
- Time values are returned in ns.

- **Appendix** (only if *image\_appendix* contains non-empty string): Content of API parameter *image\_appendix*

Example:

```
{"htype": "dimage-1.0", "series": 32, "frame": 324, "hash": "fc67f000d08fe6b380ea9434b8362d22"}
{"htype": "dimage_d-1.0", "shape": [1030, 1065], "type": "uint32", "encoding": "lz4", "size": 47398247}
```

DATA BLOB (Image Data)

```
{"htype": "dconfig-1.0", "start_time": 834759834260, "stop_time": 834760834280, "real_time": 1000000}
```

### End of Series

Zeromq message consisting of one part containing the json string:

```
{"htype": "dseries_end-1.0", "series": <id>}
```

### 4.4.3. Stream Status Parameters

The status of the stream can be accessed at:

[\$\_URL

<uri> = http://<ADDRESS\_OF\_DCU>/stream/api/<VERSION>/status/<PARAMETER>

The following stream status variables are accessible:

**Table 4.18:** Stream Status Parameters

Parameter	Type	Access	Remarks
dropped	uint	r	Number of images that got dropped as not requested. After "arm" this number is reset to zero.
state	string	r	<i>disabled</i> , <i>ready</i> , <i>acquire</i> or <i>error</i> . After the detector has been armed the state becomes acquire, after disarm, abort or cancel the state becomes ready. There are currently no error conditions.

#### 4.4.4. Stream Command Parameters

Command parameters are write only. The base path to the resource is:

**Table 4.19:** Stream Command Parameters

Parameter	Return Value	Access	Remarks
initialize	-	w	Resets the stream to its original state (i.e reset dropped images and errors, mode is set to disabled).
			<div>Caution #11</div> <div>⚠ If issued during acquisition the stream interface will stop sending data.</div>

## 4.5. System Subsystem

The SIMPLON API lets you control the DAQ service providing the SIMPLON API.

### 4.5.1. System Configuration Parameters

The status of the system can be accessed at:


```
[$_URL
```

```
<uri> = http://<ADDRESS_OF_DCU>/system/api/<VERSION>/config/<PARAMETER>
```

**Table 4.20:** System Config Parameters

Parameter	Type	Access	Remarks
datetime/date	string	rw	Returns or sets the current date.
datetime/ntp	string	rw	Enables (on) or disables (off) Network Time Protocol (NTP).
datetime/ntp_server	string	rw	Returns or sets the comma separate list of Network Time Protocol (NTP) servers.
datetime/time	string	rw	Gets or sets the current time (HH:MM:SS).
datetime/timezone	string	rw	Gets or sets the current timezone. Also returns list of available timezones on a GET request.
network/n/addr	string	rw	Returns or sets the network address (IP) of the detector control unit network interface "n".
			<div>Information #20</div> <div>Please note that the fall-back interface configurations are read-only.</div>
			<div>Information #21</div> <div>Please note that "n" needs to be replaced with the network interface name (e.g. user1p1). Available interfaces can be requested with a GET request to URI/network/keys</div>
network/n/dhcp	string	rw	Enables (on) or disables (off) DHCP for detector control unit network interface "n".
network/n/dns1	string	rw	Returns or sets the primary domain name server (DNS) for detector control unit network interface "n".
network/n/dns2	string	rw	Returns or sets the secondary domain name server (DNS) for detector control unit network interface "n".

**Table 4.20:** System Config Parameters - continued

Parameter	Type	Access	Remarks
network/n/mtu	string	rw	Returns or sets the maximum transmission unit (MTU) for detector control unit network interface "n".
network/n/netmask	string	rw	Return or sets the netmask for detector control unit network interface "n".
network/n/static_routes	string	rw	Return or sets the static routes for detector control unit network interface "n".
<div>Information #22</div> <div>  Example:  "value":["gateway":"192.168.50.2",  "destination":"10.20.1.1/32",  "gateway":"192.168.50.3",  "destination":"10.30.0.0/16"] </div>			
system_info/service_tag	string	r	Returns the DELL service tag of the detector control unit.

#### 4.5.2. System Command Parameters

Command parameters are write only. The base path to the resource is:

[\$\_URL

<uri> = http://<ADDRESS\_OF\_DCU>/system/api/<VERSION>/command/<PARAMETER>

**Table 4.21:** System Command Parameters

Parameter	Return Value	Access	Remarks
create_log_tarball	URI of the log tarball	w	Creates a tarball of all logfiles relevant for support.
delete_logs	-	w	Deletes all customer logs on the detector control unit.
reboot	-	w	Reboots the detector control unit.
restart	-	w	Restarts the service providing the SIMPLON API.
shutdown	-	w	Shuts down (halts) the detector control unit.