← Back to dashboard

All AI recommendations

AI-generated recommendations across every registered site. Understand the rationale, ask BOB, then open the site or configure an action. Nothing executes until its approval policy is satisfied.

Recommendations requiring attention

3 highest-priority recommendations shown first

Sorted by priority

Kuppam Solar Site

Solar · KUP-SOLAR-001 · Generated 14:32 IST

AI-generated | High priority | Awaiting approval

Import 8 MW for 15 minutes to protect supply continuity

Why BOB recommends this

Solar generation is below forecast. Battery 1 is already discharging within its automatic limit, so additional grid support requires approval.

SUGGESTED ACTION	OPERATIONAL IMPACT	CONFIDENCE	FRESHNESS
Grid import · 8 MW	Continuity protected	94% · High	2 minutes ago

Ask BOB View evidence

Open site | Review approval

Chittoor Hybrid Site

Solar + battery · KUP-HYBRID-004 · Generated 14:21 IST

AI-generated | Critical priority | Awaiting approval

Isolate inverter bank 3 before thermal limits are breached

Why BOB recommends this

Temperature is approaching the protected threshold. Isolation reduces immediate output but lowers the risk of equipment damage.

SUGGESTED ACTION	OPERATIONAL IMPACT	CONFIDENCE	FRESHNESS
Equipment isolation	14 MW at risk	89% · Medium	1 minute ago

Ask BOB View evidence

Open site | Review approval

Tirupati Wind Site

Wind · TIR-WIND-003 · Generated 14:29 IST

AI-generated | Medium priority | Ready to review

Schedule a 12 MWh export during the 15:00 peak window

Why BOB recommends this

Forecast output is above demand and current market pricing creates a time-sensitive revenue opportunity.

SUGGESTED ACTION	OPERATIONAL IMPACT	CONFIDENCE	FRESHNESS
Grid export · 12 MWh	+₹3.84 lakh	91% · High	4 minutes ago

Ask BOB View evidence

Open site | Set up action

Other recommendations

View all 25

Nellore Solar Site Executing

Maintain battery charge at 8 MW while excess solar remains stable

Automatic action · 11 minutes remaining

Ask BOB · Open site · Set up action →

Anantapur Battery Site Ready to review

Reserve 20 MWh for the evening demand ramp

Reserve policy recommendation · no setting changed

Ask BOB · Open site · Set up action →

Madanapalle Hybrid Site Dismissed

Restore the telemetry gateway after breaker inspection

Audit record retained · no action started

Ask BOB · Open site · Set up action →

Showing 1–6 of 28 recommendations

1 2 3 Next