1 Select action — 2 Configure — 3 Test — 4 Activate

3 of 7 configuration decisions completed · Snapshot 01 Oct 2026 14:32 IST

BOB Agent Setup | Kuppam Solar Site KUP-SOLAR-001 | Setup in progress | 3 systems connected | All changes saved | Save and exit

1 Select action — 2 Configure — 3 Test — 4 Activate

3 of 7 configuration decisions completed · Snapshot 01 Oct 2026 14:32 IST

Action selected: Discharge battery to support demand

Objective configured Edit

Maintain supply reliability · Snapshot 01 Oct 2026 14:32 IST

Controlled asset configured Edit

Battery 1 — Available · 72% SOC · 8 MW max · Snapshot 01 Oct 2026 14:32 IST

When should I discharge Battery 1? · Snapshot 01 Oct 2026 14:32 IST

> Four of five trigger conditions are currently met. The action would become eligible if the demand gap continues for one more minute.

Start when site demand exceeds solar generation by more than **3 MW** for at least **5 minutes** and all safety conditions are met.

Adjust the highlighted values to change the trigger threshold and duration. Safety conditions remain visible below.

Required conditions · Snapshot 01 Oct 2026 14:32 IST

- Battery 1 SOC is above 60%
- Shortfall is forecast to continue for at least 15 minutes
- Battery 1 has no critical warning
- Live battery data is available
- Maintenance is not active

Current site values · Snapshot 01 Oct 2026 14:32 IST

Site demand	44 MW
Solar generation	38 MW
Current demand gap	6 MW
Gap duration	4 minutes
Battery charge	72%
Forecast duration	20 minutes
Battery availability	Available

Use recommended trigger | Adjust conditions | Add condition | Explain trigger

Ask BOB to adjust limits or explain any setup option...

Configured actions 1 action | Add action

Support demand using Battery 1 Configuring

3 of 7 settings complete · Snapshot 01 Oct 2026 14:32 IST

CONFIGURED

- Objective: Maintain supply reliability
- Battery: Battery 1
- Trigger: Demand gap above 3 MW for 5 minutes

MISSING

- Limits
- Automation
- Recovery
- Notifications