Action selected: Discharge battery to support demand

Objective configured Edit

Maintain supply reliability

Controlled asset configured Edit

Battery 1 — Available · 72% · 8 MW max

Trigger configured Edit

Demand exceeds solar by 3 MW for 5 min · Battery above 60% · Shortfall forecast 15+ min

How much control can I have over Battery 1?

Configured policy

Automatic discharge max	**6** MW	Configured reserve	**55** %
Maximum energy per action	**3** MWh	Maximum duration	**30** min
Cooldown between actions	**15** min		

Manufacturer recommendation

Manufacturer recommendation	**50% reserve**
Equipment maximum	**8 MW**

Protected limits

- [x] **Immutable organizational floor: reserve must remain above 30%**
- [x] **Immutable organizational ceiling: discharge above 6 MW requires approval**
- [x] Stop when battery charge reaches configured reserve
- [x] Stop if battery temperature exceeds 45°C
- [x] Stop if battery-health warning detected
- [x] Stop if live battery data becomes unavailable
- [x] Stop when site demand returns to normal

> Configured policy: 6 MW automatic discharge max and 55% reserve. Manufacturer recommends 50% reserve. Immutable organizational boundary: discharge above 6 MW requires approval and reserve must stay above 30%. Equipment maximum is 8 MW.

- [x] Do not start while maintenance is active

> I recommend a maximum discharge rate of 6 MW and a 55% reserve to preserve emergency capacity.

Use safe defaults | Customize limits | Enable safety limits

Ask BOB to configure, explain, or change an action

Configured actions

1 action | Add action

Support demand using Battery 1

Configuring

4 of 7 settings complete

CONFIGURED

- Objective: Maintain supply reliability
- Battery: Battery 1
- Trigger: Demand exceeds solar by 3 MW for 5 min · Battery above 60% · Shortfall forecast 15+ min
- Limits: Being configured

MISSING

Automation

Recovery

Notifications