Action selected: Discharge battery to support demand

Objective configured Edit

Maintain supply reliability

Controlled asset configured Edit

Battery 1 — Available · 72% · 8 MW max

Trigger configured Edit

Demand gap 3 MW for 5 min

Safety limits configured Edit

Max 6 MW · 30 min · 55% reserve

Automation configured Edit

Automatic within limits

Recovery behavior configured Edit

Recovery behavior was configured in a prior decision: automatic discharge up to 6 MW, approval required above 6 MW, configured reserve 55%, immutable floor 30%.

Which updates should I send?

Notification events

- [x] Approval required
- [x] Action started
- [x] Safety limit approaching
- [x] Action paused
- [x] Action stopped
- [x] Action completed
- [x] Action failed
- [x] Data connection lost
- [ ] Routine sensor updates
- [ ] Every condition check
- [ ] Every forecast update

Recipients

- [x] **Site operator** — Approval requests, Warnings, Failures
- [x] **Utility control manager** — Escalations, Critical failures
- [x] **Maintenance team** — Battery-health warnings

Channels

- [x] In-app notification
- [x] Email
- [ ] Microsoft Teams
- [ ] SMS

Notification preview

Battery discharge started

BOB started discharging Battery 1 at 6 MW because site demand exceeded solar generation by 6 MW.

Battery charge: 72% · Min reserve: 55% · Expected: 2:49 PM · Demand: Fully covered

View action

Confirm notifications | Customize recipients

Configured actions

3 actions | Add action

Support demand using Battery 1 — Configuring

6 of 7 settings complete

CONFIGURED

- Objective: Maintain supply reliability
- Battery: Battery 1
- Trigger: Demand gap 3 MW for 5 min
- Limits: Max 6 MW · 30 min · 55% reserve
- Automation: Automatic within limits
- Recovery: Request approval to import up to 4 MW

MISSING

Notifications

Charge Battery 2 during low demand — Configuring

6 of 7 settings complete

CONFIGURED

- Objective: Optimize battery charge
- Battery: Battery 2
- Trigger: Demand below 40% of peak for 15 min
- Limits: Max 4 MW · 60 min · 40% reserve
- Automation: Automatic within limits
- Recovery: Resume charge when demand drops below 40% of peak

MISSING

Notifications

Reduce load during peak demand — Configuring

6 of 7 settings complete

CONFIGURED

- Objective: Reduce peak load
- Load: HVAC and non-essential pumps
- Trigger: Peak demand above 85% of site capacity for 10 min
- Limits: Max 2 MW · 45 min · 30% reserve
- Automation: Automatic within limits
- Recovery: Resume load when peak demand drops below 80% of capacity

MISSING

Notifications

Control systems

- [x] **Battery control system** — Battery 1 and Battery 2
- [x] **Load management system** — HVAC and non-essential pumps
- [x] **Grid connection system** — Import/export monitoring and approval checks

Monitoring feeds

- [x] **Site demand** — Real-time demand and 5-minute gap detection
- [x] **Solar generation** — Real-time generation and 15-minute forecast
- [x] **Battery 1 state** — Charge, discharge rate, temperature, and reserve status
- [x] **Battery 2 state** — Charge, discharge rate, temperature, and reserve status
- [x] **HVAC load** — Real-time load and 15-minute demand forecast
- [x] **Grid import/export** — Real-time flow and approval status