Kuppam Solar Site

Online · Andhra Pradesh, India

45 MW capacity · Commissioned 2021 · Solar PV

BOB is active | Configure BOB | •••

Currently Executing

1 Active

Battery Discharge 6 MW

Kuppam Solar Site · Battery 1

Executing

Started at 14:32 IST (18m ago)

4.2 / 6 MW discharged (70%)

- ✓ Initiated — Automated threshold trigger
- ✓ Approval verified — Inside autonomous limit policy
- ✓ Discharge started — Commands sent to battery arrays
- ● **Monitoring output — Fetching SCADA meters every 15s**
- ○ Completion & report generation

CURRENT OUTPUT	BATTERY SOC	GRID DEMAND	EST. COMPLETION
6 MW	72%	High	14:55 IST

Pause Task | View Live Chart

Pending Approval

1 Required

Import 8 MW from Grid · Kuppam Solar Site · Grid Tie

High Urgency

Reason: Demand exceeds solar output by 6 MW. BOB recommends importing 8 MW to maintain supply while keeping battery discharge within the 6 MW autonomous limit.

Cost Est: ₹12,000 Time remaining: 8 mins

Reject | Modify | Approve Action

Waiting Actions

3 Watching

Auto-Sell Surplus Energy

Kuppam Solar Site · Grid Tie

Watching

- ✗ Surplus generation > 5 MW **0 MW**
- ✓ Market price > ₹8.00/kWh **₹8.40/kWh**
- ✓ Grid stability > 95% **97.2%**

1 of 3 conditions not met — Waiting for surplus to reach threshold

Last triggered: 45 min ago — Sold 12 MW at ₹8.40/kWh

Preventive Maintenance Alerts

Kuppam Solar Site · Inverter 01

Watching

- ✗ Inverter efficiency < 92% **94.8%**
- ✗ Vibration anomaly detected **Normal**

All equipment operating within normal parameters

Last triggered: 2 hours ago — Created WO-4521 for panel cleaning

Grid Import on Shortfall

Kuppam Solar Site · Grid Tie

Watching

- ✗ Generation < demand by > 3 MW for > 10 min **deficit 1.8 MW for 4 min**

Monitoring — deficit trending up but below threshold

Last triggered: 12 min ago — Import 8 MW recommended (pending approval)