Configure BOB

Add new action +

Manage BOB's automated actions, triggers, safety limits, and permissions for Kuppam Solar Site

Configured actions **3** · Active **3** · Paused **0** · Last modified **45 MW**

All (3) | Active (3) | Paused (0) | Needs attention (0)

Search actions... | Sort by: Last modified

Auto-Sell Surplus Energy

Active

Automatically sell surplus generation to grid when prices are optimal and safety limits are met.

8 today

TRIGGER CONDITIONS

- When surplus generation > 5 MW and site capacity < 45 MW
- AND market price > ₹8.00/kWh and grid stability index > 95%
- AND grid stability index > 95%

EXECUTION RULES

Auto-approve up to: **6 MW**

Above 6 MW: **Requires admin approval**

Maximum daily trades: **5**

Cooldown between trades: **15 min**

RECENT ACTIVITY

3:38 PM — Sold 6 MW at ₹8.40/kWh — Revenue ₹50,400 — Completed

11:20 AM — Sold 5 MW at ₹8.10/kWh — Revenue ₹40,500 — Completed

9:05 AM — Skipped: Market price ₹7.50 below threshold — Skipped

PERFORMANCE SUMMARY

Today: **2 trades** · **₹91,000 revenue** · **11 MW sold** · **100% success rate**

Edit Action | Pause | View Full History

Battery Charge Management

Active

Optimize battery discharge to support peak demand while respecting configured reserve, manufacturer recommendation, and organizational floor.

3 today

TRIGGER CONDITIONS

- When battery SOC drops below 55% configured reserve
- OR battery SOC exceeds 90% and peak demand is detected
- OR grid frequency deviation > 0.5 Hz and discharge is safe
- OR site shortfall exceeds 3 MW and grid import is available

EXECUTION RULES

Charge target: **85% SOC**

Discharge floor: **55% configured reserve**

Max charge rate: **10 MW**

Max discharge rate: **6 MW**

Routine operations: **Auto-approved up to 6 MW**

Emergency discharge: **Requires approval above 6 MW**

RECENT ACTIVITY

3:42 PM — Discharging 6 MW (peak demand) — 70% progress — Running

9:00 AM — Charged from 55% reserve to 85% SOC — Completed

Yesterday 6:30 PM — Discharged 4 MW (evening peak) — Completed

PERFORMANCE SUMMARY

Today: **3 operations** · Battery health **98%** · Avg cycle efficiency **94%**

Edit Action | Pause | View Full History

Grid Import on Shortfall

Active

Auto-import when generation + demand by > 3 MW

1 today

Preventive Maintenance Alerts

Active

Work orders when inverter efficiency < 92%

1 today

Notifications & Alerts

Active

Teams + Email for critical events and approvals

12 today