

Summary — limits drawn as references, not enforced (* outside the limit)

Lots/phase	Device	VUF [%]	Vmin [pu]	Neutral [A]	NEV [pu]	Loss [kW]	Capacity use
3/3/3	None	0.000	0.9485	0.0	0.0000	3.536	—
3/3/3	Q only	0.000	0.9490	0.0	0.0000	3.481	0.058
3/3/3	Q (cap)	0.000	0.9532	0.0	0.0000	3.224	0.505
3/3/3	P only	0.000	0.9485	0.0	0.0000	3.536	0.000
3/3/3	P + Q	0.000	0.9488	0.0	0.0000	3.503	0.034
4/3/2	None	0.794	0.9199	33.7	0.0172	3.835	—
4/3/2	Q only	0.020	0.8973 *	69.8	0.0352	4.467	0.636
4/3/2	Q (cap)	0.121	0.9041	65.3	0.0330	4.062	1.000
4/3/2	P only	0.005	0.9359	17.8	0.0090	3.598	0.511
4/3/2	P + Q	0.007	0.9340	23.0	0.0116	3.605	0.332
5/3/1	None	1.597	0.8898 *	67.8	0.0346	4.746	—
5/3/1	Q only	0.274	0.8507 *	128.0	0.0647	6.775	1.000
5/3/1	Q (cap)	0.916	0.8724 *	100.6	0.0510	5.308	1.000
5/3/1	P only	0.033	0.9242	34.9	0.0176	3.771	0.999
5/3/1	P + Q	0.014	0.9155	50.7	0.0256	3.992	0.636
6/2/1	None	2.183 *	0.8567 *	96.0	0.0489	5.922	—
6/2/1	Q only	0.790	0.8328 *	152.6	0.0772	7.953	1.000
6/2/1	Q (cap)	1.458	0.8523 *	121.0	0.0614	6.289	1.000
6/2/1	P only	0.611	0.9218	48.1	0.0244	4.031	1.000
6/2/1	P + Q	0.022	0.8926 *	76.8	0.0388	4.630	0.851
7/1/1	None	2.940 *	0.8210 *	131.3	0.0669	7.973	—
7/1/1	Q only	1.414	0.8053 *	189.0	0.0957	10.470	1.000
7/1/1	Q (cap)	2.128 *	0.8189 *	157.4	0.0799	8.553	1.000
7/1/1	P only	1.209	0.8876 *	80.0	0.0406	4.960	1.000
7/1/1	P + Q	0.137	0.8637 *	112.2	0.0566	5.990	1.000