

Summary — VUF objective (scenario A: no controllable device)

Split [kW]	Scn	VUF [%]	Vmin [pu]	Vmax [pu]	NEV [pu]	ΣP [kW]
6.0/6.0/6.0	A	0.000	0.9839	0.9999	0.0000	—
6.0/6.0/6.0	B	0.000	0.9839	0.9999	0.0000	+0.000
6.0/6.0/6.0	C	0.000	0.9839	0.9999	0.0000	-0.000
8.0/5.5/4.5	A	0.303	0.9702	0.9999	0.0084	—
8.0/5.5/4.5	B	0.019	0.9624	0.9999	0.0158	+0.000
8.0/5.5/4.5	C	0.000	0.9738	0.9999	0.0078	+0.000
10.0/5.0/3.0	A	0.608	0.9561	1.0044	0.0169	—
10.0/5.0/3.0	B	0.322	0.9488	1.0033	0.0239	+0.000
10.0/5.0/3.0	C	0.087	0.9619	1.0001	0.0163	+0.000
12.0/4.0/2.0	A	0.898	0.9416	1.0114	0.0252	—
12.0/4.0/2.0	B	0.600	0.9362	1.0089	0.0315	+0.000
12.0/4.0/2.0	C	0.373	0.9478	1.0077	0.0244	-0.000
14.0/3.0/1.0	A	1.195	0.9266	1.0186	0.0338	—
14.0/3.0/1.0	B	0.886	0.9216	1.0164	0.0400	+0.000
14.0/3.0/1.0	C	0.667	0.9331	1.0150	0.0329	-0.000
16.0/1.5/0.5	A	1.492	0.9110	1.0230	0.0426	—
16.0/1.5/0.5	B	1.171	0.9062	1.0268	0.0491	+0.000
16.0/1.5/0.5	C	0.960	0.9180	1.0196	0.0414	-0.000