



P2000

Security Management System

Metasys® Integration

PRELIMINARY

P2000

Security Management System

Metasys Integration

Version 3.11 and higher, September, 2011

24-10618-66 Revision –

**Johnson
Controls**



Security Solutions
(805) 522-5555
www.johnsoncontrols.com

Copyright 2011
Johnson Controls, Inc.
All Rights Reserved

No part of this document may be reproduced without the prior permission of Johnson Controls, Inc.

Acknowledgment

Cardkey P2000, BadgeMaster, and Metasys are trademarks of Johnson Controls, Inc.

All other company and product names are trademarks or registered trademarks of their respective owners.

If this document is translated from the original English version by Johnson Controls, Inc., all reasonable endeavors will be used to ensure the accuracy of translation. Johnson Controls, Inc. shall not be liable for any translation errors contained herein or for incidental or consequential damages in connection with the furnishing or use of this translated material.

Due to continuous development of our products, the information in this document is subject to change without notice. Johnson Controls, Inc. shall not be liable for errors contained herein or for incidental or consequential damages in connection with furnishing or use of this material. Contents of this publication may be preliminary and/or may be changed at any time without any obligation to notify anyone of such revision or change, and shall not be regarded as a warranty.



Declaration of Conformity

This product complies with the requirements of the European Council Electromagnetic Compatibility Directive 2004/108/EEC and the Low Voltage Directive 2006/95/EEC.

This equipment must not be modified for any reason and it must be installed as stated in the Manufacturer's instruction.

If this shipment (or any part thereof) is supplied as second-hand equipment, equipment for sale outside the European Economic Area or as spare parts for either a single unit or system, it is not covered by the Directives.

TABLE OF CONTENTS

Chapter 1: Introduction

Overview	1-1
Theory of Operation	1-2

Chapter 2: Object Reference

Host Device Object	2-1
Attributes	2-1
Attribute Definitions	2-3
Counter Object	2-6
Attributes	2-6
Attribute Definitions	2-6
Panel Object	2-7
Status Relationships	2-7
Attributes	2-7
Attribute Definitions	2-8
Terminal Object	2-9
Status Relationships	2-10
Attributes	2-10
Attribute Definitions	2-11
Reader Object	2-12
Status Relationships	2-12
Attributes	2-13
Attribute Definitions	2-15
Input Point Object	2-16
Status Relationships	2-17
Attributes	2-17
Attribute Definitions	2-18
Output Point Object	2-20
Status Relationships	2-21
Attributes	2-21
Attribute Definitions	2-22
Notification Class Object	2-24
Event Categories	2-24
Attributes	2-24
Attribute Definitions	2-25

Chapter 3: P2000 Setup

Setting Up BACnet Site Options	3-1
BACnet Site Field Definitions	3-2
Enabling the P2000 BACnet Service to Auto-Start	3-3
Setting Up External IPs	3-4

Configuring Hardware Components for BACnet Interface	3-5
BACnet Panel Devices	3-7
Setting Up BACnet Action Interlocks	3-8
Action Interlock Operation	3-9

Chapter 4: M3/M5 Setup

General Guidelines for Configuring P2000 and Metasys Workstations over Routers	4-2
Configuration Considerations	4-3
M5 Workstation	4-3
Router	4-4
P2000 Server	4-5
Verification of Metasys-P2000 Integration Using the Metasys Site Book Application	4-5
Launching the Site Book Application and Adding a Site	4-6
Browsing the Site	4-7
Adding P2000 Objects	4-8
Adding a Host Object	4-8
Displaying the P2000 Objects in the Site Book Database	4-9
Verification of Metasys-P2000 Integration Using the Metasys M-Explorer Application	4-10
Confirming the Entry of a Site	4-11
Confirmation of P2000 Objects Within a Site	4-12
Viewing P2000 Object Attributes	4-13
Confirming Change of States in Input and Reader Attributes	4-13
Verification of Metasys-P2000 Integration Using the Metasys M-Alarm Application	4-14
Configuring M5 Workstation and P2000 Object Subscriptions	4-14
Verification of Metasys-P2000 Integration Using the Metasys M-Graphics Application	4-19
Verification Procedure	4-20
Opening a Door Using M-Graphics	4-24
Prod Lib Installation	4-26
Updating Site Database	4-27
M-Explorer Browse Mode Setup	4-27
Notification Recipient Setup	4-28
Security Settings	4-28
M-Graphics	4-28
Door Status	4-29
Controlling Doors	4-29
Input Point Status	4-29
Output Point Status	4-29
Controlling Output Points	4-30

Chapter 5: Troubleshooting

Duplicate Object Name Errors	5-1
Msg Rejected Errors	5-1
Action Interlock Errors	5-1

INTRODUCTION

OVERVIEW

The BACnet Interface allows the P2000 system to be integrated into the Johnson Controls Metasys building automation system. The P2000 system can be monitored and controlled from a Metasys M3 or M5 workstation. This interface provides a BACnet gateway through which P2000 hardware configuration and status information can be accessed. It allows an M3/M5 workstation to receive and acknowledge P2000 alarms and events. In addition, the P2000 software can be configured to cause actions to occur within the Metasys system when access is granted. Figure 1-1 on page 1-3 shows a logical architecture of the BACnet Interface.

NOTES

- *M5 Workstation Software Release 5.4 was used in the development of this manual. Depending on the M3/M5 software version you are using, the screen captures depicted in this manual may differ slightly.*
- *If upgrading P2000 software from version 3.0 and below to any version above 3.0, all BACnet devices must be remapped. Refer to Metasys documentation for more information.*
- *This P2000-BACnet integration cannot be used with the Metasys System Extended Architecture. Johnson Controls offers a separate feature that enables the P2000 to integrate with this system. Refer to the P2000 and Metasys System Extended Architecture Integration Manual (24-10515-80) for more information.*

The following security controllers are supported with the P2000-Metasys integration feature:

Network Controllers	Serial Controllers	Network/Serial Controllers
CK721-A CK721 CK720 CK705	D620 D600-AP D620-TIU S320 P900	S321-DIN

The following controllers are **not** supported with the P2000-Metasys integration feature:

- S321-IP
- PowerNet RC-02 by Isonas
- HID® Edge
- OSI OMNILOCK® wireless readers

THEORY OF OPERATION

BACnet (**B**uilding Automation and **C**ontrol **n**etwork) is a standard protocol from the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). This protocol provides a standard for allowing computers and equipment controllers to transfer data between the devices in an object-oriented fashion. The BACnet standard defines the types of information and attributes that any device must maintain, and defines how BACnet messages are communicated between the various devices.

The attributes associated with a particular device are grouped together into *Objects*. BACnet defines a standard set of objects, and a device may be represented by, or contain a number of these objects. A device **must** contain at least one BACnet object, called a Device Object. Objects have *attributes* and provide standardized functions to read and write those attributes. BACnet also provides defined methods to send event and alarms between equipment.

The BACnet objects associated with the P2000 system represent the P2000 hardware. There are objects for the P2000 host, counters, panels, terminals, readers, input points, and output points. Each of these objects has attributes that contain the configuration parameters and status for that object. For instance, commands to open doors and set output points are sent to the P2000 system by writing specific attributes. The P2000 BACnet Interface also contains Notification Class objects. These objects hold the names of recipients for P2000 alarms and events.

The P2000 BACnet Interface that resides on the P2000 Host computer is called BACnet Service. BACnet Service is a Windows NT service, like the other P2000 communication services. BACnet Service creates the BACnet objects that represent the P2000 hardware, and updates the hardware attributes and status in real time as changes occur in the P2000 system. BACnet Service sends data to and receives data from the Metasys system over the network using the BACnet protocol.

BACnet Service reads from the P2000 database any status information it needs, and uses the standard P2000 message routing service (RTLRoute Service) to receive real-time status and alarm changes. The following figure shows a logical view of this architecture.




Figure 1-1: BACnet Interface Logical Architecture

To prevent unauthorized BACnet devices from accessing the P2000 system, the P2000 system will only communicate with those devices that have been configured as allowed BACnet Sources in the P2000 database. Communication attempts by other devices over the BACnet interface will cause the P2000 system to log a system error and deny communication. A device can also be configured in the P2000 software as a disallowed BACnet Source. In this case the P2000 system will not log any error messages but will deny the communication. Typical BACnet Sources are M3/M5 workstations and N30 controllers.

The BACnet Interface also provides a way for the P2000 system to initiate actions in other BACnet devices. This capability is called an Action Interlock. An Action Interlock is an action caused by a write of the specified value to a specific attribute of a specific BACnet object. This allows the P2000 software to initiate actions in an N30 controller or other BACnet device if the proper attribute is known. The P2000 system allows a badge to be assigned up to two actions (Action Interlocks) that are triggered when that badge is granted access, and also allows Action Interlocks to be assigned as a Host Event Action. A typical use of an Action Interlock would be to cause the lights in a person's office to turn on when they are granted access at the door.

The P2000 software will send out its messages and alarms as BACnet event/alarm messages. In order to receive these BACnet event/alarm messages, a BACnet device must have been added to the recipient list contained in the appropriate Notification Class object. The P2000 BACnet Interface provides for the following event categories:

- Host Events
- Host Log
- Host Logic (not used in this version)

- Audit Log
- Panel Events
- Panel Hardware Status
- Input Status
- Output Status
- Access Grant
- Access Deny
- Access Trace

PRELIMINARY

OBJECT REFERENCE

HOST DEVICE OBJECT

The Host Device Object is a standard BACnet Device Object with additional properties. It represents the P2000 Server and system wide settings. The Host Device Object accepts writes to Invoke Global Access to unlock all doors in the system.

Attributes

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Alarm History	Unsigned			1 to 525600 (1 min to 365 days)
APDU Segment Timeout	Unsigned	B		
APDU Timeout	Unsigned	B		
Application Software Version	String	BK		
Audit History	Unsigned			1 to 525600 (1 min to 365 days)
Audit Item Name	String	IN		Internal use only
Audit Notification Class	Unsigned			Instance of Notification Class
Comms Server	String	K		
Database Server	String			
Daylight Savings Status	Boolean	B		True (1) or False (0)
Description	String	WN	Null	Not written to by P2000
Device Address Binding	List	B		
Error Log Type	String	IN		Internal use only
Firmware Revision	String	B		
Host Event Notification Class	Unsigned			Instance of Notification Class
Host Log Notification Class	Unsigned			Instance of Notification Class

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Host Logic Notification Class	Unsigned			Instance of Notification Class
Invoke Global Access	Boolean	WZ		0 – Open all doors or 1 – Return all doors to normal.
Local Date	Date	B		
Local Time	Time	B		
Max APDU Length Accepted	Unsigned	B		
Model Name	String	B	P2000 BACnet	
Number of APDU Retries	Unsigned	B		
Object Category	Enumeration		Security Category (2)	
Object Identifier	BACnet Object ID	B		Set by the Object Engine
Object List	Array	B		
Object Name	String	BC		<computer name> PEGASYS
Object Type	Enumeration	B	HOST CLASS (314)	
P2000 Event Name	String	IN		Internal use only
PMI Refresh		F		
Protocol Conformance Class	Unsigned (1..6)	B	3	
Protocol Object Types Supported	Enumeration	B		
Protocol Revision	Unsigned	B	1	
Protocol Services Supported	Enumeration	B		
Protocol Version	Unsigned	B	1	
Query Filter String	String	C		
Segmentation Supported	Enumeration	B		
System Status	Enumeration	BDF		Operational (0), Non Operational (4)
Time Synchronization Recipients	List	BI		
Transaction History	Unsigned			1 to 525600 (1 min to 365 days)
Trigger Code	Unsigned	IN		Internal use only

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Trigger Text String	String	IN		Internal use only
Trigger Value	Unsigned	IN		Internal use only
User Name	String	IN		Internal use only
UTC Offset	Integer	B		
Vendor Name	String	B	Cardkey	
Visitor Time	Unsigned	C		1 to 80 hours
Vendor Identifier	Unsigned	B	71	

*A - Save Attribute when Archived, B - BACnet Required Attribute, C - Configurable, D - Default Attribute, E - Execute on Write, F - Person Machine Interface (PMI), I - Internal Attribute, K - Key Attribute, N - Value Not Required, O - Optional Attribute, Q - Input from Other Objects, R - Association to Reliability, V - Redirect Default Value to Attribute, W - Writeable, Z - Priority on Write

Attribute Definitions

Attribute Name	Definition
Alarm History	P2000 requirement. How long Alarm History is maintained in minutes. From P2000 Site configuration.
APDU Segment Timeout	BACnet requirement. Indicates the amount of time in milliseconds between retransmissions of an APDU segment. This value is nonzero if Number of APDU Retries is nonzero. The APDU Segment Timeout property is present if segmentation of any kind is supported. In order to achieve reliable communication, the values of the APDU Segment Timeout attributes of the Host Device Objects of all intercommunicating devices should contain the same value.
APDU Timeout	BACnet requirement. Indicates the amount of time in milliseconds between retransmissions of an APDU requiring acknowledgement for which no acknowledgement has been received. This value is nonzero if Number of APDU Retries is nonzero. In order to achieve reliable communication, the values of the APDU Timeout attributes of the Host Device Objects of all intercommunicating devices should contain the same value.
Application Software Version	BACnet requirement. Identifies the version of the P2000 software installed on the host.
Audit History	P2000 requirement. How long Audit History is maintained in minutes. From P2000 Site configuration.
Audit Item Name	P2000 requirement. Internal use only.
Audit Notification Class	P2000 requirement. Instance number of Notification Class for sending Audit Event messages.
Comms Server	P2000 requirement. Name of computer running communication services. From P2000 Site configuration.
Database Server	P2000 requirement. Name of computer running database engine.
Daylight Savings Status	BACnet requirement. Indicates if daylight saving time is in effect (True) or not (False).
Description	Metasys system requirement. This is a string of printable characters.

Attribute Name	Definition
Device Address Binding	BACnet requirement. This is a list of BACnet Object Identifiers of a Host Device Object and a BACnet device address in the form of a BACnet Address. Entries in the list identify the actual device addresses that are used when the remote device is accessed via a BACnet service request. The list may be empty if no device identifier-device address bindings are currently known to the device.
Error Log Type	P2000 requirement. Internal use only.
Firmware Revision	BACnet requirement. Identifies the version of the P2000 software installed on the host.
Host Event Notification Class	P2000 requirement. Instance number of Notification Class for sending Host Event messages.
Host Log Notification Class	P2000 requirement. Instance number of Notification Class for sending Host Log messages.
Host Logic Notification Class	P2000 requirement. Instance number of Notification Class for sending Host Logic messages.
Invoke Global Access	P2000 requirement. This unlocks every door in the P2000 system if set (True) or normal operation if reset (False).
Local Date	BACnet requirement. This indicates the date.
Local Time	BACnet requirement. This indicates the time of day.
Max APDU Length Accepted	BACnet requirement. The maximum number of octets contained in a single, indivisible application layer protocol unit. Underlying data link technology constrains the value of this attribute.
Model Name	BACnet requirement. Set to "PEGASYS 2000 BACnet."
Number of APDU Retries	BACnet requirement. Indicates the maximum number of times that an APDU is retransmitted. The default value is 3. If this device does not perform retries, then this property is zero. If the value of this property is greater than zero, a nonzero value is placed in the Host Device Object APDU Timeout property.
Object Category	Metasys system requirement. Set to Security Category (2).
Object Identifier	BACnet requirement. A unique numeric code used to identify the object.
Object List	BACnet requirement. This is an array of object identifiers, one for each object in the device accessible by BACnet services.
Object Name	BACnet requirement. Set to "<computer name> PEGASYS."
Object Type	BACnet requirement. Identifies the type of this object. Set to HOST CLASS (314).
P2000 Event Name	P2000 requirement. Internal use only.
PMI Refresh	Metasys system requirement.
Protocol Conformance Class	BACnet requirement. This integer indicates that the device supports a specific set of standardized protocol services and object types. While the Protocol Conformance Class indicates the minimum set of standardized services, object types, and properties required to claim a particular level of conformance, implementation often supports additional services, object types, and properties. Protocol Services Supported and Protocol Object Types Supported describe the set of all such standardized services and object types.

Attribute Name	Definition
Protocol Object Types Supported	BACnet requirement. Indicates which standardized object types the device's protocol implementation supports. Protocol Conformance Class reflects the minimum set of object types, but an implementation often supports additional standard and non-standard object types with their own set of properties
Protocol Revision	BACnet requirement. Indicates the minor revision level of the BACnet standard. This starts at 1 and increases for each subsequent release. If Protocol Version attribute changes, this number reverts to zero. Annex K records changes to the values for Protocol Version and Protocol Revision. This attribute is required for all devices with BACnet Protocol Version 1, Protocol Revision 1 and above. If this attribute is not present, the device is Protocol Version 1, Protocol Revision 0.
Protocol Services Supported	BACnet requirement. Indicates which standardized protocol services the device's protocol implementation supports. Protocol Conformance Class reflects the minimum set of services, but an implementation often supports additional standardized services.
Protocol Version	BACnet requirement. Represents the BACnet protocol supported by the device. Initial releases are Version 1, subsequent releases increase the number by one.
Query Filter String	Metasys requirement. From P2000 Site configuration.
Segmentation Supported	BACnet requirement. Indicates if the BACnet device supports segmentation of messages and (if so) if it supports segmented transmission, reception, or both.
System Status	BACnet requirement. Reflects the current state of the P2000 Server.
Time Synchronization Recipients	BACnet requirement. This is used to control the restrictions placed on a device's use of the Time Synchronization service. If the list is of length zero, a device is prohibited from automatically sending a Time Synchronization request. If the list is of length one or more, a device automatically sends a Time Synchronization request but only to the devices or addresses listed. If it is present, this property is writeable. If the PICS indicates that this device is a Time Master, then Time Synchronization Recipients is present.
Transaction History	P2000 requirement. How long Transaction History is maintained in minutes. From P2000 Site configuration.
Trigger Code	P2000 requirement. Internal use only.
Trigger Text String	P2000 requirement. Internal use only.
Trigger Value	P2000 requirement. Internal use only.
User Name	P2000 requirement. Internal use only.
UTC Offset	BACnet requirement. Indicates the number of minutes offset between local standard time and Universal Time Coordinated (UTC). The Time Zones to the west of the zero degree meridian are positive and those to the east are negative. Subtract the value of the UTC Offset from the UTC received in the UTC Time Synchronization service requests to calculate the correct local standard time.
Vendor Name	BACnet requirement.
Visitor Time	P2000 requirement. Default Visitor Badge Valid time in hours. From P2000 Site configuration.
Vendor Identifier	BACnet requirement. This is a unique ASHRAE vendor ID code that distinguishes proprietary extensions to the protocol.

COUNTER OBJECT

The P2000 Counter Object is a custom object that represents a single P2000 Counter Object.

Attributes

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Description	String	W	Null	Not written to by P2000
Device Name	String			
Object Category	Enumeration		Security Category (2)	
Object Identifier	Enumeration	B		
Object Name	String	BC		<counter name> <Partition>
Object Type	Enumeration	B	COUNTER CLASS (317)	
Partition	String	K		
PMI Refresh		F		
Present Value	Signed	DF		-2147483648 to 2147483647
Query Filter String	String	C		

*A - Save Attribute when Archived, B - BACnet Required Attribute, C - Configurable, D - Default Attribute, E - Execute on Write, F - Person Machine Interface (PMI), I - Internal Attribute, K - Key Attribute, N - Value Not Required, O - Optional Attribute, Q - Input from Other Objects, R - Association to Reliability, V - Redirect Default Value to Attribute, W - Writeable, Z - Priority on Write

Attribute Definitions

Attribute Name	Definition
Description	Metasys system requirement. This is a string of printable characters.
Device Name	Metasys system requirement. The name of the host device.
Object Category	Metasys system requirement. Always set to SECURITY CATEGORY (2).
Object Identifier	BACnet requirement. Set by Object Engine. A unique numeric code that identifies the object.
Object Name	BACnet requirement. A character string that represents the name of the counter.
Object Type	BACnet requirement. A value that indicates membership in a particular object class.
Partition	P2000 requirement. Partition that owns this counter.
PMI Refresh	Metasys system requirement.
Present Value	P2000 requirement. This indicates the present value of the counter.
Query Filter String	Metasys requirement. From P2000 Site configuration.

PANEL OBJECT

The P2000 Panel Object is a custom BACnet Object. It represents a panel as configured in P2000. There will be one Panel Object for every panel configured in P2000. Although the Panel Object contains attributes for intrinsic reporting, they are not used in this version of P2000.

Status Relationships

The status of the panel relates to the system status in the relationship shown as follows:

Panel Status	Present Value	Reliability
Up	Up	No Fault Detected
Down	Down	Unreliable Other

Attributes

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Acked Transitions	Bit String	B		To-Offnormal, To-Fault, To-Normal
Alt IP Address	String	C		
Alt is Dialup	Boolean	C		True (1) or False (0)
Description	String	W	Null	Not written to by P2000
Event Enable	Bit String	WB		To-Offnormal, To-Fault, To-Normal
Firmware Revision	String	B		Starting in P2000 version 2.1, it will be exactly the same as the application software version.
Input Report Delay	Unsigned	C		0 to 60 seconds
Loop Number	Unsigned	CK		
Model Name	String	B		
Network Timeout	Unsigned	C		
Notification Class	Unsigned	B		Instance of Notification Class
Notify Type	Enumeration	WB		Alarm or Event
Object Category	Enumeration		Security Category (2)	
Object Identifier	BACnet Object ID	B		Set by Object Engine
Object Name	String	BN		
Object Type	Enumeration	B	PANEL CLASS (315)	
Out of Service	Boolean	B		True (1) or False (0)

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Output Delay	Unsigned	C		0 to 60 seconds
Panel Event Notification Class	Unsigned			Instance of Notification Class
Panel Hardware Notification Class	Unsigned			Instance of Notification Class
Partition	String	CD		
PMI Refresh		F		
Present Value	Unsigned	BDRF		1 - Up, 2 - Down
Pri IP Address	String	CK		
Pri Preferred	Boolean	C		True (1) or False (0)
Pri Valid	Boolean	C		True (1) or False (0)
Public	Boolean	CK		True (1) or False (0)
Query Filter String	String	C		
Reliability	Enumeration	B		No Fault Detected, Disabled, Unreliable Other
Status Flags	Bit String	BF		In Alarm (always False), Fault (True if Reliability is Unreliable Other), Overridden (always False), Out of Service (True if Out of Service is True)
Time Delay	Unsigned	BC	0	
Unit Number	Unsigned	CK		1 to 16

*A - Save Attribute when Archived, B - BACnet Required Attribute, C - Configurable, D - Default Attribute, E - Execute on Write, F - Person Machine Interface (PMI), I - Internal Attribute, K - Key Attribute, N - Value Not Required, O - Optional Attribute, Q - Input from Other Objects, R - Association to Reliability, V - Redirect Default Value to Attribute, W - Writeable, Z - Priority on Write

Attribute Definitions

Attribute Name	Definition
Acked Transitions	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Alt IP Address	P2000 requirement. Alternate IP address of panel (redundant path).
Alt is Dialup	P2000 requirement. True if alternate IP address is dialup.
Description	Metasys system requirement. This is a string of printable characters.
Event Enable	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Firmware Revision	BACnet requirement. Version string returned from the panel.
Input Report Delay	P2000 requirement. Number of seconds that an input must be set before generating an alarm.
Loop Number	P2000 requirement. Loop number of panel (serial panels only).
Model Name	BACnet requirement. The model of the panel.
Network Timeout	P2000 requirement. Network timeout setting for the panel in seconds.

Attribute Name	Definition
Notification Class	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Notify Type	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Object Category	Metasys system requirement. Always set to SECURITY CATEGORY (2).
Object Identifier	BACnet requirement. A unique numeric code used to identify the object.
Object Name	BACnet requirement. Panel name as configured in P2000.
Object Type	BACnet requirement. PANEL CLASS (315).
Out of Service	BACnet requirement. Indicates whether (True) or not (False) the terminal is not in service.
Output Delay	P2000 requirement. Number of seconds delay before setting an output.
Panel Event Notification Class	P2000 requirement. Instance of Notification Class used to report Panel Event messages.
Panel Hardware Notification Class	P2000 requirement Instance of Notification Class used to report Panel Hardware status messages.
Partition	P2000 requirement. Partition that owns this panel.
PMI Refresh	Metasys system requirement.
Present Value	BACnet requirement. This indicates the logical state of the output. INACTIVE (0) or ACTIVE (1)
Pri IP Address	P2000 requirement. Primary IP address of panel.
Pri Preferred	P2000 requirement. True if Primary IP address is preferred communication path.
Pri Valid	P2000 requirement. True if P2000 currently using Primary IP Address. False if P2000 currently using Alt IP Address.
Public	P2000 requirement. True if panel visible to other partitions.
Query Filter String	P2000 requirement. From panel configuration.
Reliability	BACnet requirement. Indicates if the Present Value is reliable or not, and why.
Status Flags	BACnet requirement. Represents four Boolean flags that indicate the general health of an object. Three flags are associated with the values of other attributes of the object. To determine a more complete status of the object, read these flags.
Time Delay	BACnet requirement. Report delay in seconds from panel.
Unit Number	P2000 requirement. Unit number of panel (serial panels only).

TERMINAL OBJECT

The P2000 Terminal Object is a custom object with attributes similar to the BACnet Multistate Output Object and additional attributes. It represents configured terminals in P2000. For every configured terminal, there will be three Terminal Objects. One object represents the Reader Terminal attributes, one represents the Input Terminal attributes, and the third represents the Output Terminal attributes. Although the Terminal Object contains the attributes for intrinsic reporting, they are not used in this version of P2000.

Status Relationships

The status of the terminal and the parent panel, the present value of the object, and the reliability of the object interrelate in the manner shown in the following table:

Terminal Status	Parent Panel Status	Present Value	Reliability
Unknown	Up	Up	Unreliable Other
Up	Up	Up	No Fault Detected
Down	Up	Down	No Fault Detected
Disabled	Up	Up	Disabled
<don't care>	Down	Up	Unreliable Other

Attributes

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Acked Transitions	Bit String	B		To-Offnormal, To-Fault, To-Normal
Description	String	W	Null	Not written to by P2000
Device Name	String			
Event Enable	Bit String	WB		To-Offnormal, To-Fault, To-Normal
Event State	Enumeration	B	Normal	
Notification Class	Unsigned	B		Instance of Notification Class
Notify Type	Enumeration	WB	Event	Alarm or Event
Number of States	Unsigned	B	2	
Object Category	Enumeration		Security Category (2)	
Object Identifier	BACnet Object ID	B		Set by the Object Engine
Object Name	String	BC		<terminal name> <Rdr, In, or Out> Term
Object Type	Enumeration	B	TERM CLASS (316)	
Out of Service	Boolean	B		True (1) or False (0)
Output Stat Enabled	Boolean	C		True (1) or False (0)
Parent Panel	String	CP		
Partition	String	CK		
PMI Refresh		F		
Present Value	Unsigned	BDRF		1 - Up, 2 - Down
Present Value Text	String	RF		
Priority Array	Array	B		(Empty array)
Public	Boolean	CK		True (1) or False (0)
Query Filter String	String	C		
Reliability	Enumeration	B		No Fault Detected, Disabled, Unreliable Other
Relinquish Default	Unsigned	B	Up (1)	Up (1)

Attribute Name	Data Type	Flags*	Default Value	Options/Range
State Text	Array	B		Up, Down
Status Flags	Bit String	BF		In Alarm (always False), Fault (True if Reliability is Unreliable Other), Overridden (always False), Out of Service (True if disabled)
Strike Stat Enabled	Boolean	C		True (1) or False (0)
Terminal Enable	Boolean	CK		True (1) or False(0)
Terminal Type	Enumeration	CK		Reader (0), Input (1), or Output (2)
Time Delay	Unsigned	BC	0	

*A - Save Attribute when Archived, B - BACnet Required Attribute, C - Configurable, D - Default Attribute, E - Execute on Write, F - Person Machine Interface (PMI), I - Internal Attribute, K - Key Attribute, N - Value Not Required, O - Optional Attribute, Q - Input from Other Objects, R - Association to Reliability, V - Redirect Default Value to Attribute, W - Writeable, Z - Priority on Write

Attribute Definitions

Attribute Name	Definition
Acked Transitions	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Description	Metasys system requirement. This is a string of printable characters.
Device Name	Metasys system requirement. Name of the panel that contains this terminal.
Event Enable	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Event State	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Notification Class	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Notify Type	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Number of States	BACnet requirement. Defines the number of states possible for Present Value.
Object Category	Metasys system requirement. Always set to SECURITY CATEGORY (2).
Object Identifier	BACnet requirement. A unique numeric code used to identify the object.
Object Name	BACnet requirement. Based upon the terminal name as configured in P2000 as <terminal name> <Rdr, In, or Out> Term.
Object Type	BACnet requirement. A value that indicates the object type class. Set to TERM CLASS (316).
Out of Service	BACnet requirement. Indicates whether (True) or not (False) the terminal is not in service.
Output Stat Enabled	P2000 requirement. True if the terminal should send Output status messages to P2000 Server.
Parent Panel	P2000 requirement. Name of the panel to which this terminal is attached.
Partition	P2000 requirement. The partition that owns this terminal.

Attribute Name	Definition
PMI Refresh	Metasys system requirement
Present Value	BACnet requirement. This indicates the logical state of the output. INACTIVE (0) or ACTIVE (1)
Present Value Text	P2000 requirement. Text of the Present Value state. "Active" or "Inactive"
Priority Array	BACnet requirement. Not used in this version of P2000.
Public	P2000 requirement. True if terminal visible to other partitions.
Query Filter String	Metasys requirement. From terminal configuration.
Reliability	BACnet requirement. Indicates if the Present Value is reliable or not, and why.
Relinquish Default	BACnet requirement. Not used in this version of P2000.
State Text	BACnet requirement. This is an array of character strings representing descriptions of all possible states of Present Value. The number of descriptions matches the number of states found in Number of States. As an integer, Present Value serves as an index to the array.
Status Flags	BACnet requirement. Represents four Boolean flags that indicate the general health of an object. Three flags are associated with the values of other attributes of the object. To determine a more complete status of the object, read these flags.
Strike Stat Enabled	P2000 requirement. True if terminal should send door strike messages to P2000 Server.
Term Index	Unsigned
Terminal Enable	P2000 requirement. True if terminal enabled.
Terminal Type	P2000 requirement. Indicates type of terminal.
Time Delay	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.

READER OBJECT

The P2000 Reader Object is a custom object with attributes similar to the BACnet Multistate Output Object with additional attributes. This object represents the Reader attributes for the corresponding reader terminal in P2000. Although this object has intrinsic reporting attributes, they are not used in this version of P2000. The Reader Object accepts writes to Present Value to unlock or override doors.

Status Relationships

The status of the reader and parent panel, the present value of the object, and the reliability of the object interrelate in the manner shown below:

Reader Status	Parent Panel Status	Present Value	Reliability
Unknown	Up	Locked Closed	Unreliable Other
Locked Closed	Up	Locked Closed	No Fault Detected
Unlocked Closed	Up	Unlocked Closed	No Fault Detected

Reader Status	Parent Panel Status	Present Value	Reliability
Locked Open	Up	Locked Open	No Fault Detected
Unlocked Open	Up	Unlocked Open	No Fault Detected
Down	Up	Down	No Fault Detected
Disabled	Up	Locked Closed	Disabled
<don't care>	Down	Locked Closed	Unreliable Other

Attributes

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Access Deny Notification Class	Unsigned			Instance of Notification Class
Access Grant Notification Class	Unsigned			Instance of Notification Class
Access Mode	Enumeration	CK		Local (0), Shared (1), or Central (2)
Access Time	Unsigned	CK		
Acked Transitions	Bit String	B		To-Offnormal, To-Fault, To-Normal
Action Interlock Enable	Boolean	C	True (1)	True (1) or False(0)
Badge Number	String	IN		Internal use only
Badge Trace	Boolean	IN		Internal use only
Barcode Attachment	String	IN		Internal use only
Card Trace Notification Class	Unsigned			Instance of Notification Class
Description	String	W	Null	Not written to by P2000
Device Name	String			
Direction	Enumeration	IN		Internal use only
Event Enable	Bit String	WB		To-Offnormal, To-Fault, To-Normal
Event State	Enumeration	B	Normal	
Facility Code	Unsigned	IN		Internal use only
First Name	String	IN		Internal use only
Function Key	Unsigned	IN		Internal use only
Issue Level	Unsigned	IN		Internal use only
Last Name	String	IN		Internal use only
Notification Class	Unsigned	B		Instance of Notification Class
Notify Type	Enumeration	WB	Event	Alarm or Event
Number of States	Unsigned	B	4	
Object Category	Enumeration		Security Category (2)	
Object Identifier	BACnet Object ID	B		Set by the Object Engine

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Object Name	String	BC		Reader <terminal name>
Object Type	Enumeration	B	READER CLASS (318)	
Out of Service	Boolean	B		True (1) or False (0)
Override Enable	Boolean	C		True (1) or False (0)
Override Tz	String	CK		
Parent Terminal	String	CQ		
Partition	String	CK		
Pin Code Tz	String	C		
PMI Refresh		F		
Present Value	Unsigned	WZBDRF		1 - Locked Closed, 2 - Unlocked Closed, 3 - Locked Open, 4 - Unlocked Open, Write 13 - Unlock for Unlock Time, Write 12 - Unlock for access time, Write 11 - Return to normal (cancel timed unlock)
Present Value Text	String	RF		
Priority Array	Array	B		(Empty array)
Public	Boolean	CK		True (1) or False (0)
Query Filter String	String	C		
Reliability	Enumeration	B		No Fault Detected, Disabled, Unreliable Other
Relinquish Default	Unsigned	B		1 (Locked Closed)
Shunt Time	Unsigned	CK		0 to 255 seconds
State Text	Array	B		Locked Closed, Unlocked Closed, Locked Open, Unlocked Open
Status Flags	Bit String	BF		In Alarm (always False), Fault (True if Reliability is Unreliable Other), Overridden (always False), Out of Service (True if Out of Service is True)
T&A Access Notification Class	Unsigned			Instance of Notification Class
Term Tz	String	CK		
Time Delay	Unsigned	BC	0	
Timed Override	Unsigned	IN		Internal use only
Unlock Time	Unsigned	W		0 to 1440 minutes

*A - Save Attribute when Archived, B - BACnet Required Attribute, C - Configurable, D - Default Attribute, E - Execute on Write, F - Person Machine Interface (PMI), I - Internal Attribute, K - Key Attribute, N - Value Not Required, O - Optional Attribute, Q - Input from Other Objects, R - Association to Reliability, V - Redirect Default Value to Attribute, W - Writeable, Z - Priority on Write

Attribute Definitions

Attribute Name	Definition
Access Deny Notification Class	P2000 requirement. Instance of Notification Class used to send Access Deny messages.
Access Grant Notification Class	P2000 requirement. Instance of Notification Class used to send Access Grant messages.
Access Mode	P2000 requirement. Indicates the configured access mode: Local, Shared, or Central.
Access Time	P2000 requirement. The access time in seconds.
Acked Transitions	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Action Interlock Enable	P2000 requirement. Enables Action Interlocks from this Reader if set to True (1).
Badge Number	P2000 requirement. Internal use only.
Badge Trace	P2000 requirement. Internal use only.
Barcode Attachment	P2000 requirement. Internal use only.
Card Trace Notification Class	P2000 requirement. Instance of Notification Class used to send Card Trace messages.
Description	Metasys system requirement. This is a string of printable characters.
Device Name	Metasys system requirement. Name of the panel that contains this terminal.
Direction	P2000 requirement. Internal use only.
Event Enable	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Event State	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Facility Code	P2000 requirement. Internal use only.
First Name	P2000 requirement. Internal use only.
Function Key	P2000 requirement. Internal use only.
Issue Level	P2000 requirement. Internal use only.
Last Name	P2000 requirement. Internal use only.
Notification Class	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Notify Type	BACnet requirement. For intrinsic reporting. Not used in this version of P2000.
Number of States	BACnet requirement. Defines the number of states possible for Present Value.
Object Category	Metasys system requirement. Always set to SECURITY CATEGORY (2).
Object Identifier	BACnet requirement. A unique numeric code used to identify the object.
Object Name	BACnet requirement. Based upon the terminal name as configured in P2000 as Reader <terminal name>.
Object Type	BACnet requirement. A value that indicates the object type class. Set to READER CLASS (319).
Out of Service	BACnet requirement. Indicates whether (True) or not (False) the output or process the object represents is not in service.

Attribute Name	Definition
Override Enable	P2000 requirement. True if Cardholder Override is enabled.
Override Tz	P2000 requirement. Timezone during which the reader is overridden.
Parent Terminal	P2000 requirement. Name of the terminal to which this reader is attached.
Partition	P2000 requirement. The partition that owns this terminal.
Pin Code Tz	P2000 requirement. Timezone during which pin codes are disabled.
PMI Refresh	Metasys system requirement.
Present Value	BACnet requirement. This indicates the state of the reader. The state of the reader is one of 4 states: Locked Closed, Unlocked Closed, Locked Open, or Unlocked Open. Current version of P2000 will only report Locked Closed or Unlocked Closed.
Present Value Text	P2000 requirement. Text string of the Present Value.
Priority Array	BACnet requirement. Not used in this version of P2000.
Public	P2000 requirement. True if reader is visible to other partitions.
Query Filter String	P2000 requirement. From terminal configuration.
Reliability	BACnet requirement. Indicates if the Present Value is reliable or not, and why.
Relinquish Default	BACnet requirement. Not used in this version of P2000.
Shunt Time	P2000 requirement. The shunt time in seconds.
State Text	BACnet requirement. This is an array of character strings representing descriptions of all possible states of Present Value. The number of descriptions matches the number of states found in Number of States. As an integer, Present Value serves as an index to the array.
Status Flags	BACnet requirement. Represents four Boolean flags that indicate the general health of an object. Three flags are associated with the values of other attributes of the object. To determine a more complete status of the object, read these flags.
T&A Access Notification Class	P2000 requirement. Instance of Notification Class used to send T&A messages. Not used by this version of P2000.
Term Tz	P2000 requirement. Time zone during which the reader is enabled.
Time Delay	BACnet requirement. Not used in this version of P2000.
Timed Override	P2000 requirement. Internal use only.
Unlock Time	P2000 requirement. Time in minutes to unlock the door (see Present Value).

INPUT POINT OBJECT

The P2000 Input Point Object is a standard BACnet Life Safety Device Object with Fault/Reliability attributes. This object represents a configured input point object in P2000. The Input Point Object uses intrinsic reporting for event notification.

Status Relationships

The status of the input, parent terminal, and parent panel, the present value of the object, and the reliability of the object interrelate in the manner shown below:

Input Status	Parent Terminal Status	Parent Panel Status	Present Value	Reliability
Unknown	Up	Up	Quiet	Unreliable Other
Reset	Up	Up	Quiet	No Fault Detected
Set	UP	Up	Alarm	No Fault Detected
Short	UP	Up	Fault	Shorted Loop
Open	Up	Up	Fault	Open Loop
Disabled	Up	Up	Quiet	Disabled
<don't care>	Down, Unknown, or Disabled	Up	Quiet	Unreliable Other
<don't care>	<don't care>	Down	Quiet	Unreliable Other

Attributes

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Acked Transitions	Bit String	B		To-Offnormal, To-Fault, To-Normal
Alarm Values	List	B		Alarm
Description	String	W	Null	Not written to by P2000
Device Name	String			
Display Alarm	Boolean	CK		True (1) or False (0)
Event Enable	Bit String	WB		To-Offnormal, To-Fault, To-Normal
Event State	Enumeration	B		Normal, Fault, Offnormal
Event Time Stamps	Array	B		
Fault Values	List	B		Fault-Alarm
Mode	Enumeration	WBC		Enabled, Disabled
Notification Class	Unsigned	B		Instance of Notification Class
Notify Type	Enumeration	WB		Alarm or Event
Object Category	Enumeration		Security Category (2)	
Object Identifier	BACnet Object ID	B		Set by the Object Engine
Object Name	String	BC		
Object Type	Enumeration	B	SECURITY BI CLASS (323)	
Operation Required	Enumeration	B		None
Out of Service	Boolean	B		True (1) or False (0)
Parent Terminal	String	CKQ		

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Partition	String	CK		
PMI Refresh		F		
Point Number	Unsigned	CK		1-25
Present Value	Unsigned	BDRF		Quiet (0), Alarm (2), Fault (3), Fault-Alarm (5)
Present Value Text	String	RF		Quiet, Alarm, Short, Open
Priority	Unsigned8	CK		0-255
Public	Boolean	CK		True if this input is visible from other partitions
Query Filter String	String	C		
Reliability	Enumeration	B		No Fault Detected, Open Loop, Shorted Loop, Unreliable Other (if parent terminal is down or offline)
Silenced	Enumeration	B	Unsilenced	
Soft Input	Boolean	CK		True (1) or False (0)
Status Flags	Enumeration	B		In Alarm (True if Event State is not Normal), Fault (True if Reliability is not No Fault Detected), Overridden (always False), Out of Service (True if Out of Service is True)
Supervised	Boolean	C		True (1) or False (0)
Suppression Tz	String	CK		
Time Delay	Unsigned	BC	0	

*A - Save Attribute when Archived, B - BACnet Required Attribute, C - Configurable, D - Default Attribute, E - Execute on Write, F - Person Machine Interface (PMI), I - Internal Attribute, K - Key Attribute, N - Value Not Required, O - Optional Attribute, Q - Input from Other Objects, R - Association to Reliability, V - Redirect Default Value to Attribute, W - Writeable, Z - Priority on Write

Attribute Definitions

Attribute Name	Data Type
Acked Transitions	<p>BACnet requirement. For intrinsic reporting. Conveys three flags that separately indicate the receipt of acknowledgments for To-Offnormal, To-Fault, and To-Normal events.</p> <p>These flags clear upon the occurrence of the corresponding event and set under any of these conditions:</p> <ul style="list-style-type: none"> ■ upon receipt of the corresponding acknowledgement; ■ upon the occurrence of the event if the corresponding flag is not set in Event Enable (event notifications are not generated for this condition and thus no acknowledgement is expected); ■ upon the occurrence of the event if the corresponding flag is set in Event Enable and the corresponding flag in Ack Required of the Notification Class Object implicitly referenced by the Notification Class attribute of this object is not set (no acknowledgement is expected).

Attribute Name	Data Type
Alarm Values	<p>BACnet requirement. Specifies any states the Present Value must equal before a To-Offnormal event generates. If the object supports intrinsic reporting, this attribute is required.</p> <p>A To-Offnormal event generates under these conditions:</p> <ul style="list-style-type: none"> the To-Offnormal flag is enabled in the Event Enable property, and Present Value equals at least one of the values in the Alarm Values list, and Present Value remains equal to the same value for a minimum period of time, specified by Time Delay. <p>New events may generate upon a Mode change.</p> <p>Once equal, Present Value must not equal any of the states in the Alarm Values property and not equal to any of the states in Fault Values, before a To-Normal event generates under these conditions:</p> <ul style="list-style-type: none"> the To-Normal flag is enabled in Event Enable, and Present Value remains not equal to any of the states in Alarm Values, and Present Value remains not equal to any of the states in Fault Values, and Present Value remains equal to the same value for a minimum period of time, specified by Time Delay. <p>New events may generate upon a Mode change.</p>
Description	Metasys system requirement. This is a string of printable characters.
Device Name	Metasys system requirement. Name of panel that contains this input
Display Alarm	P2000 requirement. True if input status changes should be handled as an alarm.
Event Enable	BACnet requirement. For intrinsic reporting. Conveys three flags that separately enable and disable reporting of To-Offnormal, To-Fault, and To-Normal events based on Present Value and Mode changes.
Event State	BACnet requirement. For intrinsic reporting. This is included to determine if the object has an active event state associated with it. This attribute indicates the event state of the object.
Event Time Stamps	BACnet requirement. For intrinsic reporting. Conveys the times of the last event notifications for To-Offnormal, To-Fault, and To-Normal events, respectively. Time stamps of type Time or Date have FF in each octet. Sequence number time stamps are 0 if no event notification of that type has generated since the object was created.
Fault Values	<p>BACnet requirement. Specifies any states Present Value must equal before a To-Fault event generates. A To-Fault event generates under these conditions:</p> <ul style="list-style-type: none"> the To-Fault flag is enabled in Event Enable, and Present Value equals at least one of the values in the Fault Values list. <p>New events may generate upon a Mode change.</p>
Mode	BACnet requirement. True if the input point is enabled.
Notification Class	BACnet requirement. For intrinsic reporting. Specifies the notification class used when handling and generating event notification for P2000 Input Point. This attribute implicitly refers to a Notification Class object that has a Notification Class attribute with the same value.
Notify Type	BACnet requirement. For intrinsic reporting. Conveys if the notifications generated by the object are Events or Alarms.
Object Category	Metasys system requirement. Always set to SECURITY CATEGORY (2).
Object Identifier	BACnet requirement. A unique numeric code used to identify the object.
Object Name	BACnet requirement. Input point name.
Object Type	BACnet requirement. The object type class. Set to SECURITY BI CLASS (323).

Attribute Name	Data Type
Operation Required	BACnet requirement. Not used in this version of P2000.
Out of Service	BACnet requirement. Indicates whether (True) or not (False) the inputs or process the object represents are not in service.
Parent Terminal	P2000 requirement. Name of the terminal to which this output is attached.
Partition	P2000 requirement. The partition that owns this input.
PMI Refresh	Metasys system requirement.
Point Number	P2000 requirement. The point number as configured in P2000.
Present Value	BACnet requirement. Reflects the state of the P2000 Input Point Object.
Present Value Text	P2000 requirement. Text string of the Present Value.
Priority	P2000 requirement. The configured priority for alarms generated by this input point.
Public	P2000 requirement. True if this input point visible to other partitions.
Query Filter String	P2000 requirement. From input point configuration.
Reliability	BACnet requirement. Provides an indication if the Present Value or the operation of the physical inputs in question are reliable or not, and why.
Silenced	BACnet requirement. Not used in this version of P2000.
Soft Input	P2000 requirement. True if this input point is a virtual point with no actual hardware input.
Status Flags	BACnet requirement. Represents four Boolean flags that indicate the general health of the object. Three of the flags are associated with the values of other properties of this object. To determine a more detailed status of the object, read the properties linked to these flags.
Supervised	P2000 requirement. True if this input is a 4-state input point. If False, this is a 2-state input point.
Suppression Tz	P2000 requirement. Name of timezone during which this input point is suppressed.
Time Delay	BACnet requirement. Not used in this version of P2000.

OUTPUT POINT OBJECT

The P2000 Output Point Object is the standard BACnet Binary Output Object with additional attributes. It represents a configured Output Point in P2000. The Output Point Object uses intrinsic reporting for event notification and accepts writes to Present Value to Activate/Deactivate output points.

Status Relationships

The status of the input, parent terminal, and parent panel, the present value of the object, and the reliability of the object interrelate in the manner shown as follows:

Input Status	Parent Terminal Status	Parent Panel Status	Present Value	Reliability
Unknown	Up	Up	Inactive	Unreliable Other
Reset	Up	Up	Inactive	No Fault Detected
Set	Up	Up	Active	No Fault Detected
<don't care>	Down, Unknown, or Disabled	Up	Inactive	Unreliable Other
<don't care>	<don't care>	Down	Inactive	Unreliable Other

Attributes

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Acked Transitions	Bit String	B		To-Offnormal, To-Fault, To-Normal
Active Text	String	B	Active	Active
Description	String	W	Null	Not written to by P2000
Device Name	String			
Event Enable	Bit String	WB		To-Offnormal, To-Fault, To-Normal
Event State	Enumeration	B		Normal
Feedback Value	Enumeration	B	Inactive	
Inactive Text	String	B	Inactive	Inactive
Notification Class	Unsigned	B		Instance of Notification Class
Notify Type	Enumeration	B	Event	Event
Object Category	Enumeration		Security Category (2)	
Object Identifier	BACnet Object ID	B		Set by the Object Engine
Object Name	String	BC		
Object Type	Enumeration	B	SECURITY BO CLASS (324)	
Out of Service	Boolean	B		True (1) or False (0)
Parent Terminal	String	CKQ		
Partition	String	CK		
PMI Refresh		F		
Point Number	Unsigned	CK		1-16
Polarity	Enumeration	B		Normal, Reverse
Present Value	Enumeration	WBDRF		Active (1), Inactive (0)

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Present Value Text	String	RF		Active, Inactive
Priority Array	Array	B		Empty array
Public	Boolean	CK		True (1) or False (0)
Query Filter String	String	C		
Reliability	Enumeration	B		No Fault Detected, Unreliable Other
Relinquish Default	Enumeration	B	Inactive	Inactive
Status Flags	Enumeration	B		In Alarm (always False), Fault (True if Reliability is not No Fault Detected), Overridden (always False), Out of Service (True if Out of Service is True)
Time Delay	Unsigned	BC	0	

*A - Save Attribute when Archived, B - BACnet Required Attribute, C - Configurable, D - Default Attribute, E - Execute on Write, F - Person Machine Interface (PMI), I - Internal Attribute, K - Key Attribute, N - Value Not Required, O - Optional Attribute, Q - Input from Other Objects, R - Association to Reliability, V - Redirect Default Value to Attribute, W - Writeable, Z - Priority on Write

Attribute Definitions

Attribute Name	Definition
Acked Transitions	BACnet requirement. For intrinsic reporting. Conveys three flags that separately indicate the receipt of acknowledgments for To-Offnormal, To-Fault, and To-Normal events. Transitions to High Limit and Low Limit Event States are considered to be Offnormal events. These flags clear upon the occurrence of the corresponding event and set under any of these conditions: <ul style="list-style-type: none"> ■ upon receipt of the corresponding acknowledgement; ■ upon the occurrence of the event if the corresponding flag is not set in the Event Enable attribute (meaning event notifications are not generated for this condition and thus no acknowledgement is expected); ■ upon the occurrence of the event if the corresponding flag is set in the Event Enable attribute and the corresponding flag in the Ack Required attribute of the Notification Class Object implicitly referenced by the Notification Class attribute of this object is not set (meaning no acknowledgement is expected).
Active Text	BACnet requirement. The text used by Present Value Text when the output is active.
Description	Metasys system requirement. This is a string of printable characters.
Device Name	BACnet requirement. Name of the panel that contains this output.
Event Enable	BACnet requirement. For intrinsic reporting. Conveys three flags that separately enable and disable reporting of To-Offnormal, To-Fault, and To-Normal events.
Event State	BACnet requirement. For intrinsic reporting. Provides a way to determine if the object has an active event state associated with it.
Feedback Value	BACnet requirement. Not used in this version of P2000.
Inactive Text	BACnet requirement. The text used by Present Value Text when the output is inactive.

Attribute Name	Definition
Notification Class	BACnet requirement. For intrinsic reporting. Specifies the notification class used when handling and generating event notifications for the object. This attribute implicitly refers to the BACnet Notification Class Object that has a Notification Class attribute of the same value.
Notify Type	BACnet requirement. For intrinsic reporting. Conveys if the notifications generated by the object are Events or Alarms. Always set to Events in this version of P2000.
Object Category	Metasys system requirement. Always set to SECURITY CATEGORY (2).
Object Identifier	BACnet requirement. A unique numeric code used to identify the object.
Object Name	Metasys system requirement. Output point name.
Object Type	BACnet requirement. The object type class. Set to SECURITY BO CLASS (324).
Out of Service	BACnet requirement. Indicates if the physical output that the object represents is not in service.
Parent Terminal	P2000 requirement. Name of terminal to which this output is attached.
Partition	P2000 requirement. The partition that owns this output.
PMI Refresh	Metasys system requirement.
Point Number	P2000 requirement. The configured point number.
Polarity	BACnet requirement. Indicates the relationship between the physical state of the output and the logical state represented by Present Value. If the Polarity attribute is Normal, then the Active state of the Present Value attribute is also the Active or On state of the physical output. If the Polarity attribute is Reverse, then the Active state of the Present Value attribute is in the Inactive or Off state of the physical output.
Present Value	BACnet requirement. This indicates the logical state of the Binary output. The relationship between Present Value and the state of the output is determined by Polarity.
Present Value Text	P2000 requirement. Text string of Present Value.
Priority Array	BACnet requirement. Not used in this version of P2000.
Public	P2000 requirement. True if this output point visible to other partitions.
Query Filter String	P2000 requirement. From output point configuration.
Reliability	BACnet requirement. Indicates if the Present Value is reliable or not, and why.
Relinquish Default	BACnet requirement. Not used in this version of P2000.
Status Flags	BACnet requirement. Represents four Boolean flags that indicate the general health of an object. Three flags are associated with the values of other attributes of the object. To determine a more complete status of the object, read these flags.
Time Delay	BACnet requirement. Not used in this version of P2000.

NOTIFICATION CLASS OBJECT

The P2000 Notification Class Object is the standard BACnet Notification Class Object. It provides support for holding lists of alarm and event destinations. One Notification Class instance exists for each category of event/alarm in each device.

Event Categories

The P2000 event categories allow for BACnet enrollments for the desired event category. P2000 divides transactions into the event categories shown below:

Category	Sent by these Objects	Events or Alarms
Access Grant	Reader objects	Events
Access Deny	Reader Objects	Events
Audit	Host Device Objects	Events
Card Trace	Reader Objects	Events
Host Event	Host Device Objects	Events
Host Log	Host Device Objects	Events
Input Status	Input Point Objects	Events and Alarms
Output Status	Output Point Objects	Events
Panel Event	Panel Objects	Events (Future Use)
Panel Hardware Status	Panel Objects	Events
Security Logic	Host Device Objects	Events (Future Use)
T&A Access	Reader Objects	Events (Future Use)

Attributes

Attribute Name	Data Type	Flags*	Default Value	Options/Range
Ack Required	Bit String	B		True, True, True if Input Point, otherwise False, False, False
Description	String	W	Null	Not written to by P2000
Device Name	String			
Notification Class	Unsigned	B		
Object Category	Enumeration		Security Category (2)	
Object Identifier	BACnet Object ID	B		Set by the Object Engine
Object Name	String	BC		<event category> Notification
Object Type	Enumeration	B	Notification Class	
PMI Refresh		F		
Priority	Array	B		TBD
Recipient List	List	WB		

*A - Save Attribute when Archived, B - BACnet Required Attribute, C - Configurable, D - Default Attribute, E - Execute on Write, F - Person Machine Interface (PMI), I - Internal Attribute, K - Key Attribute, N - Value Not Required, O - Optional Attribute, Q - Input from Other Objects, R - Association to Reliability, V - Redirect Default Value to Attribute, W - Writeable, Z - Priority on Write

Attribute Definitions

Attribute Name	Definition
Ack Required	BACnet requirement. Conveys three separate flags that represent whether acknowledgement is required in notifications generated for To-Offnormal, To-Fault, and To-Normal event transitions, respectively.
Description	Metasys system requirement. This is a string of printable characters.
Device Name	Metasys system requirement. Name of the device that contains this notification class.
Notification Class	BACnet requirement. Instance number.
Object Category	Metasys system requirement. Always set to SECURITY CATEGORY (2)
Object Identifier	BACnet requirement. A unique numeric code used to identify the object.
Object Name	BACnet requirement. A character string that represents the name of the object.
Object Type	BACnet requirement. A value that indicates membership in a particular object type class.
PMI Refresh	Metasys system requirement.
Priority	BACnet requirement. Convey the priority to be used for event notifications for To-Offnormal, To-Fault, and To-Normal events, respectively. A lower number indicates a higher priority.
Recipient List	BACnet requirement. Conveys a list of one or more recipient destinations to which notifications are sent when event-initiating objects using this class detect the occurrence of an event. The destinations themselves define a structure of parameters.

PRELIMINARY

P2000 SETUP

P2000 requires various configuration steps to get its BACnet Interface functional, which consist of the following:

- Setting BACnet site options (see “Setting Up BACnet Site Options” on page 3-1)
- Enabling the P2000 BACnet Service to automatically start by configuring the Service Startup Configuration (see “Enabling the P2000 BACnet Service to Auto-Start” on page 3-3)
- Adding entries to the External IPs application for all BACnet devices that will communicate with P2000 (see “Setting Up External IPs” on page 3-4)
- Defining one or more panels, terminals, input points, and output points as BACnet objects (see “Configuring Hardware Components for BACnet Interface” on page 3-5)
- Creating optional Action Interlocks (see “Setting Up BACnet Action Interlocks” on page 3-8)

SETTING UP BACNET SITE OPTIONS

BACnet Site options allow you to configure many system wide settings, defining various parameters of the BACnet Interface.

► To edit BACnet Site Parameters:

1. From the System Configuration window, select **Site Parameters** and click **Edit**. The Edit Site Parameters dialog box opens at the General tab.
2. Select the **BACNet** tab.
3. Select the **Enable BACnet Interface** check box.
4. Enter the information in each field according to your system requirements. (See “BACnet Site Field Definitions” on page 3-2 for detailed information.)

Edit Site Parameters

Port Configuration | RMS | EMail | External Event Trigger | MIS | Web Access | XmlRpc
 General | Printing | Panel Types | Facility Code | Retention Policy | Password Policy | BACNet | Download

☒ Enable BACNet Interface

Query String

Host Event Priority

Host Log Priority

Audit Priority

Panel Hardware Priority

Panel Event Priority

Output Point Priority

Access Grant Priority

Access Deny Priority

Card Trace Priority

IP Address

IP Port

Network Address

Internal Address

OK Cancel Apply

5. When you have entered all the information, click **OK**.
6. When the BACnet Service restart message appears, click **OK**.

BACnet Site Field Definitions

<i>Query String</i>	64 character string used to set the Query String attribute for the Host Device Object, Counter Objects, and Notification Class Objects. This value is used in the Metasys M3/M5 Workstation software.
<i>Priority Values</i>	BACnet priority level used when sending the corresponding event or alarm.
<i>IP Address</i>	<p>If the P2000 server has a single network interface card (NIC), you do not need to enter an IP Address in this field (i.e. you may leave the default value of 0.0.0.0).</p> <p>If the P2000 server has more than one NIC, enter the IP Address the P2000 server will use to receive BACnet broadcast messages over the network.</p>
<i>IP Port</i>	This is a BACnet protocol addressing parameter. The default value is 47808. This may need to be changed if your existing BACnet devices use different values.


- Network Address** This is also a BACnet protocol addressing parameter. The default value is 1001. This may need to be changed if your existing BACnet devices use different values.
- Internal Address** This should only need to be changed if there is another P2000 on the same network. If needed, set this value to be unique to every P2000 on the network.

ENABLING THE P2000 BACNET SERVICE TO AUTO-START


By default the P2000 software must be manually configured to automatically start the BACnet Service, which must be running for integration between the P2000 and Metasys systems.

► To configure the P2000 to automatically start the BACnet Service:

1. From the P2000 Main menu, select **Config>System**, or click the wrench icon on the toolbar. Enter your password if prompted. The System Configuration window appears.
2. In the left pane, expand the **Site Parameters** option.
3. Double-click **Service Startup Configuration**. The Edit Service Startup Configuration window appears.
4. On the **P2000 BACnet Service** row, select the **Auto Start** check box.



5. Click **OK**. The P2000 will start the P2000 BACnet Service.
6. To verify the P2000 BACnet Service is currently running, from the menu bar, select **System>Service Control**. Enter your password if prompted.
7. On the Service Control window, verify that the status of the P2000 BACnet Service is *Running*.




- Click **Done** to close the Service Control window.

SETTING UP EXTERNAL IPS

Here you will define a computer or device from which P2000 will accept BACnet messages. You can also define a computer or device from which P2000 will not accept BACnet messages (using the *Allow* option). If P2000 receives a BACnet message from a source that is not configured, P2000 will log an error message and not process the message.

► To set up External IPs:

- From the P2000 Main menu, select **Config>System**, or click the wrench icon on the toolbar. Enter your password if prompted. The System Configuration window appears.
- In the left pane, expand the **Site Parameters** option.
- Select **External IPs** and click **Add**. The External IP Edit dialog box appears.



4. Enter a descriptive **Name** of the external device.
5. Select **IP Address** or **Computer Name**.
6. If you select IP Address, enter the **IP Address** of the computer or device from which to accept messages. Use this option if the device is not a Windows® computer.

If you select Computer Name, enter the Windows **Computer Name** from which to accept messages, or click the **Browse** button [...] to find a computer by name on your network.
7. If you select the **Allow** check box, the P2000 software will allow communication with this device. If you do not select the Allow check box, the P2000 system will deny communication with this device and will not log any error messages for this device.

NOTE

*Since the BACnet protocol includes broadcast messages that are sent to all BACnet devices on the network, the P2000 software may generate a lot of error messages about rejecting messages from unknown BACnet devices. Since these error messages can cause a significant slowdown in the processing of other messages, add these devices as a BACnet device but do **not** select the Allow option.*


8. Select the **Use for BACnet** check box.
9. Select the **BACnet Routed** check box to send certain messages directly to the device instead of broadcasting them. If this check box is not selected, certain messages will be broadcasted between this device and the P2000 server. If this device is connected on the other side of a network router, but the check box is not selected, the device will not see broadcasted messages.
10. Select the **Use for XmlRpc** check box if this device uses the XmlRpc protocol.
11. Click **OK** to save the settings and return to the System Configuration window.

CONFIGURING HARDWARE COMPONENTS FOR BACNET INTERFACE

When configuring Panels, Terminals, Input Points, and Output Points, described in “Chapter 2: Configuring the System” of the *P2000 Software User Manual*, you may enter a Query String value, which is a 64-character text field used in the *QueryFilterString* property of Event Notification messages.


► **To define a panel, terminal, input point, and output point as a BACnet object:**

1. Select **Config>System** from the P2000 menu bar, or click the wrench icon on the toolbar. Enter your password if prompted. The System Configuration window appears.
2. Select a panel to configure for BACnet from the **Panels** directory.



3. Click **Edit**. The Edit Panel window appears.
4. Select one or more check boxes in the BACnet Interface area to define the panel, terminals, input points and/or output points as BACnet objects.

The BACnet Interface area only appears after you select the **Enable BACnet Interface** check box on the Site Parameters window (BACnet tab).




5. Click **OK**.

- Repeat steps 2 through 5 for each panel and its associated terminals, input points and output points you wish to configure for BACnet.


BACnet Panel Devices

Prior to P2000 version 3.0, the number of connected panels enabled for BACnet use was restricted. This restriction has been removed in P2000 version 3.0 and higher by placing all panel-related objects under a single P2000 device. There are no longer BACnet panel devices. All panels, terminals, input points and output points are BACnet objects and contribute to the 7200 BACnet object limit enforced by the P2000.

Panel Device
(P2000 version
2.5 and earlier)



Panel Object
(P2000 version 3.0
and higher)



Care should be exercised to keep the number of BACnet objects reasonably low, otherwise system performance can be adversely affected. Enabling one item can account for multiple BACnet objects. For example, if the **Enable Terminals** check box is enabled, all the terminals and all the BACnet objects associated with each terminal will be enabled, contributing to the total number of BACnet objects.

NOTE


When upgrading from a version below 3.0 of the P2000 software, all panels, terminals, input points and output points will be enabled for those panels that were enabled in the previous version. If you wish to disable any terminals, input points or output points for specific panels, you will have to manually disable them using the Edit Panel dialog.

SETTING UP BACNET ACTION INTERLOCKS

You must define Action Interlocks for P2000 to initiate actions in BACnet devices. Here you define the BACnet Object and properties that will be written to it by an Action Interlock. A typical use of an Action Interlock includes turning on lights and air conditioning in a cardholder's office when granted access at a door.

► **To set up BACnet Action Interlocks:**

1. From the P2000 Main menu, select **Config>System**, or click the wrench icon on the toolbar. Enter your password if prompted. The System Configuration window appears.
2. In the left pane, select **BACnet Action Interlocks** and click **Add**. The BACnet Action Interlock Edit dialog box appears.



3. If this is a partitioned system, select the **Partition** that will have access to this action interlock information, and select **Public** if you wish the action interlock to be visible to all partitions.
4. Enter a descriptive **Name** of the BACnet Action Interlock.
5. Enter the **Object Name** of the BACnet Object to write to.
6. Enter the **Property Number** of the BACnet property to write to.

7. In the **Property Type** drop-down list, select the data type of the property.
8. Enter the BACnet **Priority** used when writing the property. If you enter 0, a non-prioritized write will be used.
9. Click **OK** to save the settings and return to the System Configuration window.

Action Interlock Operation

Once you have configured the Action Interlocks, they will be available for assignment to cardholders in the Badge dialog box. The object property defined in the Action Interlock will be written with the value associated with the badge. Each badge can be configured to activate up to two Action Interlocks that will be triggered when that badge is granted access.

► To assign Action Interlocks to a badge:

1. From the P2000 Main menu, select **Access>Cardholder**, or select the badge icon on the toolbar, to display the Cardholder window.
2. Select a cardholder from the Cardholder list.
3. In the Badge Information box at the bottom of the window, select the badge to which you wish to assign Action Interlocks and click the **Edit** button.
4. Select the site name tab that you wish to define and click the **Action Interlocks** tab.

Security Options Access Rights Action Interlocks	
Name	Lights
Value	1
Name	Air Conditioning
Value	5

5. From the **Name** drop-down list, select the first Action Interlock that will be written when this badge is granted access.
6. Enter the **Value** to write to the first Action Interlock when this badge is granted access. This value will be converted into the correct data type to match the Action Interlock configuration.
7. Select the **Name** of the second Action Interlock that will be written when this badge is granted access.
8. Enter the **Value** to write to the second Action Interlock when this badge is granted access. This value will be converted into the correct data type to match the Action Interlock configuration.
9. When all information is entered, click **OK** to return to the Cardholder window.

PRELIMINARY

M3 / M5 SETUP

To enable basic communication between M3/M5 workstations and the P2000 system, configure the M3/M5 according to the instructions in this chapter. Adding P2000 items to M-Graphics screens requires additional time in accordance with how extensively you use M-Graphics.

Perform the steps described in this chapter on every M3/M5 workstation in your system. The configuration requirements consist of the following:

- Router configuration and considerations (see “General Guidelines for Configuring P2000 and Metasys Workstations over Routers” on page 4-2)
- M5 Workstation Configuration considerations (see “M5 Workstation” on page 4-3)
 - Using Site Book (see “Launching the Site Book Application and Adding a Site” on page 4-6)
 - Adding P2000 Objects (see page 4-8)
 - Verification using M-Explorer (see “Verification of Metasys-P2000 Integration Using the Metasys M-Explorer Application” on page 4-10)
 - Verification using M-Alarm (see “Verification of Metasys-P2000 Integration Using the Metasys M-Alarm Application” on page 4-14)
 - Verification using M-Graphic (see “Verification of Metasys-P2000 Integration Using the Metasys M-Graphics Application” on page 4-19)
- Installing the P2000 Product Libraries (see “Prod Lib Installation” on page 4-26)
- Updating the Site database (see page 4-27)
- Changing the M-Explorer configuration so it can properly browse the P2000 BACnet Objects (see “M-Explorer Browse Mode Setup” on page 4-27)
- Notification recipient setup (see page 4-28)
- Changing the M3/M5 security settings (see “Security Settings” on page 4-28)

GENERAL GUIDELINES FOR CONFIGURING P2000 AND METASYS WORKSTATIONS OVER ROUTERS

Use this section as a guide when configuring a Metasys M5 or M3 workstation across a router. It is assumed that you are familiar with the standard installation procedures detailed in the other sections of this manual.

A BBMD (Broadband Management Device) is included within the P2000 software to support an M3 or M5 workstation across a router. Previous versions did not support this configuration and required that an N30 controller (or other device) serve as the BBMD device.

As BACnet is a non-routable protocol, special consideration must be given to specific requirements relating to the P2000, the router, and the Metasys workstation.

Figure 4-1 illustrates an M5/M3 workstation configured to operate with a P2000 Security Management System across a router. CK721-A panels used to monitor alarm and control entry points are connected to the P2000 server. Alarms, valid card reads, output point (relays) status, etc., are sent to the Metasys workstation where the changes in the attributes of the P2000 Objects are detected.




Figure 4-1: Metasys Workstations Configured Over Router

Prior to loading the Metasys M5 or M3 workstation software, the basic network operation between systems must be verified. Make sure that both systems can ping one another by IP address across the router. Once this level of operation is established, the M5 or M3 software may be loaded per the associated Metasys installation documentation.

Configuration Considerations

This section describes the considerations for configuring the M5 Workstation, the router and the P2000 Server.


M5 Workstation

- If the network used does not support name resolution, an alternate method to resolve computer names, by the use of aliases, must be used (such as the Lmhosts file).
- After installing the M3 or M5 workstation, you must change the M-Explorer configuration so it can properly browse the PEGASYS BACnet objects. For more information, see “M-Explorer Browse Mode Setup” on page 4-27.
- Product Libraries must be loaded into the M5 workstation. The P2000 Product Libraries may be found in the P2000 Installation CD (see “Prod Lib Installation” on page 4-26).

NOTE


For installations where the number of panels exceeds 64, re-install the Product Libraries using the P2000 Installation CD (version 3.10 or higher) in each M3/M5 workstation to ensure proper system functionality.

- Using the **SHOP** button in Site Book, define the P2000 Server IP address situated across the router. For specifics on Site Book configuration relative to the P2000, refer to “Verification of Metasys-P2000 Integration Using the Metasys Site Book Application” on page 4-5.



The previous screen capture illustrates the initial screen that appears when Site Book is launched.


The **Advanced** button, when selected, augments the screen with additional information. The enhanced display includes the **SHOP** button, as shown in the following screen capture.



On the enhanced page, the **Advanced** button caption changes to **Basic**.

- When you click the **SHOP** button, the following window appears.

Add the IP address of the P2000 Server and deselect the **Broadcast** selection. Once complete, save and exit the window.




Router

- The router must be configured *not* to filter out User Datagram Protocol (UDP). In cases where UDP filtering is required, the router must be configured *not* to filter out UDP specifically on port 47808.

P2000 Server

- When configuring the External IPs at the P2000 Server on the External IP Edit window (see page 3-4), you may define the Metasys workstation by IP address or computer name. If the Metasys workstation is located across a router, you must define it by IP Address as depicted in the following screen capture (there is no name resolution across the router). Verify the **Use for BACnet** and **BACnet Routed** check boxes are selected.



VERIFICATION OF METASYS-P2000 INTEGRATION USING THE METASYS SITE BOOK APPLICATION

Use this section as a guide to verify the operation of the Metasys-P2000 interface with the M5 Site Book application. (See “Updating Site Database” on page 4-27 for details.) It is assumed that you are familiar with the standard installation procedures detailed in the other sections of this manual.

The purpose of using the Site Book application is to allow the registration of P2000 Objects in the Metasys M5 system. Successful operation of the P2000 system with respect to Site Book can be confirmed by the completion of the following sequence:

- Addition of a Site to the Site Book database
- Successful browsing of a site
- Successful addition of P2000 Objects into the Site Book database
- Displaying the P2000 Objects in the Site Book database

Prior to the starting the procedure, confirm that both the P2000 Server and the M5 workstation can communicate to one another over the network. Verify also that you can ping the M3/M5 workstation from the P2000 server by name, and that you can also ping the P2000 server from the M3/M5 workstation by name.

NOTE


If the systems are separated by a router, you cannot ping by name.

Before continuing, make sure you are familiar with the section “General Guidelines for Configuring P2000 and Metasys Workstations over Routers” on page 4-2.


Launching the Site Book Application and Adding a Site

➤ **To launch the Site Book application and add a site:**

1. At the M5 workstation go to **Start>Programs>Johnson Controls¹>BACnet OPC>Sitebook**. The Site Book window appears.




2. Click **Add**.
3. Choose a connection type according to your installation and click **OK**.



1. Directory name is user-definable and may vary.


4. Enter the name of the site and click **OK**. This is the only entry required. The Network Number and BACnet IP port are given values.



The dialog box titled "Ethernet Connection Information" contains three input fields: "Site Name" with the value "Corporate Office", "Network Number" with the value "1001", and "BACnet IP Port" with the value "47808". Below these fields is a note: "Note: Network Number and BACnet IP Port must be configured to be the same as the device". At the bottom are "OK" and "Cancel" buttons.

Browsing the Site

Once you enter the name of the site, it appears on the listing. To browse the site, click **Browse Site DataBase** on the Site Book dialog followed by the **Browse Devices** button. The screen will update as shown in the following screen capture.



The "BACnet Object Finder" dialog box shows a tree view on the left with "Corporate Office" selected. The right pane displays a table of attributes and values for the selected site.

Attribute	Value
System	BACnet
Connection	Ethernet
Network Number	1001
DataBase Path	C:\Documents and Settings\All Users\Ap
Site Description	
Workstation Name	CBAUERMAN5WKSXP
Workstation Number	1
Connection Control	System
Dormant Rate	0
Dormant Cycle	0
Segment Timer Length (...)	4000
Request Timer Length (...)	6000
Number Of Retries	4

At the bottom of the dialog are buttons: "Find Devices", "Browse Devices", "Select Devices", "Add Device", "View Log", "Help", and "Quit".

Adding P2000 Objects

NOTE


Each added P2000 Object must exactly match the way in which it was defined in the P2000 Server. This includes letter case, spaces, etc. Failure to enter the names correctly will result in the Site Book not finding the added object. The following examples illustrate how to add a Host Object.

Adding a Host Object

Before performing the following steps, check how the name was defined at the server in order to enter it correctly. From the P2000 Server, right-click on **My Computer**, select **Properties** and then the **Computer Name** tab. The full computer name appears.


► To add a Host Object:

1. On the BACnet Object Finder window, click the **Add Device** button.
2. In the **Enter Name** field, enter the name of the P2000 Host object. It must match the name of the P2000 Server *exactly as it is defined at the server*.
3. After the correct server name has been entered, type PEGASYS in upper case letters. The two entries **must** be separated by a space.



4. Click **OK**.

The newly defined host object appears in the BACNet Object Finder window.




Displaying the P2000 Objects in the Site Book Database

As a final step in confirming the P2000 – Site Book operation, observe the P2000 Objects in the Site Book database.

1. Select one of the added P2000 Host Objects (in our example it is the *cbauermapi3 PEGASYS* Host Object).
2. Click the **Browse Device** button. As Site Book is browsing for the device, the elongated field above the Help button quickly displays the names of each associated object detected.

- Upon completion of the browse operation, click on the + to expand the Host Object. All of the related objects should now be visible as shown in the following screen capture.



- Select any of the displayed objects to see the associated values.

VERIFICATION OF METASYS-P2000 INTEGRATION USING THE METASYS M-EXPLORER APPLICATION

After you have defined the P2000 host using the Site Book application, you can view P2000 Objects and their associated attributes using M-Explorer.

Before continuing, perform the instructions in the following sections if you have not done so already:

- “Prod Lib Installation” on page 4-26
- “Updating Site Database” on page 4-27
- “M-Explorer Browse Mode Setup” on page 4-27

Verifying the operation of the P2000 Interface with M-Explorer requires the following operations:


- Confirmation that the site entered in Site Book appears on the M-Explorer tree.
- Confirmation of the presence of P2000 Objects under the site name.
- Verification of the ability to browse a P2000 Object and view its attributes.
- Verification that any change in a state of an attribute belonging to a P2000 Object can be detected and viewed in M-Explorer.

NOTE


The following information relates to the M5 software. Instructions on the M3 software may differ.

Confirming the Entry of a Site**► To confirm the entry of a site:**

1. Go to **Start>Programs>Johnson Controls¹>M-Explorer**. The M-Explorer window appears.



2. Select the **JC.BNOC** entry in the left pane. The screen will refresh, and after a few seconds, the site will be listed on the screen as shown below.




1. Directory name is user-definable and may vary.

Confirmation of P2000 Objects Within a Site


► To confirm P2000 objects within a site:

1. Click on the icon corresponding to the site (in the following example, the **Corporate Office** icon). The status of the site appears.



Note that the **Status** of the site is *Normal* and that the **Present Value** is *Connected*. The screen also displays other elements of the site such as the Host Object (*cbauermac3 PEGASYS* in the example). Observe that all items listed return either *Normal* or *Good* status.

2. Expand the icon corresponding to the site (in the example below, the **Corporate Office** icon). The individual listings for the Host Object defined under the Site Book application appear.




Viewing P2000 Object Attributes

Clicking on a Host Object displays a list of all the various related objects.

In the following example, the name of the Host Object is *cbauermapi3 PEGASYS*. Click on the Host Object icon to display other objects related to the host along with their associated attributes.

In a properly operating system, all of the objects related to a Host Object display a status that is *Normal* or *Good*. In addition, a value of each item is listed. Input point objects have a value of *Quiet* when in a secured state. When the input point becomes active, the value will change to *Alarm*. In the case of a Reader Object, the value of a locked door is a *1*. This changes to *2* when the door is unlocked. Note that doors are labeled as *Reader*.



Label	Status	Value	Name	Descriptio
1st Floor	Normal	Alarm	JC.BNOPI\@Corporate O...	
2nd Floor	Normal	Alarm	JC.BNOPI\@Corporate O...	
Audit Log Notify cba...	Normal	-----	JC.BNOPI\@Corporate O...	
Deny Notify 1st Floor	Normal	-----	JC.BNOPI\@Corporate O...	
Deny Notify 2nd Floor	Normal	-----	JC.BNOPI\@Corporate O...	
Deny Notify Lobby	Normal	-----	JC.BNOPI\@Corporate O...	
Event Notify 1st Floor	Normal	-----	JC.BNOPI\@Corporate O...	
Event Notify 2nd Floor	Normal	-----	JC.BNOPI\@Corporate O...	
Event Notify Lobby	Normal	-----	JC.BNOPI\@Corporate O...	
Grant Notify 1st Floor	Normal	-----	JC.BNOPI\@Corporate O...	
Grant Notify 2nd Floor	Normal	-----	JC.BNOPI\@Corporate O...	
Grant Notify Lobby	Normal	-----	JC.BNOPI\@Corporate O...	
Hdw Notify 1st Floor	Normal	-----	JC.BNOPI\@Corporate O...	
Hdw Notify 2nd Floor	Normal	-----	JC.BNOPI\@Corporate O...	
Hdw Notify Lobby	Normal	-----	JC.BNOPI\@Corporate O...	

Confirming Change of States in Input and Reader Attributes

To confirm the operation of the P2000-Metasys interface, monitor the M3 or M5 screen and verify any change to the value of an input point, reader, or output point. Below is the most common method of confirming a reader status:

1. Select a reader currently in the secured mode from the list.
2. From the P2000 Main menu, go to **Control>Door Control** and manually unlock the selected door for the reader.
3. Verify that when the door is unlocked (either manually, by a card read, or by activation of an egress button), the value changes from *1* to *2*.

This process can also be used to confirm operation of a particular output point. In the case of an output point, the value will change from *0* (reset state) to *1* (set state).

To confirm operation of an input point, monitor the value of a selected input point, then force the input point into an alarm condition. The value of the monitored input point should change from *Quiet* to *Alarm*.

See “Object Reference” on page 2-1 for a comprehensive listing of all P2000 Objects and their attributes.

VERIFICATION OF METASYS-P2000 INTEGRATION USING THE METASYS M-ALARM APPLICATION

After you have confirmed the P2000 Host objects using the M-Explorer application, alarms generated by supported security panels (see page 1-1), including acknowledgments, can be routed to the M5 workstation and displayed using the M-Alarm application.

Please follow the instructions in “Notification Recipient Setup” on page 4-28. Failure to set up the Notification Recipients, which is performed using M-Explorer, results in the inability of the M5 workstation to detect alarms.

To verify the operation of the P2000 Interface with M-Alarm, perform and observe the following operations:


- Confirm that an alarm generated at a security controller can be detected at the M5 workstation.
- Confirm that an active P2000 alarm can be acknowledged from the M5 workstation. In addition, the acknowledgement of an alarm at the M5 also acknowledges and silences the audible beep at the P2000 server.
- Confirm that returning an active alarm to a secured state is detected and displayed at the M5 workstation.

Configuring M5 Workstation and P2000 Object Subscriptions


Upon completion of the M5 software installation, the M5 Screen Manager appears on the desktop.

➤ To configure M5 workstation and P2000 object subscriptions:


1. To begin configuring the subscriptions, right-click on the **Alarm Indicator** icon and select **Properties**.




The following window opens:




2. Select the **Subscription** tab.




3. Click **Add**.
4. Enter a name for the new subscription and press <Enter> on your keyboard.
5. Select the new subscription and click **Edit**. The Event Subscription dialog box appears.




6. On the **Server** tab, in the **Node** field, click **Browse**.
7. In the left pane, expand **My Computer**. Under Alarm & Event, select **JC.BNOPCEvent.2**.



8. Click **OK**. The Event Subscription dialog box appears.




9. Select the **Categories** tab.



Listed on this tab are all of the available message items that can be subscribed to report to the M5 workstation. Subscribe all of the P2000-related items by selecting them individually and clicking the **Add** button. Selected items appear on the **Subscribed** pane.

10. When you complete the subscription procedure, click **OK** to store your selections.
11. To launch the M-Alarm Viewer, go to **Start>Programs>Johnson Controls>M-Alarm>Viewer**.
12. In the M-Alarm Viewer window, from the menu bar, select **File>Open**.
13. On the Open dialog box, locate and select the **Alarm and Event mapping.a32** file.



14. Click **Open**.
15. From the menu bar, select **Actions>Runtime Mode**.

The screen appears as depicted below. The Runtime mode may also be activated by pressing the <Ctrl>+<U> keys on your keyboard.


Event Type	Event Category	Time / Date	Tag	Priority	Quality	Description	Attribute 1	Attribute 2	Attribute 3	Attribute 4	Attribute 5	Attribute 6
OPC SIMPLE E Audit Message		1:31:31 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:30 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:30 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:28 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:27 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:27 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:26 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:26 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:24 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:23 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:23 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:22 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:22 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:22 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:22 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:22 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:22 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:22 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:21 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				
OPC SIMPLE E Audit Message		1:31:21 PM 4/ @Corporate		800		Logon Invalid	BAcnet	159.222.10				

- Once you enable the Runtime mode, the system can accept alarms from the P2000 system. Select an input point that was defined in the P2000 database and manually cause it to go into an alarm state. Upon detection, the P2000 system will display the active alarm in the Alarm Monitor screen.

Event Type	Event Category	Time / Date	Tag	Priority	Quality	Description	Attribute 1
OPC SIMPLE E Host Log Message		1:46:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC CONDITI Security Alarm		1:46:05 PM 4/27/2009	@QALABmo	1000	Good - Non-S	CK721AP210 T15 R, CK721AP210 T15, CK721AP210	Alarm
OPC SIMPLE E Host Log Message		1:45:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:44:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:43:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:42:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:41:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:40:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:39:41 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:38:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:37:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:36:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:35:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:34:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:33:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:32:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:31:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:30:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:29:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:28:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:27:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:26:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:25:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:24:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:23:41 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:22:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:21:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:20:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:19:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:18:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:17:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:16:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	
OPC SIMPLE E Host Log Message		1:15:40 PM 4/27/2009	@QALABmo	1000		S321PInterface ERROR Error transmitting to http://10.41.226.140/JUC	

At the same time, (there may be a slight delay of a few seconds, due to network traffic) the alarm will appear on M-Alarm screen and alternately flash between red and yellow. There will also be an audible tone.

17. To acknowledge the alarm from the M5 workstation, right-click on the alarm being displayed and observe that the following dialog box appears.



18. Select the **Point** radio button and click **OK**.

Immediately upon making the selection, the displayed alarm will change to a different color as indicated in the following table. In addition, *BACnet Event Type* will change to *Input Secure* and the audible tone will be silenced. Immediately upon the acknowledgment of the alarm, at the M5, the audible tone at the P2000 will also be silenced and its alarm monitor screen will reflect the change of the alarm's state.

Alarm/Acknowledge State	Definition	Bacnet Event Type Display
Alarm Active	Alternate Red/Yellow	Input Set
Alarm Acknowledged but Unsecured	Green	Input Set
Alarm Secured but not Acknowledged	Alternate Red/Yellow	Input Secure
Alarm Secured	No Display	No Display

19. Complete the confirmation of the Metasys – P2000 Interface and M-Alarm by testing a number of input points in this manner.

VERIFICATION OF METASYS-P2000 INTEGRATION USING THE METASYS M-Graphics APPLICATION


M-Graphics is an optional application that provides you with the tools to develop your own graphics display. Use this section as a guide to verify the operation of the Metasys-P2000 Interface with the M-Graphics application. Before continuing, verify that you have implemented the installation information from pages 4-5 through 4-14 of this manual.

Verification of the Metasys-P2000 Interface relative to M-Graphics requires that the icon be added to the graphics editor. The icon is then linked to a P2000 Object using the Property Inspector tool within the M-Graphics application. Finally, the graphics editor is put into *Runtime* mode, during which the value of the P2000 Object (a door or input point for the purpose of this example) will display the current status. When the status of the object is altered, its displayed value will change on the graphics screen. In addition, the capability of the M-Graphics to send commands to the P2000 Server should also be tested. This may be

confirmed by performing a simple operation, such as unlocking a door that has been defined in the P2000 database using a graphic icon at the M5 workstation.

Verification Procedure


1. From the Windows taskbar, select **Start>Programs>Johnson Controls¹>M-Graphics** to launch the M-Graphics application.
2. To add an icon, click the **Process Point** icon, located in the lower toolbar. The icon appears as **686** encased in a box.




3. Upon selection, place the mouse cursor anywhere in the blank graphic editor area and left-click the mouse.

1. Directory name is user-definable and may vary.

The Property Inspector dialog box appears.




4. Click the **OPC Tags** button.
5. Expand each of the following from the tree:
 - Network Neighborhood
 - Microsoft Windows Network
 - Workgroup Name (as defined in the Network Configuration)
 - The M5 (or M3) workstation (as it is named)
 - Data Access
 - JC.BNOC.2
 - Site (The name of the site as defined in Site Book)
 - Host



In the following example, a Reader Object will be used to illustrate the operation. Select one of the readers from the list of objects (be careful not to confuse Readers with Reader Terminals). Readers are displayed in the listing as *Reader* followed by the name of the reader as defined in the P2000 database. For example, a reader defined as *Front Door* appears in the objects listing as *Reader Front Door*.


6. In the right pane under **Tag Name**, select **Present Value**.

The **Item Id** field at the top of the window displays the path containing the names of the workstation, site, panel, reader and the tag.




7. Click **OK** to return to the Property Inspector dialog box.

8. The Property Inspector also displays the path as mentioned in step 6.



9. Click **OK** to close the Property Inspector dialog box.

Upon closing the Property Inspector dialog box, question marks surrounded by red boxes appear where the cursor was originally placed on the graphics editor screen.



10. From the menu bar, select **Runtime**. All of the surrounding toolbar icons disappear, leaving only a numerical value displayed where the question marks were located. This value represents the current value of the Panel Object. In this example, the object is a Reader, so the value displayed will be *1.00*. This is the value of a locked door.
11. From the P2000 Server's menu bar, select **Control>Door Control**.
12. Manually unlock the selected door for the programmed access time. Each time the door is unlocked from the P2000 (or from a valid card read), the value displayed on the M5 workstation's M-Graphics screen should change from the original *1.00* to *2.00*, then return to *1.00* when the access time expires. Confirm that this change occurs when the door is manually opened.
13. At the M5 workstation, from the menu bar, select **Configure** to stop the *Runtime* mode and return to the *Edit mode*.
14. Continue confirmation of this operation by repeating steps 2 to 13, this time substituting an Input Object in place of a Reader Object. Confirm that the initial secure value changes to the alarm value when the input point goes into an active state, and returns to the original value when the input is secured again. See the following table for the correct reader and Input Point Object values. For a comprehensive listing of all P2000 Object values, see "Object Reference" on page 2-1.


Object	State	Value
Reader	Locked	1.00
	Unlocked (Received from P2000)	2.00
	Unlock for Access Time (Send to P2000)	13.0
Input Point	Secure	0.00
	Active	2.00

Opening a Door Using M-Graphics

The final stage in confirming the operation of the Metasys-P2000 interface with M-Graphics is by unlocking a door from the M5 workstation. This simple procedure uses a variation of the previous steps.

➤ To open a door using M-Graphics:


1. From the lower toolbar in the Metasys graphics editor, click the 'Button' icon.




After selecting this icon, place the mouse cursor anywhere on the graphics editor screen and click the mouse button. The Property Inspector window appears.

2. Select the **Pick** tab.

3. In the **Action** drop-down list, select **Download Value**.



4. Click the **Tags Menu** button to browse for a value for the **Data Source** field. Select **OPC Tags** and, if the tree is not expanded, expand it as described in step 5 on page 4-21.
5. Select one of the readers.
6. In the right pane, select **Present Value** and click **OK**. The **Data Source** field in the Property Inspector window displays the correct path.
7. In the **Value (on up)** field enter 13. This is the attribute value that will be sent to the P2000 Server to unlock the door controlled by the selected reader (see the table on page 4-24).



8. Click **OK** to close the Property Inspector window.
After you close the Property Inspector window, a button labeled **Button** encased in small red boxes appears where the mouse cursor was originally placed.
9. From the menu bars, select **Runtime** to enter the Runtime Mode. The red boxes surrounding the **Button** icon will be replaced by a solid square.
10. Click on the square icon representing the button. The door controlled by the selected reader should unlock for the programmed access time. Confirm that the door has unlocked.

A simple method of confirming this is to monitor the System Status window of the P2000 Server. Open the Reader Terminal Status screen and observe that the correct reader icon changes states each time the **Button** is clicked at the M5 workstation.
11. Stop the Runtime mode by clicking **Configure** in the top toolbar, and exit the graphics editor.

PROD LIB INSTALLATION

The P2000 Product Libraries (Prod Libs) provide M3/M5 workstations with the details of the various BACnet Objects in P2000. To install the P2000 Product Libraries, run the **Prod Lib Setup** program contained on the P2000 installation CD (in the **ProdLibs** subdirectory).

UPDATING SITE DATABASE

The P2000 BACnet Device Objects must be added to the M3/M5 workstation site database. Perform the following steps using the M3/M5 Site Book:

NOTE

All names entered in Site Book must be exact, including capitalization or BACnet communication will fail.

➤ **To add a new site entry or use an existing site entry if a valid one exists:**


1. Select the desired site entry and click **Browse Site DataBase**.
2. Select the desired site and click **Add Device** to add the P2000 Host Device.
3. In the **Enter Name** field, enter <computer name> PEGASYS, substituting <computer name> with the name of the P2000 server.
For example: *cbauermapi3 PEGASYS*
In the previous example, **cbauermapi3** is the computer name of the P2000 server.
4. Click **OK**.
5. In the left pane, select the newly added site entry and click **Browse Devices**.
This will add all notification, counter, panel, terminal, input and output objects contained in the Host Device to the site database. When browsing is complete, Sitebook should display no errors found.

M-EXPLORER BROWSE MODE SETUP

Change the M-Explorer configuration so it can properly browse the P2000 BACnet Objects.

➤ **To change the M-Explorer configuration:**

1. From the M3/M5 workstation, open Windows Explorer.
2. Navigate to the following directory:
Local Disk:\Program Files\Johnson Controls\M-Explorer
3. Locate the **jc.bnopc.pcf** file and open it in Notepad or another text editor.
4. Change the BrowseSystem setting to **OPC_BROWSE** (the default value is **NOAH_BROWSE**).



```
jc.bnopc.pcf - Notepad
File Edit Format View Help
; used to define the leaf item names for the branch summary displays
Type = #79
JCITYpe = #797
StatusText = #512
StatusNumber = #512
Value = #85
Description = #28
LeafSeparator = .
BranchSeparator = :
LeafFilter = TRUE
; use this variable to set the time out value for ;removeGroup call of op
; Default value is 10 second
OPCTimeoutvalue = 10000

; the following switch will allow NOAH_BROWSE vs. OPC_BROWSE (def.)
BrowseSystem = OPC_BROWSE

; the following are used to defined the threshold value of StatusNumber f
; each bound includes the defined boundary - numbers below warningBound
warningBound = 10
AlarmBound = 30
unknownBound = 70
CommProblemBound = 100
```

5. Save the file.

NOTIFICATION RECIPIENT SETUP

In order for a M3/M5 workstation to receive event and alarm messages from P2000, the M3/M5 must add itself to the recipient list for every event category on each device from which you want to receive messages.

Using M-Explorer, find the Notification Class Object for the type of event/alarm message you want to receive. Tell M-Explorer to **Inspect** that object. From the command list, select the **Add Recipient** command. Fill in data values as appropriate and press the **Execute** button.

SECURITY SETTINGS

The default setting of M-Alarm is to allow anyone to acknowledge alarms whether or not they are logged on. We recommend changing the M3/M5 security settings so only users who are logged on can acknowledge alarms. See the M3/M5 documentation for details on changing this setting.

M-Graphics

The use of P2000 BACnet Objects in M-Graphics can vary from simple to very complex, depending upon your needs and system layout. Consult the M3/M5 documentation for details on the use of M-Graphics.

To help get you started, the following sections address the most common items that need to be displayed in M-Graphics. For more information, see “Verification of Metasys-P2000 Integration Using the Metasys M-Graphics Application” on page 4-19.

Door Status

Use the following attributes from the appropriate Reader Object:

Object Name	name of door
Present Value	1 = Locked, 2 = Unlocked
Present Value Text	“Locked Closed” or “Unlocked Closed”

If Forced Door/Propped Door soft alarms are turned on in P2000 and you want to display them on your graphic, use the following attributes from the appropriate Input Object:

Present Value	0 = Quiet, 2 = Alarm
---------------	----------------------

NOTE

For more information on soft alarms, refer to the P2000 Software User Manual, under “Configure Soft Alarms.”

Controlling Doors

I Write the following values to the Present Value attribute in the **Mode Request** field for the appropriate Reader Object:

11	Cancel override and return to normal operation
12	Override (unlock) door for its programmed access time
13	Override door for the number of minutes specified in the Unlock Time attribute.

Input Point Status

Use the following attributes from the appropriate Input Object:

Object Name	name of input point
Present Value	0 = Quiet, 2 = Alarm, 3 = Fault
Present Value Text	“Quiet”, “Alarm” or “Fault”

Output Point Status

Use the following attributes from the appropriate Output Object:

Object Name	name of output point
Present Value	0 = inactive, 1 = active
Present Value Text	“Inactive” or “Active”

Controlling Output Points

Write the following values to the Present Value attribute for the appropriate Output Object.

0	Set Inactive
1	Set Active

PRELIMINARY

TROUBLESHOOTING

DUPLICATE OBJECT NAME ERRORS

P2000 may report errors about Duplicate Object Names when *BACnet Service* starts. The error message will include the name of the object that caused the error. This type of error is caused when the name of one object is the same as another object. All terminals, input points, and output points must have unique names.

To correct the error, rename the object specified in the error message.

MSG REJECTED ERRORS

P2000 reports a Msg Rejected error whenever BACnet receives a message from an IP Address that does not correspond to a configured BACnet Source. The error message contains the IP Address of the device that sent the message.

To correct the error, add a BACnet Source for the IP Address specified in the error message. If this device has no reason to communicate with the P2000 BACnet Interface, clear the **Allow** check box on the External IP Edit dialog box (see “Setting Up External IPs” on page 3-4).

ACTION INTERLOCK ERRORS

When you use Action Interlocks, you may see one of the following error messages:

- ActionInterlock OpenConnection error
- WriteAttributeWait error
- Error writing object

All these errors indicate a failure to write to the object defined in the Action Interlock dialog box. Most likely, the problem is due to incorrect values in the Action Interlock definition. Verify the Object Name, Property Number, and Property Type in the Action Interlock dialog box in the P2000 System. Note that the Object Name must match exactly the name of the object, including the case.

If the Action Interlock is defined correctly, then there is a BACnet communication problem between the P2000 Server and the device containing the object. Verify basic network connectivity using the “ping” command on the P2000 Server to ping the IP address of the device. If you are unable to ping the device, then most likely there is a routing problem that is blocking the BACnet broadcast messages between the device and the P2000 Server. Refer to the BACnet Communication Troubleshooting section of your M3/M5 documentation.

PRELIMINARY