

NAME OF THE CONTRACTOR: M/s. U.K. ENTERPRISE
NAME OF THE PROJECT: Bongaigaon Medical College
NAME OF THE CLIENT: Assam Power Distribution Company Limited
LOA NO.: CGM(D&M)/APDCLAR/Bongaigaon Medical College/2025-26/38 Dt. 13.05.26
NAME OF THE MANUFACTURER: HAVELLS INDIA LIMITED
CABLE DETAILS: 1X241 AAC MCVC
VOLTAGE GRADE 33KV



HAVELLS INDIA LTD. (CABLE DIVISION) - ALWAR

Technical Particulars

Our Ref. No. HIL/GTP/YY/2025, Dated -29.06.2026

		AAC COVERED CONDUCTOR	
S.N	Descriptions	Unit	241 SQ. MM
1	Name of Manufacturer.		HAVELLS INDIA LIMITED
2	Applicable Standard to which cable conforms		GENERALLY CONFORMING TO IS -388 PT-IV / EN 50397-1
3	Type of cable		AAC COVERED CONDUCTOR
4	Voltage Grade	KV	33
5	Phase Conductor detail		
	~ Conductor material		AAC CONDUCTOR as per IS : 336-IV
	~ Nominal cross-sectional Area	mm ²	241
	~ Number of strands / Nom. dia of strands	No.	19/4.02
	~ Form of conductor	mm	Stranded Non-Compacted circular
	~ Breaking Load of conductor	kN	70.61
	~ Longitudinal Water Blocking		Yes
6	Screening on Conductor :		Suitable extruded Water Blocking layer shall be provided over central strand & in between layers of conductor
	~ Type & Material.		Semiconducting Compound by extrusion
	~ Approx. Thickness of semiconducting part	mm	0.30
7	Insulation :		
	~ Material.		XLPE
	~ Nominal thickness	mm	2.43
	~ Colour		Natural
8	Outer covering :-		
	~ Material.		(Track Resistant , Erosion resistant & UV Resistant)
	~ Nominal thickness	mm	1.20
	~ Colour		BLACK
9	Standard drum length	Mtrs.	1000 ± 5%
10	Non Standard Drum length	%	Max. 5% of ordered quantity
11	Allowable max. cond. Temp. when carrying cont. rated current (Temp. at which water blocking material shall remain stable)	Deg. C	90
12	Allowable max. cond. Temp. at the time of short circuit (Temp. at which water blocking material shall remain stable)	Deg. C	250
13	Short Circuit current rating for 1 Sec. duration	K.A.MPS	23.62
14	Conductor DC Resistance at 20°C. (Max.)	Ohms/km	0.143
15	Over all diameter (mm) (Approx)		30
16	Weight (Kg/Km)(Approx)		1020
17	Max load(IEC 61537), cond.temp 90 °C, air temp. 40 °C, wind speed 0.5 m/s, Solar radiation 1045W/m ² ,Approximate value (continuous):	Amp	495
18	Marking detail (Embossing/printing)		HAVELLS 33 KV XLPE AAC COVERED CONDUCTOR (SIZE IN SQMM) - (MFG. YEAR) , AS PER EN 50397-1 IN GENERAL
19	SEQUENTIAL LENGTH MARKING		SHALL BE PROVIDE BY PRINTING AT EVERY MTR OF CABLE
20	Insulation Resistance (Volume resistivity)(Min)		
	at 27 Deg.C	Ohms - cm	1 X 10 ¹⁴
	at 90 Deg. C	Ohms - cm	1 X 10 ¹²
21	Lightning impulse Withstand Voltage	kV	100
22	Design Life		We confirm use of cables for 25 years under Stipulated functional conditions & use of cables as per relevant IS: 1255 wherever applicable.
23	Packing material		Non Returnable wooden drums

* Values indicated as " Approx. " are for guidelines only

* In case of any Typographical Error / Discrepancy , relevant standards shall be prevailed.

CLASSIFICATION | PUBLIC

Yours Faithfully,

For Havells India Ltd
Angkit Boruah,
Manager- Cables.
Email: Angkit.boruah@havells.com
Phone no: 7002287818.