



ASSAM POWER DISTRIBUTION COMPANY LIMITED.
OFFICE OF THE CHIEF GENERAL MANAGER (D & S),
(LOWER ASSAM REGION)
CIN: U40109AS2003SGC007242

No. CGM(D&S)/APDCL/LAR/GTP Appro/Pt-2/2023/ 126

Date: 24-08-2026

To,

M/s U.K. Enterprise,
R.P. Road, Dispur

Sub: **Approval of GTP and drawings.**

Ref: 1. Letter received from the CGM (PP&D) vide No. CGM(PP&D)/APDCL/GTPA/PART-23/2025-26/4855; dated 19.08.2026.
2. LoA No. CGM(D&S)/APDCL/LAR/ Bongaigaon Medical College/2025-26/38, Dtd. 13.05.2026.
3. Your letter vide no. UKE/BMC/2026-27/176A, dated: 05.08.2026

Sir,

With reference to the above subject, this is to inform you that GTP along with drawings of item mentioned below is hereby approved subject to the strict compliance to the highlighted corrections and recommendations of the GTP. All factory accepted tests shall be conducted upon the item and submitted along with supply and verified before installation. The date of manufacturing of the said item should be after the date of issue of this letter.

➤ GTP for the following items have been approved.

Sl. No.	Description of item	Vendor Details	Documents
1	33 KV Isolator without E/S with GI mounting structure	M/S. Ruma Company, 6, Q Road, Howrah-Isolator 711105 (W.B)	GTP & Drawing
2	33 KV Gang switch, 800 Amps		
3	11 KV Gang switch, 400 amps		
4	33 KV CT, 400-200/5-5-5 Amps	M/S. Macroplast	
5	33 KV Poly. Disc insulator, 70 KN T&C	M/S. Jainco Transmission Ltd., Kolkata	
6	GI Stay wire, 7/10 SWG	M/S. Aditya Electricals Howrah-711108	
7	GI Stay wire,7/8 SWG		

However, the GTP and drawings of the following materials have been **not been approved**:

Details of the items are as follows:

Sl. No.	Item Descriptions	Manufacturer	Remark
1	33KV 150A DO Fuse Set	M/S. Ruma Company, 6, Q Road, Howrah-Isolator 711105 (W.B)	Not an APDCL approved vendor for 33KV DO Fuse
2	GI Stay Wire 7/12 SWG	M/S. Aditya Electricals Howrah-711108	Not an APDCL approved vendor for GI Stay Wire 7/12 SWG

- N.B: 1. *It is to be noted that this approval is solely against the furnished GTP of the said material and shall not be treated as approval of vendor under APDCL.*
2. *Tests Certificates are to be submitted along with the supply.*

Encl: - Approved GTPs.

Yours faithfully

Chief General Manager (D&S)
APDCL, LAR

Memo No. CGM(D&S)/APDCL/LAR/GTP Appro/Pt-2/2023/
Copy to:

Date:

- The CGM(PP&D), APDCL, Bijulee Bhawan, Paltanbazar, Ghy-01 for your information.
- The CEO, Bongaigaon-EC, APDCL, LAR for information and necessary action.
- Relevant File

Chief General Manager (D&S)



125^e

অসম শক্তি বিতৰণ কোম্পানী লিমিটেড
ASSAM POWER DISTRIBUTION COMPANY LIMITED
 [CIN / চিআইন- U40109AS2003SGC007242]

No : CGM(PP&D)/APDCL/GTPA/PART-23/2025-26/ 4855

Dated : 19/8/2026

To,

Chief General Manager (LAR)
5th Floor, Bijulee Bhawan
Paltan bazar, Guwahati-1.

Sub: Approval of GTP

Ref: i) Letter No, CGM(D&S)/APDCL/LAR/GTP Appro/Pt-2/2023/124, Dated:11.08.2026

Sir,

With reference to the subject cited above, it is to inform you that the GTP along with drawings submitted from your end vide under Ref: i) have been scrutinized by the technical team of the office of the undersigned and the following items are hereby approved subject to full compliance to the highlighted corrections and recommendations. Details of materials:

Sl No.	Item Description	Manufacture
1	33KV, 800A Isolator without E/S & with GI Mounting Structure ✓	M/S Ruma Isolator Company, Howrah
2	33KV 150A DO Fuse Set ✗	
3	33KV 800A Air Break Switch ✓	
4	11KV 400A 3Ph GOAB Switch ✓	
5	33KV Outdoor CT, 400-200/5-5-5A ✓	Macroplast Pvt Ltd., U.P
6	GI Stay Wire 7/8 SWG ✓	Aditya Electricals, Howrah
7	GI Stay Wire 7/10SWG -	Aditya Electricals, Howrah
8	33KV, 70KN Composite Polymer Disc Insulator ✓	Jainco Transmission Ltd.

The GTPs submitted for the following items could not be processed for the reasons mentioned against each item:

Sl No.	Item Description	Manufacture	Remarks
1	33KV 150A DO Fuse Set	M/S Ruma Isolator Company, Howrah	Not an approved Vendor for 33KV DO Fuse
2	GI Stay Wire 7/12 SWG	Aditya Electricals, Howrah	Not an approved Vendor for GI Stay Wire 7/12 SWG

Moreover, you are also requested to ensure that the approved item supplied strictly comply with the approved GTP & highlighted corrections/recommendations. All factory acceptance tests shall be conducted upon the item. The date of manufacture of the said item shall be later than the date of issue of this letter.

This is for favour of your kind information and necessary action.

Yours sincerely

Chief General Manager (PP&D)



ASSAM POWER DISTRIBUTION COMPANY LIMITED.

OFFICE OF THE CHIEF GENERAL MANAGER (D),
(LOWER ASSAM REGION)

CIN: U40109AS2003SGC007242

No. No. CGM(D&S)/APDCL/LAR/GTP Appro/Pt-2/2023/ **124**

Date: **11-08-2026**

To,

✓ The Chief General Manager (PP&D),
APDCL, Bijulee Bhawan,
Paltan Bazar, Guwahati-1.

Sub: Forwarding of GTP, Drawing.

Ref: 1. Letter received from M/s UK Enterprise, vide letter no. UKE/BMC/2026-27/176A, dated: 05.08.2026

Sir,

With reference to the above subject, enclosed please find herewith a letter have been received from ~~Shri~~ M/s UK Enterprise, vide letter no. UKE/BMC/2026-27/176A, dated: 05.08.2026 regarding submission of GTP and drawings of the following material as per the LoA No. CGM(D&S)/APDCL/LAR/ Bongaigaon Medical College/2025-26/38, Dtd. 13.05.2026 for your information and necessary action.

Details are as follows: -

Sl. No.	Description of item	Vendor Details	Documents
1	33 KV Isolator without E/S with GI mounting structure	M/S. Ruma Company, 6, Q Road, Howrah-Isolator 711105 (W.B)	GTP & Drawing
2	33 KV D.O. Fuse, 150 Amps		
3	33 KV Gang switch, 800 Amps		
4	11 KV Gang switch, 400 amps		
5	33 KV CT, 400-200/5-5-5 Amps	M/S. Macroplast	
6	33 KV Poly. Disc insulator, 70 KN T&C	M/S. Jainco Transmission Ltd., Kolkata	
7	GI Stay wire, 7/10 SWG	M/S. Aditya Electricals Howrah-711108	
8	GI Stay wire, 7/8 SWG		
9	GI Stay wire, 7/12 SWG		

Encl: - As above in original.

Yours faithfully

Chief General Manager (D&S)
APDCL, LAR