



ASSAM POWER DISTRIBUTION COMPANY LIMITED.

OFFICE OF THE CHIEF GENERAL MANAGER (D),
(LOWER ASSAM REGION)

CIN: U40109AS2003SGC007242

No. CGM (D&S)/APDCL/LAR/Bongaigaon Medical College/2025-26/ 82

Date: 26/08/2026

To,

M/s UK Enterprise,
Dr. R.P. Road, Dispur, Guwahati-781006

Sub: Dispatch Clearance

Ref: a) Your letter No. UKE/BMC/2026-27/227. dtd: 19.08.2026
b) LOA No. CGM (D&S)/APDCL/LAR/Bongaigaon Medical College/2025-26/38, dtd. 13.05.2026
c) GTP Approval vide letter no. CGM (D&S)/APDCL/LAR/Bongaigaon Medical College/2025-26/54, dated: 04.06.2026

Dear Sir,

In response to letter under reference (a) above, this is to inform you that the factory inspection of the following materials has been waived with the condition that the materials are to be manufactured as per the approved GTP by the same manufacturer with same specification. Accordingly dispatch clearance is accorded for dispatch of the material.

Details are as follows:

Sl. No.	Description of item	Qty	Manufacturer
1	Mid span Jointing kit for 33KV 241 sq. mm MVCC	125 nos.	Master Electricals Ganesh Complex NH-6, Raghudevapur Howrah-711322
2	Cable Termination kit for 33KV 241sq. mm MVCC	687 nos.	
3	33 KV tension H/W for 241sq. mm	717 nos.	
4	33 KV Tension clamp for 241sq. mm	717 nos.	
5	Cable Tie for 241sq. mm	1775 nos.	
6	33 KV Cable End kit for 1x630 sq. mm	50 nos.	
7	11 KV Cable End kit for 1x630sq. mm	8 nos.	

However, any supplied materials as above, if found damaged within warranty period, the same shall be replaced by the contractor/supplier in free of cost. The manufacturer shall ensure that the above materials to be supplied are as per relevant IS and approved GTP. Before execution of work the quality of materials are to be inspected by field CEO/AGM, T&C Division concerned and submit a report to the undersigned.

Yours faithfully

Chief General Manager (D&S)
APDCL (LAR)

Memo No. CGM (D&S)/APDCL/LAR/Bongaigaon Medical College/2025-26/
Copy to:-

1. The GM (Rev), Bongaigaon Zone, APDCL, LAR, for information.
2. The CEO, Bongaigaon, APDCL, LAR, for information and necessary action.
3. The AGM, T&C Division, Bongaigaon, APDCL, LAR, for information and necessary action.
4. Relevant File

Date:

Chief General Manager (D&S)