OSHA Eyewash Station Checklist (29 CFR 1910.151)

Use during routine site inspections and after any change in chemicals, processes or work areas.

OSHA 29 CFR 1910.151

DATE	SHIFT
INSPECTOR	AREA / EQUIPMENT ID

Before you start

1. Mark every item OK, Defect or N/A, and note the location you checked.
2. For each Defect, record the corrective action, who owns it and the due date, and recheck it once fixed.
3. The equipment manufacturer's instructions and your site rules may add checks to this list.

Legal basis: 29 CFR 1910.151: Medical services and first aid, including non-mandatory Appendix A (First aid kits) Source: eCFR, Title 29, Part 1910 Subpart K Online version and sources: https://safetyindex.blog/us/standards/1910-151-medical-services-first-aid

SECTION A | Eyewash and drench facilities

No.	Check item	What to look for	OK	Defect	N/A	Notes
1	Corrosive exposure areas identified Ref. 1910.151(c)	Each area where eyes or body could contact injurious corrosive materials is listed, and each listed area has a flushing or drenching facility.	☐	☐	☐	
2	Eye flushing provided Ref. 1910.151(c)	A unit that can quickly flush the eyes is installed at each listed area.	☐	☐	☐	
3	Body drenching provided Ref. 1910.151(c)	Where the body (not only the eyes) could be exposed, a unit that can quickly drench the body is installed.	☐	☐	☐	
4	Located within the work area Ref. 1910.151(c)	The unit sits in the same work area as the corrosive hazard, not in another room or building.	☐	☐	☐	
5	Access clear Ref. 1910.151(c)	Nothing blocks the route to the unit or its controls; a person can reach and operate it straight away.	☐	☐	☐	
6	Operates on demand Ref. 1910.151(c)	When activated as the manufacturer describes, the unit delivers flushing fluid at once and without fault.	☐	☐	☐	
7	In service Ref. 1910.151(c)	The unit is connected or filled, its supply is not shut off, and it is not tagged out of service.	☐	☐	☐	
8	Reachable by everyone exposed Ref. 1910.151(c)	Contractors, visitors and other people working near the corrosives can reach and use the unit.	☐	☐	☐	

SECTION B | Medical personnel and first aid responders

No.	Check item	What to look for	OK	Defect	N/A	Notes
9	Medical personnel available Ref. 1910.151(a)	Names and contact details of medical personnel who can advise and consult on plant health are posted or on record.	☐	☐	☐	
10	Nearby treatment facility confirmed Ref. 1910.151(b)	Records show whether an infirmary, clinic or hospital close to the workplace is used to treat all injured employees.	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION B | Medical personnel and first aid responders

No.	Check item	What to look for	OK	Defect	N/A	Notes
11	Trained first aiders Ref. 1910.151(b)	Where no such nearby facility treats every injured employee, one or more named people adequately trained to render first aid are on site, with training records.	☐	☐	☐	

SECTION C | First aid supplies and kits

No.	Check item	What to look for	OK	Defect	N/A	Notes
12	Supplies readily available Ref. 1910.151(b)	First aid kits are in known, unlocked, easy-to-reach locations.	☐	☐	☐	
13	Supplies adequate Ref. 1910.151(b)	Kits are stocked, items are usable, and contents meet the site's assessed needs.	☐	☐	☐	
14	Enough kits for the operation Ref. 1910.151(b)	For larger or multiple operations at one location, the number of kits, types of equipment and quantities have been assessed and provided (Appendix A guidance).	☐	☐	☐	
15	Periodic needs review Ref. 1910.151(b)	A dated review of first aid needs exists, drawing on the OSHA 300 log, OSHA 301 log or other injury reports (Appendix A guidance).	☐	☐	☐	
16	PPE with first aid supplies Ref. 1910.151(b)	Where blood exposure during first aid is reasonably anticipated, gloves and other appropriate PPE such as face shields, masks or eye protection are kept with the kits (Appendix A; 1910.1030(d)(3)).	☐	☐	☐	

DEFECTS FOUND AND ACTION TAKEN

Item no.	Defect description	Reported to	Action taken / date closed

SIGN-OFF

SAFE TO OPERATE? ☐ Yes ☐ No: tagged out of service	
INSPECTOR SIGNATURE	DATE / TIME
SUPERVISOR REVIEW	DATE / TIME