OSHA Rebar Cap Checklist (29 CFR 1926.701)

For site walks during concrete work: rebar guards, loads, the tensioning area, buckets and pneumatic application.

OSHA 29 CFR 1926.701

DATE	SHIFT
INSPECTOR	AREA / EQUIPMENT ID

Before you start

1. Mark every item OK, Defect or N/A.
2. For any Defect, stop the exposed work or keep employees away until it is corrected, then record the fix.
3. Manufacturer's instructions and site rules may add checks to this list.

Legal basis: 29 CFR 1926.701: General requirements (Part 1926 Subpart Q, Concrete and Masonry Construction) Source: eCFR, Title 29, text as of 2026-11-09

Online version and sources: https://safetyindex.blog/us/standards/1926-701-concrete-masonry-construction

SECTION A | Protruding reinforcing steel

No.	Check item	What to look for	OK	Defect	N/A	Notes
1	Rebar employees could fall onto Ref. 1926.701(b)	Every protruding bar end below or beside a work area or walkway is guarded.	☐	☐	☐	
2	Rebar employees could fall into Ref. 1926.701(b)	Protruding bars in openings, forms or excavations are guarded.	☐	☐	☐	
3	Guard condition Ref. 1926.701(b)	Guards are in place, undamaged and cover the bar so a falling worker could not be impaled.	☐	☐	☐	

SECTION B | Construction loads

No.	Check item	What to look for	OK	Defect	N/A	Notes
4	Structural design information Ref. 1926.701(a)	Information from a person qualified in structural design is available for the structure or portion being loaded.	☐	☐	☐	
5	Employer determination Ref. 1926.701(a)	The employer has determined, from that information, that the structure or portion can support the planned loads.	☐	☐	☐	
6	Loads placed Ref. 1926.701(a)	No construction loads sit on any concrete structure or portion that has not been assessed.	☐	☐	☐	

SECTION C | Post-tensioning operations

No.	Check item	What to look for	OK	Defect	N/A	Notes
7	Area behind the jack Ref. 1926.701(c)(1)	During tensioning, only employees essential to the post-tensioning work are behind the jack.	☐	☐	☐	
8	Signs Ref. 1926.701(c)(2)	Signs are erected to limit employee access to the post-tensioning area while tensioning is under way.	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION C | Post-tensioning operations

No.	Check item	What to look for	OK	Defect	N/A	Notes
9	Barriers Ref. 1926.701(c)(2)	Barriers are erected around the post-tensioning area while tensioning is under way.	☐	☐	☐	

SECTION D | Concrete buckets and pneumatic hose application

No.	Check item	What to look for	OK	Defect	N/A	Notes
10	Riding buckets Ref. 1926.701(d)	No employee rides a concrete bucket.	☐	☐	☐	
11	Work under buckets Ref. 1926.701(e)(1)	No employee is under a concrete bucket while it is being elevated or lowered into position.	☐	☐	☐	
12	Bucket route Ref. 1926.701(e)(2)	Elevated buckets follow a route that exposes no employees, or the fewest practical, to a falling bucket.	☐	☐	☐	
13	Head protection at the hose Ref. 1926.701(f)	Each employee applying cement, sand and water mixture through a pneumatic hose wears protective head equipment.	☐	☐	☐	
14	Face protection at the hose Ref. 1926.701(f)	Each employee applying the mixture through a pneumatic hose wears protective face equipment.	☐	☐	☐	

DEFECTS FOUND AND ACTION TAKEN

Item no.	Defect description	Reported to	Action taken / date closed

SIGN-OFF

SAFE TO OPERATE?	☐ Yes ☐ No: tagged out of service	
INSPECTOR SIGNATURE		DATE / TIME
SUPERVISOR REVIEW		DATE / TIME