Hazardous Materials Inspection Checklist: Compressed Gases (29 CFR 1910.101)

For site walk-throughs of areas where compressed gas cylinders and tanks are stored, handled or used.

OSHA 29 CFR 1910.101

DATE	SHIFT
INSPECTOR	AREA / EQUIPMENT ID

Before you start

1. Mark every item OK, Defect or N/A. Use N/A only where that container type or activity is not on site.
2. For any Defect, report it to the person responsible, keep the cylinder or tank out of use until it is corrected, and record what was found, the fix and the date.
3. The gas supplier's and manufacturer's instructions, site rules and the CGA pamphlets named in the standard may add checks not listed here.

Legal basis: 29 CFR 1910.101: Compressed gases (general requirements), Part 1910 Subpart H: Hazardous Materials Source: eCFR, Title 29 (text as of 2026-11-09) CGA Pamphlets C-6-1968, C-8-1962, P-1-1965, S-1.1-1963 and S-1.2-1963 are incorporated by reference through 29 CFR 1910.6 and are not reproduced here.

Online version and sources: https://safetyindex.blog/us/standards/1910-101-compressed-gases

SECTION A | Cylinder inspection

No.	Check item	What to look for	OK	Defect	N/A	Notes
1	Safe-condition check of controlled cylinders Ref. 1910.101(a)	Each cylinder under site control has been visually examined and found to be in a safe condition.	☐	☐	☐	
2	DOT inspection method Ref. 1910.101(a)	Where the DOT Hazardous Materials Regulations apply, cylinder inspections are done as 49 CFR parts 171-179 or 14 CFR part 103 prescribe.	☐	☐	☐	
3	CGA method where DOT does not apply Ref. 1910.101(a)	Cylinders outside the DOT rules are inspected to CGA Pamphlets C-6-1968 and C-8-1962.	☐	☐	☐	

SECTION B | Handling, storage and use

No.	Check item	What to look for	OK	Defect	N/A	Notes
4	Cylinder handling in the plant Ref. 1910.101(b)	Gas cylinders are moved and handled inside the plant in line with CGA Pamphlet P-1-1965.	☐	☐	☐	
5	Cylinder storage Ref. 1910.101(b)	Stored compressed gas cylinders are kept the way P-1-1965 describes.	☐	☐	☐	
6	Use at the point of work Ref. 1910.101(b)	Gas drawn from cylinders is used as P-1-1965 sets out.	☐	☐	☐	
7	Portable tanks, rail tankcars and cargo tanks Ref. 1910.101(b)	Compressed gases in any portable tank, rail tankcar or motor vehicle cargo tank on site are handled, stored and used per P-1-1965.	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION C | Pressure relief devices

No.	Check item	What to look for	OK	Defect	N/A	Notes
8	Relief devices on cylinders Ref. 1910.101(c)	Cylinders have pressure relief devices installed as CGA S-1.1-1963 (with 1965 addenda) and S-1.2-1963 specify.	☐	☐	☐	
9	Relief devices on portable and cargo tanks Ref. 1910.101(c)	Portable tanks and cargo tanks have relief devices installed to S-1.1-1963 and S-1.2-1963.	☐	☐	☐	
10	Relief device maintenance Ref. 1910.101(c)	Relief devices on cylinders and tanks are kept maintained as the same CGA pamphlets specify.	☐	☐	☐	

DEFECTS FOUND AND ACTION TAKEN

Item no.	Defect description	Reported to	Action taken / date closed

SIGN-OFF

SAFE TO OPERATE? ☐ Yes ☐ No: tagged out of service

INSPECTOR SIGNATURE	DATE / TIME
SUPERVISOR REVIEW	DATE / TIME