OSHA Local Exhaust Ventilation Checklist (29 CFR 1910.94)

For site inspections of abrasive blasting, grinding, polishing, buffing and spray finishing areas.

OSHA 29 CFR 1910.94

DATE	SHIFT
INSPECTOR	AREA / EQUIPMENT ID

Before you start

1. Mark every item OK, Defect or N/A; use N/A only for operations the area does not run.
2. For each Defect, record what was found, arrange the repair and recheck the item before the operation resumes.
3. The manufacturer's instructions and site rules may add checks; this list does not replace the full text of 29 CFR 1910.94.

Legal basis: 29 CFR 1910.94: Ventilation (Part 1910 Subpart G, Occupational Health and Environmental Control) Source: eCFR, Title 29, text as of 2026-11-09 Online version and sources: https://safetyindex.blog/us/standards/1910-94-ventilation

SECTION A | Abrasive blasting enclosures and exhaust

No.	Check item	What to look for	OK	Defect	N/A	Notes
1	Inward airflow at openings Ref. 1910.94(a)(3)(i)	During blasting, air is drawn inward at every enclosure opening	☐	☐	☐	
2	Inlets and access openings Ref. 1910.94(a)(3)(i)(a)	Openings are baffled or arranged; no visible spurts of dust escape to adjacent areas	☐	☐	☐	
3	Slit baffles Ref. 1910.94(a)(3)(i)(e)	Multiple sets of slit abrasive-resistant baffles at small access openings, intact and not worn through	☐	☐	☐	
4	Enclosure doors Ref. 1910.94(a)(3)(i)(e)(1)	Doors are flanged and close tightly	☐	☐	☐	
5	Blast room door operation Ref. 1910.94(a)(3)(i)(e)(2)	Doors open from both inside and outside, or a small operator door is present where the large work door opens from outside only	☐	☐	☐	
6	Observation windows Ref. 1910.94(a)(3)(i)(d)	Where hard deep-cutting abrasives are used, windows are safety glass protected by screening	☐	☐	☐	
7	Dust leaks Ref. 1910.94(a)(4)(i)(a)	No dust leaks on enclosure or ducts; any leak found earlier has been repaired	☐	☐	☐	
8	Static pressure drop Ref. 1910.94(a)(4)(i)(b)	Pressure drop at exhaust ducts has been checked and shows no appreciable change pointing to a partial blockage	☐	☐	☐	
9	Abrasive separator Ref. 1910.94(a)(4)(ii)	Where abrasive is recirculated, a separator removes fines from spent abrasive	☐	☐	☐	
10	Dust collector Ref. 1910.94(a)(4)(iii)	Exhaust air passes through dust collecting equipment that can be emptied without contaminating other work areas	☐	☐	☐	

SECTION B | Abrasive blasting PPE and housekeeping

No.	Check item	What to look for	OK	Defect	N/A	Notes
11	Respirator approval Ref. 1910.94(a)(5)(i)	Respirators in use carry NIOSH approval under 42 CFR part 84	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION B | Abrasive blasting PPE and housekeeping

No.	Check item	What to look for	OK	Defect	N/A	Notes
12	Blast room respirators Ref. 1910.94(a)(5)(ii)(a)	Operators inside blast-cleaning rooms wear abrasive-blasting respirators covering head, neck and shoulders	☐	☐	☐	
13	Respiratory protection program Ref. 1910.94(a)(5)(iv)	A program under 29 CFR 1910.134 covers every employee using a respirator this section requires	☐	☐	☐	
14	Respirator air supply Ref. 1910.94(a)(6)	Breathing air for blasting respirators meets 29 CFR 1910.134(i) and is free of harmful dusts, mists or gases	☐	☐	☐	
15	Gloves and aprons Ref. 1910.94(a)(5)(v)	Operators wear heavy canvas or leather gloves and aprons, or equivalent	☐	☐	☐	
16	Eye and face protection Ref. 1910.94(a)(5)(v)(b)	Provided to operators whose respirator lacks it and to others working nearby	☐	☐	☐	
17	Nozzle bonding Ref. 1910.94(a)(2)(iii)	Blast nozzle is bonded and grounded	☐	☐	☐	
18	Floors and ledges Ref. 1910.94(a)(7)	No dust accumulation outside the enclosure; spills cleaned up	☐	☐	☐	
19	Aisles and walkways Ref. 1910.94(a)(7)	No steel shot or similar abrasive on walking surfaces	☐	☐	☐	

SECTION C | Grinding, polishing and buffing hoods

No.	Check item	What to look for	OK	Defect	N/A	Notes
20	Hood position Ref. 1910.94(b)(3)(i)	Dust and dirt fall or are thrown into the hood in the direction of airflow	☐	☐	☐	
21	Wheel and belt direction Ref. 1910.94(b)(3)(i)	Wheels, discs, straps and belts do not throw dust toward the operator's breathing zone	☐	☐	☐	
22	Grinding wheel exhaust volume Ref. 1910.94(b)(3)(ii)	Measured exhaust meets the Table G-4 minimum for the wheel diameter and width	☐	☐	☐	
23	Adjustable tongue Ref. 1910.94(b)(5)(ii)	Tongue works and sits within one-fourth inch of the wheel periphery	☐	☐	☐	
24	Portable grinding enclosure Ref. 1910.94(b)(5)(iv)	Where work permits, partial enclosure with minimal opening and average face velocity of at least 200 feet per minute	☐	☐	☐	
25	Cradle enclosure Ref. 1910.94(b)(5)(vi)	Operator stands outside the working face; average inward velocity at least 150 feet per minute	☐	☐	☐	
26	Dust collector Ref. 1910.94(b)(4)(iii)	Exhaust system has a suitable dust collector in service	☐	☐	☐	

SECTION D | Spray booths and spray rooms

No.	Check item	What to look for	OK	Defect	N/A	Notes
27	Spraying enclosed Ref. 1910.94(c)(2)	Every spray-finishing job runs in a booth or dedicated spray room	☐	☐	☐	
28	Walkways Ref. 1910.94(c)(3)(ii)	Clear path at least 6 1/2 feet high from every work location to an exit or open front	☐	☐	☐	
29	Exit doors Ref. 1910.94(c)(3)(ii)	Booth exit doors open outward	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION D | Spray booths and spray rooms

No.	Check item	What to look for	OK	Defect	N/A	Notes
30	Overspray filters Ref. 1910.94(c)(3)(iii)(a)	Filters are in place and easy to reach for inspection, cleaning or replacement	☐	☐	☐	
31	Booth air velocity Ref. 1910.94(c)(6)(i)	Velocity into openings meets Table G-10 for the operating condition and booth size, unless an adequate air replacement system is fitted	☐	☐	☐	
32	Downdraft booth doors Ref. 1910.94(c)(6)(iii)(b)	Doors are closed while spray painting	☐	☐	☐	
33	Make-up air openings Ref. 1910.94(c)(7)(ii)	Self-closing doors, dampers or louvers are fully open whenever spraying	☐	☐	☐	
34	Filter pressure gage Ref. 1910.94(c)(7)(iii)(b)	Gage across filters is installed and marked with the cleaning or replacement pressure drop	☐	☐	☐	
35	Filter condition Ref. 1910.94(c)(7)(iii)(b)	Gage reading is below the marked change point and face airflow is not below Table G-10	☐	☐	☐	
36	Make-up air heater Ref. 1910.94(c)(7)(iv)(c)	No make-up air heating equipment inside the booth	☐	☐	☐	

DEFECTS FOUND AND ACTION TAKEN

Item no.	Defect description	Reported to	Action taken / date closed

SIGN-OFF

SAFE TO OPERATE? ☐ Yes ☐ No: tagged out of service	
INSPECTOR SIGNATURE	DATE / TIME
SUPERVISOR REVIEW	DATE / TIME

General guidance only, not legal advice. Check the current regulation and your employer's procedures.