Air Compressor Tank Inspection Checklist (29 CFR 1926.306)

Covers the 1926.306 air receiver rules; the standard itself sets no schedule for this check.

OSHA 29 CFR 1926.306

DATE	SHIFT
INSPECTOR	AREA / EQUIPMENT ID

Before you start

1. Mark every item OK, Defect or N/A.
2. Record each defect and the action taken, and recheck the item once it has been corrected.
3. The manufacturer's instructions and site rules may add checks to this list.

Legal basis: 29 CFR 1926.306: Air receivers (Part 1926 Subpart I, Tools—Hand and Power) Source: eCFR, Title 29, text as of 2026-11-09
Online version and sources: https://safetyindex.blog/us/standards/1926-306-air-receivers

SECTION A | Construction and installation

No.	Check item	What to look for	OK	Defect	N/A	Notes
1	Receiver construction code Ref. 1926.306(a)(2)(i)	For a receiver installed after the regulations' effective date, records or markings show it was built to ASME Section VIII, 1968 edition	☐	☐	☐	
2	Safety valve construction and upkeep Ref. 1926.306(a)(2)(ii)	Safety valves are constructed, installed and maintained to ASME Section VIII, 1968 edition	☐	☐	☐	
3	Access to openings Ref. 1926.306(b)(1)	Every drain, handhole and manhole on the receiver is easily accessible	☐	☐	☐	
4	Receiver location Ref. 1926.306(b)(1)	Receiver is not buried underground and is not in an inaccessible place	☐	☐	☐	

SECTION B | Drains and traps

No.	Check item	What to look for	OK	Defect	N/A	Notes
5	Drain pipe and valve Ref. 1926.306(b)(2)	A drain pipe and valve are fitted at the lowest point of the receiver	☐	☐	☐	
6	Automatic trap (if fitted) Ref. 1926.306(b)(2)	Any automatic trap is in addition to the drain valve, which is still present and working	☐	☐	☐	
7	Draining Ref. 1926.306(b)(2)	Receiver is drained completely and often enough that opening the drain valve releases no excessive oil or water	☐	☐	☐	

SECTION C | Gages, safety valves and safety appliances

No.	Check item	What to look for	OK	Defect	N/A	Notes
8	Pressure gage Ref. 1926.306(b)(3)(i)	An indicating pressure gage is fitted and located so it is readily visible	☐	☐	☐	
9	Spring-loaded safety valve Ref. 1926.306(b)(3)(i)	At least one spring-loaded safety valve is fitted to the receiver	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION C | Gages, safety valves and safety appliances

No.	Check item	What to look for	OK	Defect	N/A	Notes
10	Relieving capacity Ref. 1926.306(b)(3)(i)	Combined relieving capacity of the safety valves holds pressure to no more than 10 percent above the receiver's MAWP	☐	☐	☐	
11	No valve before the safety valve Ref. 1926.306(b)(3)(ii)	No valve of any type sits between the receiver and any of its safety valves	☐	☐	☐	
12	Safety appliances protected Ref. 1926.306(b)(3)(iii)	Safety valves, indicating devices and controlling devices cannot readily be made inoperative by any means, including weather	☐	☐	☐	
13	Safety valve testing Ref. 1926.306(b)(3)(iv)	Safety valves are tested frequently and at regular intervals, and each valve is in good operating condition	☐	☐	☐	

DEFECTS FOUND AND ACTION TAKEN

Item no.	Defect description	Reported to	Action taken / date closed

SIGN-OFF

SAFE TO OPERATE? ☐ Yes ☐ No: tagged out of service	
INSPECTOR SIGNATURE	DATE / TIME
SUPERVISOR REVIEW	DATE / TIME