OSHA Gas Can Checklist (29 CFR 1926.152)

For walk-through checks of flammable liquid containers, storage, dispensing and refueling areas on site.

OSHA 29 CFR 1926.152

DATE	SHIFT
INSPECTOR	AREA / EQUIPMENT ID

Before you start

1. Mark every item OK, Defect or N/A.
2. For each Defect, note the location and report it to the supervisor responsible for the area; this reporting step is a site practice, not a step taken from the regulation text.
3. The manufacturer's instructions and site rules may add checks to this list.

Legal basis: 29 CFR 1926.152: Flammable liquids (Part 1926 Subpart F, Fire Protection and Prevention) Source: eCFR, Title 29, text as of 2026-11-09
Online version and sources: https://safetyindex.blog/us/standards/1926-152-flammable-liquids

SECTION A | Gas cans and containers

No.	Check item	What to look for	OK	Defect	N/A	Notes
1	Approved containers Ref. 1926.152(a)(1)	Flammable liquids are held only in approved containers or portable tanks; none in unapproved jugs or buckets	☐	☐	☐	
2	Small quantities Ref. 1926.152(a)(1)	Liquids handled and used in quantities of 5 gallons or less are in approved safety cans or DOT-approved containers; the permitted alternatives are a highly viscid liquid in its original shipping container, or one gallon or less in the original container	☐	☐	☐	
3	Lids closed Ref. 1926.152(f)(1)	Category 1–3 liquid containers are closed whenever not actually in use	☐	☐	☐	
4	Spills cleaned up Ref. 1926.152(f)(2)	No standing leaks or spilled liquid; spill material has been removed and disposed of safely	☐	☐	☐	

SECTION B | Storage areas and extinguishers

No.	Check item	What to look for	OK	Defect	N/A	Notes
5	Exits and stairways clear Ref. 1926.152(a)(2)	No flammable liquids stored in exits, on stairways or in walkways people normally use	☐	☐	☐	
6	Room quantity Ref. 1926.152(b)(1)	No more than 25 gallons in the room outside an approved storage cabinet	☐	☐	☐	
7	Cabinet label Ref. 1926.152(b)(2)(iii)	Cabinet carries conspicuous lettering reading "Flammable-Keep Away from Open Flames"	☐	☐	☐	
8	Cabinet contents Ref. 1926.152(b)(3)	Each cabinet holds no more than 60 gallons of Category 1–3 liquids or 120 gallons of Category 4	☐	☐	☐	
9	Cabinets per area Ref. 1926.152(b)(3)	Three cabinets or fewer in the storage area	☐	☐	☐	
10	Outdoor pile distance Ref. 1926.152(c)(1)	Outdoor container piles are at least 20 feet from buildings, 5 feet apart and no larger than 1,100 gallons each	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION B | Storage areas and extinguishers

No.	Check item	What to look for	OK	Defect	N/A	Notes
11	Outdoor housekeeping Ref. 1926.152(c)(5)	No weeds, debris or unneeded combustible material in the outdoor storage area	☐	☐	☐	
12	Storage room extinguisher Ref. 1926.152(d)(1)	20-B or greater unit mounted outside the door of a room holding over 60 gallons, within 10 feet of the opening	☐	☐	☐	
13	Outdoor storage extinguisher Ref. 1926.152(d)(2)	20-B or greater unit placed 25 to 75 feet from the outdoor storage area	☐	☐	☐	

SECTION C | Dispensing, transfer and point of use

No.	Check item	What to look for	OK	Defect	N/A	Notes
14	Transfer area separation Ref. 1926.152(e)(1)	Areas transferring more than 5 gallons at one time are 25 feet from other operations or behind 1-hour fire-resistant construction	☐	☐	☐	
15	Bonding Ref. 1926.152(e)(2)	Bonding connection in place between containers before any Category 1–3 liquid is transferred	☐	☐	☐	
16	Transfer method Ref. 1926.152(e)(3)	Liquid is moved by closed piping, from safety cans, by a top-drawing device, or by gravity or pump through an approved self-closing valve; no air pressure on containers	☐	☐	☐	
17	Dispenser protection Ref. 1926.152(e)(4)	Dispensing unit is shielded from impact by vehicles and equipment	☐	☐	☐	
18	Ignition sources Ref. 1926.152(f)(3)	No open flames, welding or other ignition sources within 50 feet of where Category 1–3 liquids are used, or a greater clearance where conditions warrant it	☐	☐	☐	
19	Fuel vehicle extinguisher Ref. 1926.152(d)(4)	Tank truck or fuel-dispensing vehicle carries a 20-B:C or greater extinguisher	☐	☐	☐	

SECTION D | Service and refueling areas

No.	Check item	What to look for	OK	Defect	N/A	Notes
20	Hose Ref. 1926.152(g)(3)	Dispensing hose is an approved type	☐	☐	☐	
21	Nozzle Ref. 1926.152(g)(4)	Approved automatic-closing nozzle with no latch-open device fitted	☐	☐	☐	
22	Emergency shutoff Ref. 1926.152(g)(6)	Clearly identified, easily reached switch away from the dispensers cuts power to all of them	☐	☐	☐	
23	No smoking or flames Ref. 1926.152(g)(8)	Nobody smoking and no open flames in fueling, receiving or dispensing areas	☐	☐	☐	
24	No-smoking signs Ref. 1926.152(g)(9)	Conspicuous, legible no-smoking signs posted at the fueling area	☐	☐	☐	
25	Engines off Ref. 1926.152(g)(10)	Equipment motors are shut off throughout fueling	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION D | Service and refueling areas

No.	Check item	What to look for	OK	Defect	N/A	Notes
26	Fueling area extinguisher Ref. 1926.152(g)(11)	20-B:C or greater unit within 75 feet of every pump, dispenser, underground fill pipe opening and lubrication or service area	☐	☐	☐	

DEFECTS FOUND AND ACTION TAKEN

Item no.	Defect description	Reported to	Action taken / date closed

SIGN-OFF

SAFE TO OPERATE?	☐ Yes ☐ No: tagged out of service	
INSPECTOR SIGNATURE		DATE / TIME
SUPERVISOR REVIEW		DATE / TIME