OSHA Lockout Tagout Checklist (29 CFR 1910.147)

For supervisors checking an energy control procedure, a lockout in progress or LOTO records on site.

OSHA 29 CFR 1910.147

DATE	SHIFT
INSPECTOR	AREA / EQUIPMENT ID

Before you start

1. Mark every item OK, Defect or N/A, and record the machine, date and inspector at the top.
2. For each Defect, note what was found, who will correct it and by when; do not start servicing until isolation items are corrected.
3. The machine manufacturer's instructions and your site's rules may add checks to this list.

Legal basis: 29 CFR 1910.147: The control of hazardous energy (lockout/tagout) Source: eCFR, Title 29, Part 1910 Subpart J (text as of 2026-11-09)
Online version and sources: https://safetyindex.blog/us/standards/1910-147-control-hazardous-energy-lockout-tagout

SECTION A | Program and written procedures

No.	Check item	What to look for	OK	Defect	N/A	Notes
1	Procedure for this machine Ref. 1910.147(c)(4)(i)	A documented energy control procedure exists for the machine, or all eight conditions of the documentation exception apply	☐	☐	☐	
2	Shutdown and isolation steps Ref. 1910.147(c)(4)(ii)(B)	Procedure lists machine-specific steps for shutting down, isolating, blocking and securing	☐	☐	☐	
3	Device placement, removal and transfer Ref. 1910.147(c)(4)(ii)(C)	Procedure states how devices are placed, removed and transferred and who is responsible	☐	☐	☐	
4	Verification testing Ref. 1910.147(c)(4)(ii)(D)	Procedure states how to test the machine to verify that energy controls work	☐	☐	☐	
5	Lockable isolation on new or modified equipment Ref. 1910.147(c)(2)(iii)	Isolating devices on machines installed, replaced or majorly repaired or modified after January 2, 1990 accept a lock	☐	☐	☐	
6	Tagout on lockable devices Ref. 1910.147(c)(3)(i)	Where tags are used on lockable devices, they sit where the lock would go and the equivalent-safety demonstration is on file	☐	☐	☐	

SECTION B | Locks, tags and hardware

No.	Check item	What to look for	OK	Defect	N/A	Notes
7	Hardware supplied Ref. 1910.147(c)(5)(i)	Locks, tags, chains, wedges, key blocks, adapter pins or self-locking fasteners are available to workers from the employer	☐	☐	☐	
8	Dedicated devices Ref. 1910.147(c)(5)(ii)	LOTO locks and tags are singularly identified and not used for toolboxes, lockers or other purposes	☐	☐	☐	
9	Standardized devices Ref. 1910.147(c)(5)(ii)(B)	Devices match by color, shape or size; tags share one print and format	☐	☐	☐	
10	Tag condition Ref. 1910.147(c)(5)(ii)(A)(2)	Tags are intact and legible in wet, damp or corrosive locations	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION B | Locks, tags and hardware

No.	Check item	What to look for	OK	Defect	N/A	Notes
11	Tag attachment Ref. 1910.147(c)(5)(ii)(C)(2)	Self-locking, non-reusable attachment of at least 50 pounds unlocking strength, equivalent to a one-piece nylon cable tie	☐	☐	☐	
12	Identity of applier Ref. 1910.147(c)(5)(ii)(D)	Every lock and tag shows the name or identity of the employee who applied it	☐	☐	☐	
13	Tag warning legend Ref. 1910.147(c)(5)(iii)	Tags carry a warning such as Do Not Start or Do Not Operate	☐	☐	☐	

SECTION C | Applying lockout or tagout

No.	Check item	What to look for	OK	Defect	N/A	Notes
14	Who applied the devices Ref. 1910.147(c)(8)	Locks and tags were applied by the authorized employees doing the work	☐	☐	☐	
15	Notification before work Ref. 1910.147(c)(9)	Affected employees were told before controls were applied	☐	☐	☐	
16	Every isolation point covered Ref. 1910.147(d)(4)(i)	A lock or tag is on each energy isolating device feeding the machine	☐	☐	☐	
17	Safe or off position Ref. 1910.147(d)(4)(ii)	Each lock physically holds its isolating device in the safe or off position	☐	☐	☐	
18	Stored energy Ref. 1910.147(d)(5)(i)	Residual pressure, springs, raised parts and similar stored energy are relieved, restrained or blocked	☐	☐	☐	
19	Verification of isolation Ref. 1910.147(d)(6)	The authorized employee confirmed deenergization before starting work	☐	☐	☐	
20	Group lockout Ref. 1910.147(f)(3)(ii)(D)	Every crew member has a personal lock or tag on the group device or lockbox	☐	☐	☐	
21	Contractors Ref. 1910.147(f)(2)(i)	On-site and outside employers have exchanged their lockout or tagout procedures	☐	☐	☐	
22	Shift change Ref. 1910.147(f)(4)	A written method transfers lock or tag protection from off-going to oncoming workers	☐	☐	☐	

SECTION D | Release from lockout or tagout

No.	Check item	What to look for	OK	Defect	N/A	Notes
23	Work area cleared Ref. 1910.147(e)(1)	Nonessential items removed and machine components operationally intact before release	☐	☐	☐	
24	Employees clear Ref. 1910.147(e)(2)(i)	All employees safely positioned or out of the area before re-energizing	☐	☐	☐	
25	Notification after removal Ref. 1910.147(e)(2)(ii)	Affected employees told devices are off before the machine is started	☐	☐	☐	
26	Who removed the devices Ref. 1910.147(e)(3)	Each device removed by the employee who applied it, or under the documented absent-employee procedure	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION E | Periodic inspection and training records

No.	Check item	What to look for	OK	Defect	N/A	Notes
27	Annual periodic inspection Ref. 1910.147(c)(6)(i)	Inspection of this procedure dated within the last year	☐	☐	☐	
28	Independent inspector Ref. 1910.147(c)(6)(i)(A)	Inspector is an authorized employee who does not use the procedure being inspected	☐	☐	☐	
29	Inspection certification Ref. 1910.147(c)(6)(ii)	Record names the machine, date, employees included and the person who inspected	☐	☐	☐	
30	Authorized employee training Ref. 1910.147(c)(7)(i)(A)	Authorized employees can name the energy sources, their type and magnitude and the isolation method for this machine	☐	☐	☐	
31	Tag limitations training Ref. 1910.147(c)(7)(ii)	Where tagout is used, training covers the tag limitations listed in the standard	☐	☐	☐	
32	Training certification Ref. 1910.147(c)(7)(iv)	Training record shows each employee's name and training dates and is current	☐	☐	☐	

DEFECTS FOUND AND ACTION TAKEN

Item no.	Defect description	Reported to	Action taken / date closed

SIGN-OFF

SAFE TO OPERATE? ☐ Yes ☐ No: tagged out of service	
INSPECTOR SIGNATURE	DATE / TIME
SUPERVISOR REVIEW	DATE / TIME