Construction Fire Protection Inspection Checklist (29 CFR 1926.150)

For jobsite walks to check firefighting equipment, water supply, alarms and fire cutoffs.

OSHA 29 CFR 1926.150

DATE	SHIFT
INSPECTOR	AREA / EQUIPMENT ID

Before you start

1. Mark every item OK, Defect or N/A.
2. Record each defect and the action taken; defective firefighting equipment must be replaced immediately under 1926.150(a)(4).
3. The manufacturer's instructions and site rules may add checks to this list.

Legal basis: 29 CFR 1926.150: Fire protection (Part 1926 Subpart F, Fire Protection and Prevention) Source: eCFR, Title 29, text as of 2026-11-09
Online version and sources: https://safetyindex.blog/us/standards/1926-150-fire-protection

SECTION A | Program, access and equipment condition

No.	Check item	What to look for	OK	Defect	N/A	Notes
1	Fire protection program Ref. 1926.150(a)(1)	The site's fire protection program exists and covers the current phase of construction or demolition work	☐	☐	☐	
2	Access to equipment Ref. 1926.150(a)(2)	No materials, debris or vehicles block any extinguisher, hose rack, drum or standpipe outlet	☐	☐	☐	
3	Conspicuous location Ref. 1926.150(a)(3)	Employer-provided firefighting equipment is in plain view or clearly marked where it is	☐	☐	☐	
4	Operating condition Ref. 1926.150(a)(4)	Equipment is in operating condition; anything defective has been replaced, not left in place	☐	☐	☐	
5	Fire brigade Ref. 1926.150(a)(5)	Where the project warrants one, a trained and equipped fire brigade is in place	☐	☐	☐	

SECTION B | Portable fire extinguishers

No.	Check item	What to look for	OK	Defect	N/A	Notes
6	Coverage by area Ref. 1926.150(c)(1)(i)	At least one extinguisher rated 2A or higher for each 3,000 sq ft, or major fraction, of the protected building area	☐	☐	☐	
7	Travel distance Ref. 1926.150(c)(1)(i)	No point in the protected area is more than 100 feet of travel from an extinguisher	☐	☐	☐	
8	Each floor Ref. 1926.150(c)(1)(iv)	One or more extinguishers rated 2A or higher on every floor	☐	☐	☐	
9	Stairway extinguisher Ref. 1926.150(c)(1)(iv)	In a multistory building, at least one extinguisher sits adjacent to a stairway	☐	☐	☐	
10	Flammable liquids and gas Ref. 1926.150(c)(1)(vi)	A 10B-or-higher extinguisher within 50 feet wherever more than 5 gallons of flammable or combustible liquids or 5 pounds of flammable gas are in use (vehicle integral fuel tanks excluded)	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION B | Portable fire extinguishers

No.	Check item	What to look for	OK	Defect	N/A	Notes
11	Freeze protection Ref. 1926.150(c)(1)(v)	Extinguishers and water drums exposed to freezing are protected from it	☐	☐	☐	
12	Listed or approved Ref. 1926.150(c)(1)(ix)	Each extinguisher is listed or approved by a nationally recognized testing laboratory	☐	☐	☐	
13	Prohibited types Ref. 1926.150(c)(1)(vii)	No carbon tetrachloride or other toxic vaporizing liquid extinguishers on site	☐	☐	☐	
14	Inspection and maintenance Ref. 1926.150(c)(1)(viii)	Evidence that each portable extinguisher is inspected periodically and maintained per NFPA No. 10A-1970	☐	☐	☐	

SECTION C | Water supply and hose lines

No.	Check item	What to look for	OK	Defect	N/A	Notes
15	Water supply Ref. 1926.150(b)(1)	Once combustible materials have accumulated, water of sufficient volume, duration and pressure is available to run the firefighting equipment	☐	☐	☐	
16	Water drum substitute Ref. 1926.150(c)(1)(ii)	Any drum used in place of a 2A extinguisher is a 55-gallon open drum of water with two fire pails	☐	☐	☐	
17	Garden-type hose substitute Ref. 1926.150(c)(1)(iii)	Hose is 1/2-inch, 100 feet or shorter, has a nozzle, delivers at least 5 gallons per minute and reaches at least 30 feet horizontally	☐	☐	☐	
18	Hose racks or reels Ref. 1926.150(c)(1)(iii)	Garden-type hose is on conventional racks or reels placed so a hose stream reaches all points in the area	☐	☐	☐	
19	Hose connection adapters Ref. 1926.150(c)(2)(ii)	Adapters or equivalent are on hand where hose connections don't fit local firefighting equipment	☐	☐	☐	
20	Demolition hose lines Ref. 1926.150(c)(2)(iii)	During demolition involving combustible materials, charged hose lines fed by hydrants, tank trucks with pumps or equivalent are available	☐	☐	☐	

SECTION D | Sprinklers and standpipes

No.	Check item	What to look for	OK	Defect	N/A	Notes
21	New sprinkler installation Ref. 1926.150(d)(1)(i)	Where sprinklers are part of the facility, installation keeps pace with construction and is in service on completed stories where laws permit	☐	☐	☐	
22	Existing sprinklers Ref. 1926.150(d)(1)(ii)	During demolition or alterations, existing sprinklers remain in service as long as reasonable	☐	☐	☐	
23	Sprinkler control valves Ref. 1926.150(d)(1)(ii)	Valves were checked at close of work today and show protection in service; only authorized persons operate them	☐	☐	☐	
24	Standpipe readiness Ref. 1926.150(d)(2)	Required or existing standpipes are brought up with the structure and ready for fire protection use	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION D | Sprinklers and standpipes

No.	Check item	What to look for	OK	Defect	N/A	Notes
25	Siamese connection Ref. 1926.150(d)(2)	Fire department connection is outside the structure at street level and conspicuously marked	☐	☐	☐	
26	Hose outlets Ref. 1926.150(d)(2)	At least one standard hose outlet on each floor	☐	☐	☐	

SECTION E | Alarms and fire cutoffs

No.	Check item	What to look for	OK	Defect	N/A	Notes
27	Alarm system Ref. 1926.150(e)(1)	A working means, such as a telephone system or siren, alerts employees on site and the fire department in an emergency	☐	☐	☐	
28	Posted alarm code Ref. 1926.150(e)(2)	Alarm code and reporting instructions are posted where they are easy to see at phones and employee entrances	☐	☐	☐	
29	Fire doors Ref. 1926.150(f)(1)	Fire doors with automatic closing devices are hung on openings once practicable	☐	☐	☐	
30	Fire cutoffs during alterations or demolition Ref. 1926.150(f)(2)	Fire cutoffs remain in place until operations make removal necessary	☐	☐	☐	

DEFECTS FOUND AND ACTION TAKEN

Item no.	Defect description	Reported to	Action taken / date closed

SIGN-OFF

SAFE TO OPERATE? ☐ Yes ☐ No: tagged out of service

INSPECTOR SIGNATURE	DATE / TIME
SUPERVISOR REVIEW	DATE / TIME