Asbestos Inspection Checklist and OSHA Checklist (29 CFR 1926.1101)

Use before asbestos work begins and at each shift on construction, renovation, maintenance or demolition jobs.

OSHA 29 CFR 1926.1101

DATE	SHIFT
INSPECTOR	AREA / EQUIPMENT ID

Before you start

1. Mark every item OK, Defect or N/A; use N/A only where the item's work class or control method does not apply to the job.
2. Report any Defect to the competent person, who has authority to take prompt corrective measures, and recheck the item before work resumes.
3. The manufacturer's instructions for enclosures, glovebags and respirators, and your site rules, may add checks.

Legal basis: 29 CFR 1926.1101: Asbestos (Part 1926 Subpart Z, Toxic and Hazardous Substances) Source: eCFR, Title 29, text as of 2026-11-09
Online version and sources: https://safetyindex.blog/us/standards/1926-1101-asbestos

SECTION A | Before work starts

No.	Check item	What to look for	OK	Defect	N/A	Notes
1	Work class identified Ref. 1926.1101(b)	Each task recorded as Class I, II, III or IV using the definitions; TSI and surfacing material treated as PACM unless rebutted	☐	☐	☐	
2	Initial exposure assessment Ref. 1926.1101(f)(2)(i)	Assessment done by the competent person immediately before or at the start of the operation, before exposure-dependent controls are chosen	☐	☐	☐	
3	Competent person supervising Ref. 1926.1101(e)(6)	A competent person is assigned to and supervising the asbestos work inside the regulated area	☐	☐	☐	
4	Other employers informed Ref. 1926.1101(d)(1)	Other employers on site have been told about the asbestos work, the regulated area rules and how their employees are protected	☐	☐	☐	
5	Resilient flooring status Ref. 1926.1101(g)(8)(i)(I)	Flooring, mastic and backing handled as asbestos-containing unless an industrial hygienist has determined it asbestos-free	☐	☐	☐	
6	Respirator program Ref. 1926.1101(h)(2)(i)	A written respiratory protection program meeting the listed parts of 1910.134 covers every employee who must wear a respirator	☐	☐	☐	

SECTION B | Regulated area and isolation

No.	Check item	What to look for	OK	Defect	N/A	Notes
7	Demarcation and signs Ref. 1926.1101(e)(2)	Boundary clearly marked (barriers or enclosure may serve) and signs displayed	☐	☐	☐	
8	Access control Ref. 1926.1101(e)(3)	Only authorized persons inside the boundary	☐	☐	☐	
9	No eating or smoking Ref. 1926.1101(e)(5)	No food, drink, smoking, chewing tobacco or gum, or cosmetics inside the boundary	☐	☐	☐	

General guidance only, not legal advice. Check the current regulation and your employer's procedures.

SECTION B | Regulated area and isolation

No.	Check item	What to look for	OK	Defect	N/A	Notes
10	Respirators at entry Ref. 1926.1101(e)(4)	Everyone entering where respirators are required has one selected under (h)(3)	☐	☐	☐	
11	Class I isolation Ref. 1926.1101(g)(4)(ii)	Critical barriers in place, or an alternative isolation method verified by perimeter surveillance and monitoring, wherever (g)(4)(ii) applies	☐	☐	☐	
12	HVAC sealed (Class I) Ref. 1926.1101(g)(4)(iii)	HVAC openings sealed with a double layer of 6 mil plastic or equivalent	☐	☐	☐	
13	Dropcloths (Class I) Ref. 1926.1101(g)(4)(iv)	Impermeable dropcloths laid beneath all removal activity	☐	☐	☐	
14	Objects covered (Class I) Ref. 1926.1101(g)(4)(v)	Objects inside covered with impermeable dropcloths or plastic sheeting secured by duct tape or equivalent	☐	☐	☐	
15	NPE pressure Ref. 1926.1101(g)(5)(i)(A)(3)	Manometer shows at least -0.02 column inches of water differential relative to outside, held throughout use	☐	☐	☐	
16	NPE leak check Ref. 1926.1101(g)(5)(i)(B)(1)	Enclosure inspected for breaches and smoke-tested before work and at each shift start; any leaks sealed	☐	☐	☐	

SECTION C | Work practices and controls

No.	Check item	What to look for	OK	Defect	N/A	Notes
17	HEPA vacuums Ref. 1926.1101(g)(1)(i)	HEPA-filtered vacuums used to collect all ACM and PACM dust and debris	☐	☐	☐	
18	Wet methods Ref. 1926.1101(g)(1)(ii)	Material kept wet during handling, removal, cutting and cleanup, unless the employer can demonstrate wetting is infeasible	☐	☐	☐	
19	Waste containers Ref. 1926.1101(g)(1)(iii)	Waste and debris picked up promptly and placed in leak-tight containers	☐	☐	☐	
20	Abrasive saws Ref. 1926.1101(g)(3)(i)	No high-speed abrasive disc saw in use without a point-of-cut ventilator or HEPA-exhausted enclosure	☐	☐	☐	
21	Compressed air Ref. 1926.1101(g)(3)(ii)	No compressed air used to remove asbestos unless with an enclosed system capturing the dust cloud	☐	☐	☐	
22	Dry cleanup Ref. 1926.1101(g)(3)(iii)	No dry sweeping, shoveling or other dry cleanup of ACM or PACM debris	☐	☐	☐	
23	Employee rotation Ref. 1926.1101(g)(3)(iv)	Exposure is not being managed by rotating workers in and out	☐	☐	☐	
24	Glovebag leak test Ref. 1926.1101(g)(5)(ii)(B)(2)	Each glovebag smoke-tested and leaks sealed before use	☐	☐	☐	
25	Glovebag single use Ref. 1926.1101(g)(5)(ii)(B)(3)	Each glovebag used once and not moved along the pipe	☐	☐	☐	
26	Roof material lowering Ref. 1926.1101(g)(8)(ii)(E)	Roof ACM carried, passed down by hand, or lowered by covered chute, crane or hoist; never dropped or thrown	☐	☐	☐	

SECTION D | Monitoring, PPE and adjacent areas

No.	Check item	What to look for	OK	Defect	N/A	Notes
27	Daily monitoring (Class I and II) Ref. 1926.1101(f)(3)(i)	Daily sampling representative of each employee doing Class I or II work in the regulated area, unless an NEA covers the whole operation or the (f)(3)(iii) exception applies	☐	☐	☐	
28	Results shared Ref. 1926.1101(f)(5)	Employees notified within 5 working days of results being received, in writing or by accessible posting	☐	☐	☐	
29	Re-monitoring after changes Ref. 1926.1101(f)(4)(ii)	Monitoring restarted after any change in process, controls, personnel or work practices that may raise exposure	☐	☐	☐	
30	Monitoring observation Ref. 1926.1101(f)(6)(i)	Affected employees and their representatives offered the chance to observe exposure monitoring	☐	☐	☐	
31	No filtering facepieces Ref. 1926.1101(h)(3)(i)(A)	No filtering facepiece respirators worn for asbestos	☐	☐	☐	
32	HEPA respirator filters Ref. 1926.1101(h)(3)(i)(B)	Powered and non-powered air-purifying respirators fitted with HEPA filters	☐	☐	☐	
33	Protective clothing Ref. 1926.1101(i)(1)	Coveralls or similar, head and foot coverings and gloves worn where exposure exceeds a PEL, a required NEA is missing, or large Class I TSI or surfacing removal is under way	☐	☐	☐	
34	Laundering Ref. 1926.1101(i)(2)(i)	Contaminated clothing laundered in a way that prevents airborne asbestos release above the PELs	☐	☐	☐	
35	Adjacent areas checked daily Ref. 1926.1101(d)(4)	Employers next to another contractor's regulated area check enclosure integrity or control effectiveness every day	☐	☐	☐	

DEFECTS FOUND AND ACTION TAKEN

Item no.	Defect description	Reported to	Action taken / date closed

SIGN-OFF

SAFE TO OPERATE? ☐ Yes ☐ No: tagged out of service	
INSPECTOR SIGNATURE	DATE / TIME
SUPERVISOR REVIEW	DATE / TIME

General guidance only, not legal advice. Check the current regulation and your employer's procedures.