

AIRCON

8118 Manning Avenue

Fort McMurray, Alberta T9H 1V7

Phone: (780)791-0430

www.aircontech.com

FIELD REPORT #

FS-17-230-260725-PA

Unit # yymmdd

Corresponding Invoice #

CUSTOMER Syncrude Mildred Lake

UNIT No. 17-230

DATE 2026-07-25

CONTACT Michael Latcham

MAKE CAT

CUSTOMER PO #

MODEL 797F

WORK ORDER # 450827853

SERIAL No. LTZ00246

Operation # 0010

EQUIP CATEGORY Truck

NOTIFICATION # 009400871820

OUR METER 14676

QTY.	PART No.	DESCRIPTION	ADMIN	DESCRIPTION OF WORK
1	ACT500006	LT5RH Exchanged Nitrogen Cartridge		C1 - Complaint:
1	ACT584500N	Plastic Tamper Seal		
1	ACT584501N	10" Lead Tamper Seal		Perform A101/210 Proof Test
1	ACT801015S	Nitrogen Purge		C2 - Cause:
1	ACT581501N	Actuator Cartridge Gasket (Flat Gasket)		Scheduled work
				C3 - Correction
				FLRA, CHAT, Lock out unit, Performed A101/210 Proof Test as per SCL Procedure
				Pneumatic Shutdown - PASS
				Automatic Shutdown - PASS

Manual Shutdown - PASS

C4 - Complications: (Minimum of 2)

Other techs working in same area

Other workers on unit

WORK REMAINING

Team: 503D		REG		OT	STAT	
Performed By:	Pavlo Aksonkin	Truck #	✓		TIME IN:	TIME OUT:
	PA-90446064					
Performed By:	Olexandr Nazarenko	Truck #	✓		TIME IN:	TIME OUT:
	ON-90414541					
Performed By:		Truck #			TIME IN:	TIME OUT:

Approved
by:

Incomplete

✓ F/S

Company Syncrude Mildred Lake
:

Date: 2026-07-25