Task Description	Data				Model			
	Sample	Size	Annotations	Source	Algorithm	Architecture	Performance	Ref
3D points Classification of Power Lines		2,595 M 3D points along 40,000 km	5 (22) Classes 36,000 B. Boxes	Code + Data Openly Available [190]	Explainable ML	SCENE-Net V2	mIoU = 50.21%	[191]
					Supervised DL	Point Trans-former V3 [192]	mIoU = 65.58%	[191]
3D points Classification of Power Lines		27.4 M 3D points Unspecified Line Length	5 Classes Unspecified B. Box Num.	Annotations Not Available Data Openly Available [52]	Supervised DL	PSFE-Net	mIoU = 89.90%	[193]
					Supervised DL	SCD-Net [194]	mIoU = 88.63%	[193]
3D points Classification of Power Lines		Unspecified 3D points Unspecified Line Length	4 Classes Unspecified B. Box Num.	Partially Available [195]	Unsupervised ML	Reflectivity Threshold + Cluster PCA	F1 = 95.09%	[196]
					Supervised DL	PointNet++ [197]	F1 = 83.10%	[196]
Power Lines Conductors Extraction and Modelling		Unspecified 3D points Unspecified Line Length	Not Existent	Not Available	Unsupervised ML	PCA + K-D tree + DBSCAN	Not Evaluated	[198]
Power Lines Conductors Distances Assessment		Unspecified 3D points 160 km Line Length	Not Existent	Not Available	Unspecified	Unspecified	Not Evaluated	[199]