INSPECTION REPORT

Pre-Start Inspection

RTB Roofing Ltd · Studley Rd, London, SW4 6RZ

Pre-Start Inspection	Complete
Score	**2 / 2 (100%)**
Project address	Studley Rd, London, SW4 6RZ
Date	04 Nov 2026
RTB attendance	Andy Admin

INSPECTION REPORT

Pre-Start Inspection

RTB Roofing Ltd · Studley Rd, London, SW4 6RZ

Pre-Start Inspection — 2 / 2 (100%)

Scope Of Works — 1 / 1 (100%)

Renewal or repair?	**Renewal**
Roof to be stripped?	**Yes**
Waste away solution?	**Yes - RTB sorting Skips**
Loft insulation to be renewed?	**Yes**
Any visible signs of concern with structural elements (rafters/gables etc)?	**Yes**
Lead work to be carried out?	**No**

Any other works/variations/issues visible at time of pre-start?

Slates slipped near the valley; battens sound. Lead flashing to the chimney needs re-dressing.

Health & Safety — 1 / 1 (100%)

Scaffolding in place & correct heights to facilitate roof works?	**Yes**
Is scaffold signed off and handed over? Copy received?	**Yes**
Hoist/Ginny wheel in situ?	**Yes**
Chute in position?	**No**

RAMS

RAMS in place and suitable?	**Yes**

Sign Off

Sign off signature

Andy Admin

04/11/2026 10:00 GMT+0