



28 March 2024

Chris Ritchie
Director, Industry and Assessment
Department of Environment and Assessment
Locked Bag 5022
Paramatta NSW 2124

Dear Chris

Request for Secretary's Environmental Assessment Requirements, 132 McCredie Road, Guilford West 'Project Pluto'

We write on behalf of *Goodman Property Services (Aust.) Pty Ltd* (Goodman) to request the Department of Planning and Environment (DPE) to issue Secretary's Environmental Assessment Requirements (SEARs) for a data centre at 132 McCredie Road, Guilford West (the site). The project is referred to as 'Project Pluto'.

Goodman is a digital infrastructure company that owns, develops, and manages high quality, sustainable properties that are close to consumers and provide essential infrastructure for the digital economy. These include warehouses, large scale logistics facilities, data centres and business and office parks globally. Further information on Goodman's business details are provided below:

Goodman Property Services (Aust.) Pty Ltd	
ABN	40 088 981 793
Address	The Hayesbery 1-11 Hayes Road Rosebery NSW 2018 Australia

Table 1: Applicant details

Subject Site

The site is located at 132 McCredie Road, Guilford West, in the local government area of Cumberland Council (Council). The site is legally described as Lot 1 DP 828392 and provides a site area of approximately 71,710m². An aerial depicting the site and its immediate surrounding context is provided in Figure 1.

The site currently comprises a single storey office building fronting McCredie Road, at grade parking and hard stand industrial storage. Vehicle access is available via a two-way access driveway from McCredie Road.

AU02-1967080693-63519\1.0 Goodman Group

Goodman Limited | ABN 69 000 123 071
Goodman Funds Management Limited | ABN 48 067 796 641 | AFSL Number 223621
as responsible entity for Goodman Industrial Trust | ARSN 091 213 839

The Hayesbery, 1-11 Hayes Road, Rosebery NSW 2018 | GPO Box 4703, Sydney NSW 2001 Australia
Tel +61 2 9230 7400 | Fax +61 2 9230 7444

Goodman Logistics (HK) Limited | Company No. 1700359 | ARBN 155 911 149 | a Hong Kong company with limited liability
Suite 901, Three Pacific Place, 1 Queen's Road East, Hong Kong | Tel +852 2249 3100 | Fax +852 2525 2070

info-au@goodman.com | www.goodman.com

The site previously operated as a Castrol lubricants facility, and is currently subject to category 1 remediation of soil and groundwater contamination, approved under DA 2022/0085.

The site presents a rare opportunity to leverage a site of scale, located immediately opposite existing Ausgrid infrastructure with significant electricity capacity available.



Figure 1 - 132 McCredie Road, Guilford West Site (Base source: Nearmap)

The site is in the E4 General Industrial zone, with surrounding context as follows:

- **To the north**, there is a recently constructed warehouse and distribution centre which contains two buildings comprising of eight (8) tenancies which are permitted to operate 24/7 (DA2018/347/1).
- **To the east**, the site adjoins an electrical substation 'Guildford Transmission Substation' as well as public open space 'Guildford West Sportsground' to the east and south of the site.
- **To the west**, the site adjoins a variety of warehouse buildings utilised for industrial related land uses.
- **To the south**, the site adjoins public open space. Further to the south of the site is Prospect Creek and residential dwellings fronting Hemingway Crescent. Guildford Train Station is located approximately 2.65km to the east of the site.




Figure 2 - Site context map (Base source: Mecone, Six Maps)

The Proposal

The proposed development comprises the construction, fit out and operation of a data centre.

The proposal will seek to develop sufficient data centre floor space plus ancillary office space with a load capacity of 126MW, including associated carparking and landscaping.

Key components of the proposed development include:

- demolition of existing structures and bulk excavation of the site
- detailed earthworks and infrastructure construction, including vegetation clearing, installation of services and drainage infrastructure
- construction, fit out and use of a data centre including offices, with a total GFA of 37,092 (including 5,508sqm of office)
- provision of approx. 63 car parking spaces
- approximate 26m building height over three (3) floors (including an acoustic screen parapet) (noting no height limit applies to the site)
- a floor space ratio (FSR) of approximately of 0.52:1 (noting no FSR limit applies to the site)
- 23,701sqm of landscaping (accounting for 33% of the site)

State Significant Development

The proposed development is State Significant development (SSD) under Schedule 1 clause 25 of *State Environmental Planning Policy (Planning Systems) 2021*.

Clause 25 states:

25 Data centres

(1) Development for the purpose of data centres that has a total power consumption of more than the relevant amount.

*(2) In this section—
relevant amount means—*

(a) for development in relation to which the relevant environmental assessment requirements are notified under the Act on or before 31 May 2023—10 megawatts, or

(b) for any other development—15 megawatts.

The proposal is anticipated to have a total estimated power consumption of **one hundred and twenty six (126) megawatts**.

It is proposed to lodge a SSDA under section 4.38 of the Environmental Planning and Assessment Act 1979 (EP&A Act) to be assessed as SSD. It is therefore requested that the DPE issue SEARs under section 4.12 of the EP&A Act and Clause 3 of Schedule 2 of the Environmental Planning and Assessment Regulation 2021 that will enable the preparation of an Environmental Impact Statement (EIS) for the proposed development.

Key Issues

The EIS will be prepared in accordance with the SEARs and the legislative requirements defined under the EP&A Regulation. The EIS will outline recommendations to address any environmental impacts of the project to inform DPE in its assessment and recommendation on the project.

Key assessment issues for consideration are likely to be visual impact resulting from necessary bulk and scale of the facility. Noise, air, and flood impacts will also be key considerations.

Visual Impact

Visual impact, particularly on the residential receivers to the south will be a key consideration, however is alleviated through a generous setback to these receiver and significant existing trees along the southern boundary proposed for retention. Playing fields to the east will also be of consideration.

The proposal will also seek to limit the presentation of bulk and scale through a high-quality architectural outcome, which will provide articulation and visual interest to the facades through strategic location of office spaces and use of high-quality materials and landscaping.

To site is bounded to the north and west by industrial development of low sensitivity, and therefore not impacted by environmental impacts such as overlooking and overshadowing.

Flood Assessment

Initial flood investigation indicates that the Site is affected by overland flows draining to Prospect Creek. Given the flood affection, the proposal will be assessed in accordance with Cumberland City Council's flood-related policy and development controls.

Air Quality & Noise

Air quality and noise impacts will be considered in the assessment, with mitigation measures proposed as necessary, including noise screening and other measures.

Conclusion

We trust that the above information is sufficient to enable the issue of SEARs for the proposed development. If you wish to discuss any aspect of this letter, please contact the undersigned on 9230 7225.

Yours sincerely




Guy Smith
Head of Planning, Goodman

	McCredie St
	CLOUD B
	ASK059-060
Site area (m2)	71,710
Potential IT load capacity (MW)	126.00
PUE	1.45
Site max demand (MW)	182.70
Number of floors	3
Number of data halls	18
Rack per Data Hall (Quantity)	600
Rack IT Load (kW)	11.67
IT per storey (MW)	42.00
Site IT power potential / site area (kW)	1.76
Data hall IT power / data hall area (kW)	3.99
Total power per storey (MW)	60.90
Total kw per m2 / GBA (kW)	1.97
Level of redundancy	5N4
Substation Quantity	3
Substation Area Total (m2)	3,500
Number of generators	90
Cooling system assumed	CHILL WAT/ FWU
Floor-to-floor height (m)	7
Building height (inc 5m plant) (m)	26
Car parking	0.5-1 PER MW
GBA (exc. Gen Platforms and Subst.) (m2)	64,044
FSR (permissible and what is achieved)	NA/0.52:1
GFA data halls (m2)	31,584
GFA office (m2)	5,508
Indoor plant area (m2)	17,934
Roof plant area (m2)	10,528
Landscape deep soil (m2)	23,701
Landscape deep soil (%)	33%

LEGEND

	INDICATIVE PROPOSED ACCESS ROAD
	INDICATIVE DATA HALL
	INDICATIVE FAN WALL
	INDICATIVE PLANT
	INDICATIVE ADMINISTRATION BUILDING
	INDICATIVE ROOF PLANT
	INDICATIVE LANDSCAPING
	CORRIDOR/ ELECTRICAL SERVICES
	LEP SETBACK
	INDICATIVE SUBSTATION
	INDICATIVE CORRIDOR
	SITE BOUNDARY

NOTE: SUBSTATION SIZING IS INDICATIVE ONLY.
EASEMENTS SHOWN AS PER TITLE



1 SITE - 132 MCCREDIE ROAD, SMITHFIELD (CLOUD B)
1 : 2000



Issue	Date	Description	Client Goodman		+61 2 8069 8930 LEVEL 22 68 PITT STREET SYDNEY NSW 2000 AUSTRALIA	Use written dimensions only - Do not scale from drawing - Contractors shall confirm all dimensions on-site prior to commencing any work or producing any shop drawings - All materials to be used in accordance with the manufacturer's specifications and instructions and shall comply with the relevant Australian Standards - Copyright of this drawing and design remain the property of Greenbox Architecture Pty Ltd - Nominated Architect - Gerard Page; NSW reg No.7247, Vic reg No.17664, QLD reg No.4538	Project GOODMAN DC NSW	Scale	Checked By	Drawing Title MASTERPLAN - 132 MCCREDIE ROAD, SMITHFIELD (CLOUD B)	Drawing Number ASK059	Issue D
	A	08/12/23						As indicated	BY			
	B	11/12/23						Drawn By	Approved By			
	C	13/12/23						ML	AO			
D	21/12/23	FOR INFORMATION	Project Manager	GREENBOX ARCHITECTURE PTY LTD ABN: 79 139 779 098 ISO 9001 CERTIFIED QUALITY SYSTEM				Job Number		230071	ASK059	D
			Construction Manager									

LEP/ PLANNING CONTROLS:

Address: 132 McCredie Street, Smithfield
Lot/DP: Lot 1 DP 596315
Relevant Local Environmental Plan: Cumberland
Local Environmental Plan (LEP) 2021
Zoning & land use permissibility: E4 – General
Industrial Light industries (Data Centres) are
permitted with consent under Cumberland LEP.
Maximum Height of Buildings: N/A
Floor Space Ratio: N/A

Other Development Controls:

- Site Setbacks:
- Front Setback: 15m Note: Front setback areas shall not be used for storage or display of goods or excessive signage, loading/unloading or large areas of car parking
 - Side and Rear Setback: Southern boundary adjoins a residential zone. Minimum rear setback is 6m, minimum width of landscaping within the setback 3m
 - Rear Setback: Nil side setbacks except where setback the Site
 - adjoins the residential zone (Southern part of the site).

Landscaped Area/Tree Coverage:

- Minimum width of landscaping within the building setback of 3m

Car Parking Controls (DCP)

- 1 space per 40m² GFA


Easements:

- J11865 – Easement for transmission line 18.29 wide affecting the part of the land above described shown so burdened in the title diagram. Located at northern portion of the site.
- H876662 – Easement for transmission line affecting the part of the land traversing the site and then returning north along the eastern boundary.


Flooding:

The 10.7 Planning Certificate for the site identifies the site as being located in a flood planning area. The land is subject to flood-related development controls.

LEGEND



NOTE: SUBSTATION SIZING IS INDICATIVE ONLY.
EASEMENTS SHOWN AS PER TITLE



Issue	Date	Description	Client		+61 2 8069 8930 LEVEL 22 68 PITT STREET SYDNEY NSW 2000 AUSTRALIA GREENBOX ARCHITECTURE PTY LTD ABN: 79 139 779 098 ISO 9001 CERTIFIED QUALITY SYSTEM	Use written dimensions only - Do not scale from drawing - Contractors shall confirm all dimensions on-site prior to commencing any work or producing any shop drawings - All materials to be used in accordance with the manufacturer's specifications and instructions and shall comply with the relevant Australian Standards - Copyright of this drawing and design remain the property of Greenbox Architecture Pty Ltd - Nominated Architect - Gerard Page; NSW reg No.7247, Vic reg No.17664, QLD reg No.4538	Project GOODMAN DC NSW	Scale 1 : 200	Checked By BY	Drawing Title 3D MASSING - 132 MCCREDIE ROAD, SMITHFIELD (CLOUD B)	Drawing Number ASK060	Issue D
A	08/12/23	FOR INFORMATION	Project Manager					Drawn By ML	Approved By AO			
B	11/12/23	FOR INFORMATION	Construction Manager					Job Number 230071				
C	13/12/23	FOR INFORMATION										
D	21/12/23	FOR INFORMATION										