

NOTES:

DOCUMENT ID

S-05846

- 1) CERTIFICATE 2.2/EN ISO 10204 OR SIMILAR REQUIRED.
- 2) STEEL WEIGHT 100 kg
- 3) EXTERNAL PAINTING: SEE SPEC. REF. NO. 46.02
- 4) ALL FREE EDGES NOT ROUNDED MUST BE DE-BURRED. SHARP EDGES ARE NOT ALLOWED.
- 5) GASKET POS 8 TO BE PROVIDED WITH 24 HOLES Ø20 IN BCD 840 EQUALLY SPACED.

11	1	INSULATION SUPPORT RING t = 2	X2CrNiMo17-12-2 / SS 316L	
10		INSULATION	CERAMIC FIBRE	
9	15m	GASKET - ROPE 20 x 7	EXPANDED PTFE	
8	1	GASKET, OD 895 / ID 300 x 2	PTFE	5)
7	48	WASHER 5/8"	SS 316L / A4	
6	24	NUT 5/8"	A194-8M / A4 -70	
5	24	BOLT 5/8" UNC x 75	A193-B8M / A4 - 70	
4	1	SLEEVE / PIPE	X2CrNiMo17-12-2 / SS 316L	
3	1	FLANGE 12"	A36 / S355J2N	1)
2	1	PIPE Ø324 x 4	A36 / S355J2N	1)
1	1	SPECIAL FLANGE DN 700	A36 / S355J2N	1)
POS	NO	DESCRIPTION	MATERIAL	NOTES

## REFERENCE DOCUMENTS TEXT REF. NO.

CONTRACTOR APPROVAL CODE

1 REJECTED

2 APPROVED WITH COMMENTS

PROJ.: K484
OWNER: ENAP
CONTRACTOR: KT / TCM Chile

WR N°: 4100-01
PO N°: 7500113000

CONTRACTOR APPROVAL CODE

1 REJECTED

2 APPROVED WITHOUT COMMENTS

4 FOR INFORMATION ONLY

U.O.: KT S.p.A.

MR N°: 4100-01
PO N°: 7500113900
EQUIPMENT: C-3808

U.O.: KT S.p.A.
BY: AL
DATE: 28/01/25

KT Doc. CODE: K484-0000-0000-MR-4100-01-C3808-CA1109-0013

## TOPSOE

Vault rev. 0

Information contained herein is confidential; it may not be used for any purpose other than for which it has been issued, and may not be used by or disclosed to third parties without written approval of Topsoe A/S.

1 Revised as indicated

2 Jan 23, 2025 KLPN NMO NMO

0 First issue

DEC 21, 2023 ELAS GARG GARG

REV.

DESCRIPTION

DATE

DRAWN CHKD. APPD.

ENAP, Chile

WSA plant for Aconcagua Refinery

REF. NO. 03.60

DWG. SIZE

A0

C-3808

WSA condenser

Acid concentrator, hot air inlet flange

WSC53109-0360

DOCUMENT NUMBER

WSC53109-0360 rev. 1

Approved