



New Jersey Department of Agriculture - SSCC

Inspection Report

Meadows at Manalapan

Address

Woodward, between Route 33 and Millhurst
Manalapan NJ 07726

Inspector: Courtney Davidson
cdavidson@permitrack.com

Inspection Date: 06/03/2009

Weather Trends: Partly Cloudy

Temperature: 77 F

Last Precip. Date: 06/02/2009

Last Precip. Amount: 1.5 in

Last Precip. Source: Estimate

Reason for Inspection: After Rainfall

Comments:

Follow-up Action: Stop Work Order
Stop Work Order to be issued immediately unless BMPs are repaired immediately due to surplus runoff.

Inspection Items

Name: Perimeter Control -- Silt Fence

Required: Yes

Inspected: Yes

Status: Active

Condition: Ineffective

Description: Heavy duty silt fence to be buried a minimum of six inches below existing grade and supported by wooden/steel posts no further than four feet apart.

Comment: Install berm to minimize runoff toward silt fence low point. IMMEDIATELY.



Name: Construction Entrance -- Tracking Pad

Required: Yes

Inspected: Yes

Status: Active

Condition: Correct

Description: Rock tracking pad to be comprised of large gravel and should be a minimum width of 12 feet and 20 feet in length.

Comment: Tracking pad beginning to show signs of sediment build-up. Remove sediment and replace rock as necessary.

