



SERTIFIKAT ANALISA MUTU PRODUK

Kalsium Hipoklorit, $\text{Ca}(\text{OCl})_2$ 60 %



No QC Pass : 3-160426; 1,3-170426;
1-180426; 1,3-190426

DN : 5782414538

No Kendaraan : S 9192 UH

Tanggal Produksi : 16,17,18,19-04-2026

Kadaluwarsa : Av. Cl_2 turun 3-5% / tahun (tertutup)

Parameter	Unit	Spec.	Value	Test Method
Available Cl_2	%	Min. 60	60.56	ASTM D2022-16
$\text{Ca}(\text{OH})_2$	%	Maks.19.5	17.12	ASTM C25-11
Moisture	%	3 – 5	3.0	Gravimetric

Sidoarjo, 21-Apr-26