文字记录：报警管理规则及操作规范讨论 2026年10月14日

> 录音主题：报警管理规则及操作规范讨论
> 录音时间：2026年10月14日（周三） 09:10 - 09:50 （GMT+08）
> 智能纪要：报警管理规则及操作规范讨论 2026年10月14日

说话人 1 00:00:01
Normally when the alarm is triggered in the like production room on the operator will hear the alarm sound and they will contact us. They will come. Sorry.The specific plan engineer or SMEs immediately and they will come to the room and they will do the alarm risk assessment first.So our alarm risk assessment will be prepared for each type of equipment based on is a lot.

说话人 1 00:00:44
Please, for this risk assessment, they are few, there are few classifications for the Level 1 is the, it will this attribute the along occurring the long back operation. For example, when the.Increment is during installation or other our operation that is not during the like the real production and will be required by it's like the system, it will be our report inside the like the complex picture as well. And the next level is the general reminder.And warning messages during the patch operation.For example, the for information only allows also will report only by system.And then next level is information or warning allows relation to parameter or operation mode adjustment during the patch operation.That example includes the alarm triggered by the attention of change process parameter and it will be recorded by the system and also lock in the alarm lock.I'll show you the lock in the next few slides. That sample.Is the alarm related to functional failure of the equipment?For example, the equipment failure exit process range allow being record by system and then report inside the alarm log and then trigger the incident investigation.Sorry, I got all the alarms are some of the optional only?Some and visual.Okay, see the my here some so all of them and are all these quality related learns or are some these safety only learns. Sure, just sure. Chinese. Some, some that there's one.And I should tell you what.

说话人 2 00:03:00
都包含。

说话人 1 00:03:01
用户。

说话人 3 00:03:02
Love.Oh yeah, I'm trying to with informational way, what's the purpose of gathering those alarms?

说话人 3 00:03:22
You know, what purpose you really find.So, you know, your business designs, but they don't have it. They're not necessary.

说话人 1 00:03:31
对，我们我们的第二个，它是。

说话人 4 00:03:38
是。它这个就是，不是只只写一个，一，只是一个信息上的这个报警，它为什么咱们要设一个信息上报警？它也不会做任何影响，你也没有什么行动，只是让他了解。

说话人 2 00:03:51
是这样，他这个，我举个例子啊，就是比方说现在我有一个加料，这个桶里边空了。这个时候我要提示操作人员，诶，这个桶空了，或者提示他一下，让他去换桶。这他是有行动的，这，但是这个行动呢，只是说视为一个正常。

说话人 4 00:04:11
Okay, so yeah, it's for operational purpose.Like for example, we got when we're doing the charging and the drums empty and they will do alarm to alarm the operator and the drum is empty and you can do the next operation. Okay, so yeah, yeah, yeah, yeah.

说话人 5 00:04:35
That's why I'm sorry for interrupting.I just found the entry and so I have an iron trigger by the intention of changing change classes. Give an example of why we would change classes.

说话人 1 00:05:02
请问，就这个，我们有任何的，跟这个相关的技术吗？

说话人 2 00:05:07
其实这个是其他厂区，因为我们这个应该不涉及到这个设备，这个应该是其他厂区设置的一个设备，它存在的一种模式，对于咱们这边来说的话，三，没有三的包。

说话人 1 00:05:21
Oh, okay.We don't really have the example of that.So those recess assessment is created by the other side. For example, TJ2.

说话人 6 00:05:43
So basically, this class of along is not really applied to G J4. So mostly.

说话人 3 00:05:51
主要我们是一二。

说话人 5 00:05:53
Yes, so many happened in t J 4+ L 1,2 and 4.Okay, okay.So do you get no alarm if you control the temperature to 20 degrees and your power is 20 degrees?

说话人 1 00:06:14
Do you get an alarm before it's 30 degrees or is it just an exceeds?Can you remind me when the temperature is like above 20 and under 30, do we have to alarm during this? And do you get like a warning and then.

说话人 1 00:06:38
就是比如说我们的温度报警，比如说我20度以上和30度以下，这个温度之间的报警看，我们会有吗？

说话人 2 00:06:47
有，这个就是我们说的比方说工艺要求范围是20~30，那20~30在我们这就是高高报和低低报。如果超过这个温度，它是超过工艺的要求，这个就是四类的。还有一个是高报和低报，高报的话那就是28，然后低报的话就是22，这个就是提示性的报警，就是二类的，就是预警。这个能解释吗？

说话人 6 00:07:15
So basically in the process, French, for example, if the temperature is French is 20 to 70, right?So we have a high alarm and low alarm, which is within this process.French, for example, 22 to 28.So if that exists, that French, it will trigger alarm.And then we also have the high alarm and

the lower alarm, which is for set for 20 and 30.If exceeding that temperature range will be level 4.And yeah, so over the process, right? So that's the differences. And then it's.

说话人 5 00:07:58
That example, 22 or.30A is a level.

说话人 4 00:08:02
Level two.

说话人 2 00:08:08
超过高报和低报是二类报。

说话人 6 00:08:12
Yeah, so it's only just it's just a reminder to like adjust the Jessica or control it.

说话人 1 00:08:37
就是他这边，就是如果说超过了他的高报和低报，我们不是会介入吗？

说话人 7 00:08:42
那介入是怎么介入？就是我们通常会报警。

说话人 8 00:08:46
通知到。

说话人 2 00:08:47
对，我们通知到现场的人，操作人员，然后他可能会采取一些降温啊或者收的一些措施。

说话人 8 00:08:54
是这样，就是他那个中控室的那个人员是一直都在的。他只要听到了这个报警，他会联系生产现场的人员，告诉他这块有报警了。然后让他及时进行处理。嗯，所以说呢，是这个通知呢，是能够。

说话人 7 00:09:09
然后他也想知道说这中间会出现操作工去，更改参数这些的情况。

说话人 8 00:09:16
更多的是升，直接做升降温，他不会更改参参数。

说话人 2 00:09:20
对。

说话人 6 00:09:21
Okay, so basically, so the last system is connect to the DTS.So the DTS has now will notify the operator straight away and the operator will start doing a bit of like increasing culture and building the.

说话人 6 00:09:42
To control the Pro to make sure that it's within the processor.But the parameter itself, it will not change.It was still in the processor.So it will adjust the temperature, but it will not go over the processor. So the operator have the ability to change.

说话人 4 00:10:07
不是，他是说在配方系统里头，这个操作人员有权限看到，比如说你 Level two 报警之后，在配方系统里改参数，他有这个权限。不可改。

说话人 2 00:10:19
不可参数。配方里面他是不能改这个的。不可改。

说话人 4 00:10:22
那他是怎么做升降温的？

说话人 2 00:10:24
但是他可以去调整 TCU 出口温度那个，啊，假装温度。

说话人 1 00:10:31
那我们是操作室可以直接去控制，还是说需要一个系统？

说话人 2 00:10:36

那个是操作室可以去做，但是他有第二人。电子签名，工程师，OK。都复核了。

说话人 7 00:10:43
OK， 行。

说话人 6 00:10:46
So basically the parameter is a recipe.The operator doesn't have any access to change it. It's more like changing the CPU jacket.

说话人 3 00:11:00
Is the Jackie temperature set by recipe?So if you're eating the nuts, you're right.You expect a certain Jackie temperature in the chocolate recipe just to set fault. Yeah, okay.

说话人 2 00:11:31
如果是是这样啊，如果是合成仪的话，它就是配方里边会给你一个初始的一个加热温度，然后呢，就是实际生产过程中，它按照配方去运行，那这个时候它可能会根据这个放热量的不同，添加速度不同，可能放热不一样，那这个时候我们可能对这个 TCO， 就是甲套温度，就可能有一个微调。

说话人 8 00:11:54
人为的干预。对对。但是只是干预甲套温度。

说话人 2 00:11:58
对。

说话人 4 00:11:59
它是它是通过什么 PLC 还是什么 DCS?

说话人 2 00:12:01
通过 PLC。PLC。对，对 DCS 它不是配方啊。DCS 它不是配方。

说话人 4 00:12:07
啊，就是直接就通过 PLC 那个微调一下温度就好。

说话人 3 00:12:13

对，对。

说话人 2 00:12:28
因为你的放热量会实际情况不一样，所以说那这个时候如果温度，你比方说放热很快，对吧？他可能会对于这个假的温度做一个微调，这个微调是所有的资源可以去改假的温度。嗯，会有我们这个工程师去做负责。

说话人 7 00:12:46
嗯，但是就是他的 PLC 是是有。

说话人 2 00:12:54
PLC 是可以帮控制的。

说话人 7 00:12:56
但是我们在这个方面是可以做一些稍微的就是调整。

说话人 2 00:13:05
他调整的不是配方，我的配方还是不变。我只是说额外的是去调整的是加客的颜色。

说话人 7 00:13:14
你是不是跟贾涛文不是人？

说话人 6 00:13:16
我知道贾涛文他们是。

说话人 1 00:13:18
就是。

说话人 4 00:13:20
So, okay, and then we, so, so we, yeah, and actually the operator will do a slight adjustment on the plc and to control the 0 output of the TCU and to slightly adjust the jacket temperature.And then we got E E, the signature by engineering who do the verification.

说话人 3 00:13:44

Of these are free.So you're changing.Actually, I think I, if you make your suggestion, change your recipe, change your process.So where is QA coming to this?Does any changes need? Should be the recipe parameter is now changed.They only do s adjustment on the plc itself.So you can, so your recipes is operating.Yeah, you can make different changes outside of the recipe are you have to stop your recipe with your mother goes and they go back in stress.

说话人 4 00:14:33
配方系统，它在运行的过程之中，咱们能单独的就控制一下 PLC， 让它改一下这个温度吗？还是说你得先把配方给停下来，再。

说话人 2 00:14:46
不用停，是这样，我的配方还是正常运行的。我刚才说的两个温度，就是刚才咱们说的那个 TCO 的温度。那个 TCO 的温度，我们是单独有一个按钮或者接口，可以去调整这个 TCO。

说话人 8 00:15:01
这个维度，是这样，第一个问题就是 TCU 的温度和 TCU 的控制在不在配方里？

说话人 2 00:15:10
不是它，它是在配方里边，咱们配方会给你一个初始的一个加热的温度。比方说你控温20~30，我会给一个加热温度，可能是25，处于一个中间值，对吧？比方说那我实际生产过程中，可能我的放热比较快，那这个可能我这个加热温度25度已经控制不住我这个20~30度了，那这个时候它还在运行，但是我可以通过就是 PLC 它有一个按钮，就叫 TCO。的这个温度，我从这去调整一下加热的温度，可以把25度，你比方说它发热很快，我调整到20度，或者说是18度，或者说多少度。那这个调整是刚才我说的操作员调整，工人去复核，被我们的系统自动去记录。

说话人 8 00:15:57
那第二个问题是如果说你不去调整这个 TCO 的温度的话， TCO 会不会随着你本身配方的设置，它自己去做一些微调？

说话人 2 00:16:09
不会，因为我的配方已经设定好了，它就是25度，你不人为干预的话，它就是不会去调整的。他肯定得按照合同去执行。

说话人 8 00:16:18
那这个那。不好意思，我我再多确认一下这个。

说话人 6 00:16:24
sorry, 我已经可以上传。

说话人 8 00:16:30
是，因为你配方里面是要设置给这个 TCU 设置一个标准值。

说话人 2 00:16:36
对吧？是的。

说话人 8 00:16:37
然后最开始它达到这个25度，就是开始运行的时候。它指定是通过介质去调整，嗯， TCU 里边的这个介质。对吧？对。那么你在，比如说本身体系做有轻微的升降温转数好。那你这个 TCU 按道理来说，它是会做自动的控制、控温的。

说话人 2 00:17:03
没有，应该有类似。我我明白你的意思，你的意思就是说它会根据体系的温度自动去调节这个 TCU 出口的温度。

说话人 8 00:17:10
对。

说话人 2 00:17:11
但是咱们目前还没有设计，它不是整，就是说整体的设计，就是咱们。小区啊，集团都没有这种根据体系的温度自动去调节夹套温度的，那这种要怎么过呢？

说话人 8 00:17:23
所以说 TCU 的操作就是需要人为干预的。

说话人 2 00:17:27
对，这个咱们就写到 SU 里边。

说话人 8 00:17:30
但是呢， TCU 的干预是被允许的。

说话人 2 00:17:35
被允许。

说话人 8 00:17:37
对于整个体系的这个温度的设置，还是没有办法去设的。

说话人 2 00:17:41
对，体系的温度，因为我是配方里边设好的，我才投放的。

说话人 8 00:17:45
那你干预它的这个过程，需要中断配方吗？不需要。说。不需要。

说话人 2 00:17:52
不需要出来配方。

说话人 8 00:17:53
不需要出来配方，它是直接配方还在运行着，是的，能直接改这个 TCO 的，它是一个独立的模块。

说话人 2 00:18:00
改改一下那个 TCO 的维度， TCO 的维度是只有。

说话人 8 00:18:03
TCO 是独立的模块。

说话人 2 00:18:06
对，它是独立的模块， TCO 就是独立的模块，它是接到我的本地上的。

说话人 8 00:18:12
那个。

说话人 2 00:18:15
都有。

说话人 4 00:18:18
如果就比如说我，咱们想象一个场景，如果比如说它现在是你的 Recipe 设的25度，你 TC， 你的 PLC 给改成了20度。然后之后它会自动在 Recipe 进。

说话人 2 00:18:32
对，不会，那个它会按照我20度去运行，但是我的配方还是会25度，因为我的配方是不能做任何改变的。

说话人 8 00:18:40
那它这个是运行配方的温度，还是运行人为修改的温度？

说话人 2 00:18:45
人为修改的一个温度，它是被谁最终接收到的。

说话人 4 00:18:48
啊，然后它就会一直，如果你不改的话，它就一直20度就走了。

说话人 2 00:18:52
是的。

说话人 4 00:18:52
然后直到它比如说到 load 报警以后，你再再需要做一个修改，再回去。

说话人 2 00:18:58
是的。

说话人 3 00:19:00
So do you want to say the rest of the sentence?

说话人 2 00:19:25
对，其实它和自动调是一个意思。你想一下，你跟你提供的自动平台，其实它也是要要调整的一个过程，但是你给到平台里面是只是为了一个初始的一个值，对吧？

说话人 7 00:19:41
Never before. And it's nothing. So it's just suggestions.

说话人 2 00:19:50
对，这个是属于一个，是属于一个。

说话人 2 00:20:05
是，所以说咱们把这个。

说话人 7 00:20:08
其实。

说话人 2 00:20:10
就是比方说我背包里边，它是自动调换的，它也是在后期。

说话人 2 00:20:42
对，咱只是说为了让我的体系的温度控制在我的工艺范围，所以说你的配方其实更多的要求的是你合成一体系的温度。

说话人 7 00:20:52
是的。

说话人 2 00:20:53
咱们工艺上不是按照体系的温度去做的。对，它是一个通用的一个。

说话人 7 00:21:05
是的，就是。

说话人 7 00:21:14
但是就如果。

说话人 7 00:21:34
不应该是由人来决定的。如果你要在你的设备上，你给了一个 message， 然后它执行出来。按理说大家应该不期待人在上面。然后这个 message 写的东西，它应该设置这个。我理解是希望让来。

说话人 8 00:22:12
嗯，怎么说呢？可能现在可能还没有做到说那么先进，完全的通过自动化的方式去控制假钞。

说话人 2 00:22:26
其实假钞问题不是一个工艺要求的一个。

说话人 7 00:22:44
但是。对，他的培训做的过工作。

说话人 7 00:23:02
有哪个假冒温度？如果我们能知道，因为这是因为刚才的报警。如果他要查的话。其实是。

说话人 8 00:23:16
假冒温度没有。你一直还是体系温度去控制。

说话人 7 00:23:22
刚才你们就问那个问题。

说话人 8 00:23:26
是因为你，咱体系温度设报警，达到这个报警值了之后，人为的需要干预，假套的这个温度来控制体系的温度。

说话人 7 00:23:34
是的，他其实是在这。对。

说话人 2 00:23:44
新记录里边不会，他因为他不属于咱们那个，刚才我说的那个工艺操作的一个。公益的一个参数，所以说它只会进入到我们的。

说话人 6 00:23:54
I can check this one again, but.

说话人 7 00:24:00
现场 QA 是有签字的。

说话人 2 00:24:03
不需要，因为咱后。

说话人 2 00:24:05
So for the level 1, we say it's not really accurate.For level 4 is so it's report is the extent. And for level 2, could you have a manual?

说话人 3 00:24:25
Interaction based on the alarm scene are such monitoring, which we also, it costs them for you actually act.

说话人 7 00:24:36
人为的关闭这个报警。

说话人 2 00:24:40
人为关闭，不会不会，报警我们是不会去，去关闭它的。

说话人 7 00:24:47
但是人为干预，干预。

说话人 2 00:24:50
干预报警吗？就是报警之后，人为去去采取一些措施，去让这个报警恢复到这个正常范围之内，进行参数或者某些东西，但是他不会说把这个报警就直接给消掉，他不会，他不是这样的。

说话人 1 00:25:08
So you see when for level 2, when the amount is correct, say the operator gonna be some like tiny adjustment for two, 3 step and then the amount will be like will be stop.

说话人 3 00:25:33
But it's not for only taking action.So for only means there are documents and we get your contact data, but taking action, it's not for.

说话人 4 00:25:48
他在说你那个第二列，L1、L2那块，你写的是 FIO 嘛，就是 for information only， 那块他觉得不太对，他如果就是说你要做一些措施介入的话，他就不是 for information only， 这块。

说话人 8 00:26:04
Notification 栏。

说话人 4 00:26:06
是吧？对，等于，我觉得就是咱们L2，第二行，第第三列那块，应该就是描述的有点问题。

说话人 7 00:26:19
应该是就是给到信信息的。Notification， 对吧？

说话人 3 00:26:30
Might be easier to get a copy of the alarm management procedure and just have a voice and already answer some of those questions in that procedure.Okay, so we should talk, we might have enough of that. I think probably this.

说话人 3 00:26:54
Yeah, if we get a payment of procedure, much easier to read the notes and the question was just another part of the investigation. We open sanitation investigation.

说话人 1 00:27:09
第三，如果它是 level 4所形成的调查报告是偏差报告，对吗？

说话人 8 00:27:18
对。

说话人 2 00:27:49
评简呢.

说话人 1 00:27:56

When the level 4, it's identified as level 4.So we will do their record at the along long.and then trigger the。Consider the investigation and then we'll do like to like kind of US assessment to see do will become the violation or not.Okay, I'll stop the form that we share before.When you fill it out information, make sure you review that form.

说话人 3 00:28:32
Kind of deviation is required that stage taste.So it doesn't have instant investigation rates on a little batch with that form being attached to the backtrack arch.Okay.So because it's not changed to revision seats, but like little 4 is very significant.Yes, you know, it's gonna have a direct impact on the process if you something.

说话人 5 00:28:58
But of course, the direct impact you did expect to see to reach that last year.This is certainly check on quality parameters.Do you monitor by using the alarms or do you have a backtrack on like your temperatures, for example?It's between 20 and 30 degrees.Do you check the fact record that remains in that range, or do you assume that remains in that range if there's no one?

说话人 8 00:29:42
Yes, in the batch record, we have the confirmation to confirm the alarm limit, which is correctly set in the DCS and PRC system. In the batch record. Yes, that's right. Every step.

说话人 3 00:29:59
Yes, and I think we need to confirm as well. I think, yeah, I think.But, so I think this other, this process takes the background trade off, which is a bit more quite moments over 20 minutes because the printers don't check this.They're parents.Okay, so even in the environment is miss, the attractor should have cash.I haven't seen the Lara about charts that followed for the Lara about charts as well.So yeah, the temperature is confirmed that the temperature maintains the age of it.

说话人 7 00:31:30
so, when the temperature is, we need to do some like. our purpose is to make sure that the process is within the evidence allow range. but when the rest is in the system of human, we should。

说话人 7 00:32:13
That's.And.

说话人 3 00:33:03
Yes, you can control the process.You can control the process.You can control the, can control the process. You can control the process.

说话人 7 00:33:24
So all of us can be with that number of people.So the RP should be controlled in our school. Yeah, but I'm not really, I'm manage.

说话人 3 00:33:48
Even though that's not the, that's not.So it could be possible change like that, but it's actually not expected.Are could be some platforms not very well rested.You need to understand why that, you know, don't know. Know. I don't know.So our question is the same about this situation with that.

说话人 7 00:34:51
Then the rescue in the medical should not to change the environment.So that's the number in the level 3 or the level 4 sounds like should be have when the temperature out of range.So this should be a pull up that today maybe. Okay. And then better today.

说话人 7 00:35:12
So we make it clear that oscillations will have discussion in this situation.First one, which is a lot, is that the temperature of the room.And the second thing is that how we could handle this situation.Should we trigger an activation or should we still have confidence about the message in meditated?I know which way I'm going to do the next step, and we'll ensure that I will do it.That's all this.Today, we will prepare something for better collaboration.Yeah, I think what we just want to avoid is that your operators are changing parameters on the plane to subject to their range.

说话人 3 00:35:54
As Evan says, I'm not a holiday present.I'm qualified equipment.I'm having to do a lot of that, something like that. It's.If you're validating the process, it should be validated to not solve it.And it's not, there must be a reason behind why it's not doing this.So in terms of the net of the place, important, but I think it is important that don't have going in the rate.So, you know, there is time for my main function in this.It's just that it's almost why I think this I practice.

说话人 7 00:36:39
And especially, I am the person to review the fashion of.And when I review the fashion at the recipe, okay, a lot. Okay, all 10% is okay. It's not possible.for me to review every on material for every batch. so, if we could not.

说话人 7 00:37:00
On this question, probably I am very helpful on what I would do.That's the tickets about one patch.How could I found that over change and so on?Yeah, I get your point.So what you said is if the recipe being valid.All that I made it then.It means that no matter what happened, it should stay within the correct.And it doesn't.That's all things happen.It's called this is trust our rescue and trust our equipment and made automated change up. Yeah.

说话人 3 00:37:44
And if you wait for trying to raise the deviation, then you're not usually corrected when you see it.So you might be able to see it showing.Go on to see it starts happening. But when you come to control the social deviation.

说话人 5 00:38:16
要不，要不你来。

说话人 8 00:38:20
是这样，这个今天的解释我先这样，咱下午准备一些东西，包括咱们的 SOP， 包括咱们的配方，都准备好了。

说话人 7 00:38:33
准备这3个词，然后都展示。

说话人 4 00:38:36
对。

说话人 8 00:38:38
对，就是我们配方管理的那个 SOP。配方管理的 SOP， 包括我们配方的设置，以及我们这个逻辑到底是怎么呈现的。通过这几个方面，我们下午再来，再来单独地去聊，因为这个事可能一句话两句话也说不清楚。