

# 文字记录：20260925\_212844 2026年9月25日

会议主题：20260925\_212844

上传时间：2026年9月25日（周五） 21:43（GMT+08）

智能纪要：[20260925\\_212844 2026年9月25日](#)

说话人 1 00:00:21

Hey, Mark, sorry, I just check with my team. So basically we did the assessed all the process lines like use for the pure 5 water, but we'll definitely like that. You raise a good point, will also check the pure 5 water use for cleaning. We'll do that as well.

说话人 2 00:00:45

And just to clarify, you do, I assume you do, but are you planning to use purified water for cleaning, like for the SPS equipment set, for instance? Let me double check. This one, yes, we do use the pure by water to clean the test PPS and Clive it.

说话人 2 00:01:09

Yes. So I again, I think the re, there's still probably opportunities here to improve the distribution system if it has similar gaps. Hum. And we probably need to just talk through how to manage that in the interim. For cleaning your addition to where you have processed water charges, right? Because there still could be microbial contamination risks. Maybe we can mitigate those and justify that with, you know, some of the solvent rinses and dry UPS we do subsequently. But I think it's. Probably something we need to kind of understand the scope of where these gaps exist and understand how we want to manage that. I'm in the interim until you can modify the system. Yep. So I want to make sure we capture maybe that again, I think most of the focus here was on purification, which is certainly high risk, obviously, with the water being charged to the process. But. Just what didn't want to lose light of holistically reviewing this for all of your water systems. Yep. Yeah, that's good point. I'll take note on that. And again, that might have a more immediate impact on timing potentially if there's challenges there for.

说话人 3 00:02:27

The early stage steps. Okay. Thank you. If you guys can think about that and follow up and we can have that discussion. Okay, sounds good. And then just to clarify that three weeks of validation there, is that like validation of the same, the new sampling points? Or is that a different?

说话人 1 00:02:54

Validation. Is that like equipment qualification more so? Yes, I believe so. That's include 2 weeks of sampling and also 1 weeks of like mobile back audio test. Okay. Yeah.

说话人 3 00:03:14

And then just to confirm, like internally, what would your standard be during that validation? Would it be that until you get that validated, you can't use the water for process use? So it would be three weeks like, or we would have to be down during that whole window or what? Like, would we, yeah, would we need downtime during that entire window there, essentially, or we couldn't use water? Let me double check. So you're saying like during the modification 3 weeks are we can like, like there's no careful water can be used or like there. Are you asking this kind of question? Yeah, I guess it'd be like the three weeks, one week, three weeks. So be during that seven weeks, you know, you're gonna have active construction on all these water lines plus passivation, and then you have to revalidate. Does that mean that for seven weeks we would not be able to use water and we would need a seven week downtime window?

说话人 1 00:04:23

Just check with my team. So there will be no impact for the main profile water system. Yeah, not the loop, but like all of these lines going to all of our process vessels.

说话人 4 00:04:39

不同的循环，有不同的循环循环循环过来，循环循环管路，是吧？

说话人 5 00:04:44

因为咱们主管路没有动，它只是加了，测了一个最远点。会影响其他用。

说话人 1 00:04:52

就是改进的时候，他们会他们，比方。

说话人 4 00:04:56

啥意思？这个改了之后，这个水会回到主管，是吧？不会回到主管。

说话人 5 00:05:00

不会回。

说话人 4 00:05:01

Okay, no worry for me. So here I wanna like to see this will not impact the main pipe because this is the only collected to their, you know, to their. To each of the equipment from each of the distribution point, they will not return to the pure for water tank. So you can see, you can see here, can you see the screen?

说话人 3 00:05:36

Yeah, and sorry, I understand that it won't impact the purified water loop, but what I'm saying is like the all of those clients, those are all process vessels for our process. So if we go modify that piping and have to revalidate it, that means that we can't send water to our process. Right. So I agree the loop doesn't have to come down, but will our process tanks have to not be in use because we'll have no way to send water to them because the piping, client specific piping will be under construction.

说话人 3 00:06:25

Maybe I'll send my question in an email to make it more clear. I'll work on the wording a bit of the question, if that's okay. Cuz I see we're at time here or overtime. Yeah, Andrew, you raise a good point. So like, we probably like if that's case, we will probably use the host to do the connection. Yeah, but like, like, even if you had longer hoses and you used hose like. That piping includes like the flow meters and eh, so maybe you have a portable flow meter. So like there's other things in that line besides just hard pipe, right? So maybe, yeah, so if you could explain the interim plan for how you get water to the process during this seven week window, that'd be great.

说话人 1 00:07:21

Okay, yep. Hey, I think it's a little bit overtime, but I Ju I have two more points we want to go through. So do we have time or we want to cut it off? I have to run, but I don't know if Mark, Steve, Jeremiah, others can stay on. Yeah, I think the next point is.

说话人 2 00:07:49

Probably touching what we just talked about, right? If you're gonna revalidate that. Yeah, so that ties into the discussion. I think the last one's pretty straightforward. Yeah, that's straightforward. We'll just, yeah, update our SMP. Yep. So I think that makes sense to me. So I don't need to go any more detail. I think that was pretty clear. So yeah, I think the point above we covered. So I'm probably good at this point as well.

说话人 1 00:08:10

Okay, that's good. So, yeah. We'll definitely like keep updates the Excel sheet and we'll send to back to Lily's team as possible latest the early next week. Yeah, perfect. Thank you so much. Yeah, this is very helpful discussion and thanks for preparing what you have so far. We look forward to kind of working through the rest of the actions.

说话人 2 00:08:36

我也去。

说话人 5 00:08:37

说一下。嗯，还记，还有时间。对，我是来记数。

说话人 6 00:08:43

And with that, any other kind of critical items to cover here? Again, I know we're a bit over time, but since we have some follow UPS, I'll send out some minutes. But maybe one more chance for any final items here.

说话人 6 00:09:02

Nothing else for my end at this point. Yes, we, okay, we're good for the day. Okay, definitely more discussion to come. So yeah, good start. Yeah, you appreciate those updates to the sheet and the additional details there. I will look forward to receiving that to by early next week and I'll connect with Simon for establishing some additional time here for us. So.

说话人 2 00:09:24

Thank you very much, everybody. Nice weekend. Hey, Mark.

说话人 1 00:09:30

Sorry, do you have a quick minute? Sure. I can talk for a second. Sorry, just really quick question. I think you can just answer like in a minute. So about like the humidifiers, nitrogen. So well, I think from last discussion, we decide to move the humidifier nitrogen, white nitrogen in the classy area. And we, but we purchased the sterilized bag for the Wi Fi. Is that need to be moved to this class greedy Gracie area or it can be lived in the CNC area and connect used. Expect the aesthetic connection to connect to the, the, to get into the C area, class C area. So you're asking about the type where to make that connection. Yeah, so the purchase to the. So we see. Yeah, yeah, yeah, yeah.

说话人 2 00:10:40

Okay, yeah, I think that's probably a good discussion to have with the broader team. Yeah, I my initial thought is maybe doing that in this great C area would make the most sense, but I yeah, be worth maybe discussing that with the broader team and understanding what kind of what your challenges might be to doing that. There's any limitations. Okay, okay. So, yeah, I don't know. We have the right folks on the call this point to kind of make that decision or talk through that, but I think it's a good topic to discuss and certainly we need to align on the strategy there for sure. Okay, okay. Sounds good. Yeah, we'll definitely like share sh, like come up or questions and sh chat with you guys like in next week. Absolutely. And it'd be good if you have a missionally like a proposal or thoughts from your end on what kind makes the most sense logistically, then we can talk about.

说话人 1 00:11:35

Well, that's appropriate. Okay. Sounds good. Yep. Yep. Thanks for everybody's time. Absolutely. Yep. Thank you again. Have a good weekend. Thanks. Bye, everyone.