Drawing No. 902-007-002-000-00219 | Revision 1

DO NOT SCALE THIS DRAWING | ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED | IF IN DOUBT ASK

This drawing is the property of Asymchem Limited, It is an offence to copy or reproduce this drawing without the consent of Asymchem Limited.
© Copyright ASYMCHEM LIMITED

SCALE 1:1 MILLIMETRES

1:1 SIZE OF THIS SCALE BAR – 100mm
CHECK – THIS DRAWING MAY HAVE BEEN REDUCED/ENLARGED

THESE LAYOUTS ARE BASED ON ORDNANCE SURVEY LARGE SCALE MAPPING WITH THE PERMISSION OF THE CONTROLLER OF HM STATIONARY OFFICE. ©CROWN COPYRIGHT. (IF APPLICABLE TO THIS DRAWING)
UNAUTHORISED REPRODUCTION INFRINGES CROWN COPYRIGHT AND MAY LEAD TO PROSECUTION OR CIVIL PROCEEDINGS

GENERAL NOTES & LEGEND:

1. HIGH PERFORMANCE ELECTRONIC FLOW CONTROL VALVE.
2. TCU SET POINT SET REMOTELY VIA PLC AND PACKAGE STARTED VIA PLC COMMS SIGNAL.

RELIEF VENT 902-007-002-000-00159 (TP 013) — HOLD-RV-E1E-0-9025832 — RELIEF VENT 902-007-002-000-00220

PROCESS VENT 902-007-002-000-00159 (TP 014) — HOLD-SV-E2E-0-9025834 — PROCESS VENT 902-007-002-000-00221

NITROGEN 65 Barg 902-007-002-000-00159 (TP 002) — 10-N-E2E-0-9025830

HYDROGEN 65 Barg 902-007-002-000-00159 (TP 001) — 10-N-E2E-0-9025835

NITROGEN 0.8 Barg 902-007-002-000-00159 — 15-N-A3E-0-9025837

RAW MATERIAL/DILUTION SOLVENT (TP 015) — H9824 — HC9832 — 25-P-A2E-0-9025840

CIP DISTRIBUTION 902-007-002-000-00221

CIP INLET (TP 008) — H9826 — HC9830 — V9848 — 15 V9872 — 25-P-A2E-0-9025841

CRASH COOL 907-007-002-000-00220

CV 010 — V9869 — V9870

CV 001 — V9871

PSV 013 SET AT 80 Barg — HOLD-RV-E1E-0-9025848

PI 001 HH H L — HOLD-H-E2E-0-9025847 — V9868

PIT 001

FI 003 — FIC 003 — NOTE 1 — FT 003 — C — V9866

FCV 003 — CV 003

V9865

R24-BT03

10-H-E2E-0-9025849

10-H-E2E-0-9025853 — 10 V9856

10-P-E2E-0-9025845

LI 001 HH H L — PI 020 HH H L LL — LIT 001 — PIT 020 — 15-SV-A2E-0-9025842

V9863 — V9862

N1 25 — N7 25 — N5 25 — N8 15 — N3 15 — N4 50/25 — SB9864

V9849

FCV 005 — NOTE 1 — FT 005 — FIC 005 — FI 005 H — V9867

SG 9851 — R24-BT01 — SG 9852

TI 020 H L — TT 020

N2 25 — 25x10 — CV 012 — V9858 — 10-P-E2E-0-9025844 — V9859

FIC 001 H L — FT 001 — C — CV 006

SET AT 80 Barg PSV 015 — SIC 001 — R24-MP01

N2 15 — N5 — N3 10 — N1 10 — N4 10

R24-PH01

PI 003 HH H L — PT 003 — 850

10-H-E2E-D-9025850 — V9847 — HYDROGEN 902-007-002-000-00220

10-P-E2E-D-9025846 — RAW MATERIALS 902-007-002-000-00220

SERVICE AREA | HYDROGENATION ROOM

TP 016 — 15 V9843 — 20-HT-A1E-D-9025852

TP 017 — 15 V9846 — 20-HT-A1E-D-9025851

15 V9840 — 15 V9841 — 15 V9842 — 15 V9844 — 15 V9845

R24-TCU04 — NOTE 2 — H9827 HC9847 — H9829 HC9848

SUPPLIERS NAME	EQUIP No.	CAPACITY	M.O.C
	R24-BT01	0.22m³	316L SS
	R24-BT02	0.22m³	316L SS
	R24-MP01	0.02m³/Hr	316L SS
	R24-MP02	0.02m³/Hr	316L SS
	R24-BT03	0.01m³	316L SS
	R24-SM01		316L SS
	R24-PH01	LIQUID – 1.1m³ GAS – 0.4m³	316L SS
SUPPLIERS REFERENCE N°	R24-TCU04	4kW HEATING 3.5kW COOLING	SS C/W COPPER SOLDERED EVAPORATOR

ALL INSTRUMENT TAG NUMBERS PRECEEDED BY R24

PIPING LINE NUMBERS:
ALLOCATED:
LAST NUMBER USED –

VALVE NUMBERS:
ALLOCATED:
LAST NUMBER USED –

Details

REV	DATE	DRN	CHANGE CONTROL	CHKD	DATE

Details

REV	DATE	DRN	CHANGE CONTROL	CHKD	DATE

Details

REV	DATE	DRN	CHANGE CONTROL	CHKD	DATE

Details
ORIGINAL P&ID RE-DRAWN TO ASYMCHEM P&ID STANDARD

REV	DATE	DRN	CHANGE CONTROL	CHKD	DATE
1	26/11/2025	P.B.	20250015		

Drawing Status: DETAILED DESIGN

ASYMCHEM
Asymchem Limited,
Ramsgate Road,
Sandwich, Kent.
CT13 9ND

Title
PIPING AND INSTRUMENT DIAGRAM
CONTINUOUS HYDROG - T-2502

Global Asymchem Country ID	44	UK Site Identification Code	SW
Drawn		Date		Scale	N.T.S.
Checked		Date		Mapping Tile	
Approved		Date		Cross Ref	

Drawing No 902-007-002-000-00219 | Revision 1

This drawing has been prepared at scales shown on plot for paper size – A1