

180 Trowers Rd Unit 16 Vaughan, Ontario L4L 8A6 Brantford: (519) 756-8962 Toronto: (416) 665-6555 Woodbridge: (905) 851-9119 Toll free: 1-877-243-9664 Website: www.crownfire.ca

Range Hood Systems Report

Name: LJ KUSINA

Address: 7690 MARKHAM ROAD

City: MARKHAM
State: ONTARIO
Zip: L3S 4S1

Telephone: 416-881-3528

Store No.:

Owner or Manager:

Date of Service		Time	A.M.		P.M.	
NOVEMBER 16, 2012		10:00	х			
Annual Semi-Annual		Recharge	Installation		Renovation	
X						
Location of System Cynlin	nders				UL 300	
AT HOOD						
Manufacturer		Model #	Wet	:	Dry Chemical	
PROTEX	II	Х				
Cylinder Size Master		Cylinder Size Slave		Cylinder Size Slave		
6 GALLON		N/A		N/A		
Fuel Shut-Off		Electric	Gas		Size	
			Х		1 1/4	
Serial Number		Last Hydro Test Date		Last Rech	arge Date	
45W225						
Manufacturer's Manual Re	ce					
Page No.:	ving No.:		Date:			

Cooking Appliance Locations: Left to Right

XXXXX	
OO FF WW G	

		Yes
1.	All appliances properly covered w/correct nozzles	✓
2.	Duct and plenum covered w/correct nozzles	✓
3.	Check positioning of all nozzles	✓
4.	System installed in accordance w/MFG UL listing	✓
5.	Hood/duct penetrations sealed w/weld or UL device	✓
6.	Check if seals intact, evidence of tampering	✓
7.	If system has been discharged, report same	
8.	Pressure gauge in proper range (if gauged)	✓
9.	Check cartridge weight (if applicable)	
10.	Hydrostatic test date	N/ A



180 Trowers Rd Unit 16 Vaughan, Ontario L4L 8A6 Brantford: (519) 756-8962 Toronto: (416) 665-6555 Woodbridge: (905) 851-9119 Toll free: 1-877-243-9664 Website: www.crownfire.ca

11.	6 year maintenance date	
12.	Inspect cylinder and mount	√
13.	operate system from terminal link	√
14.	Test for proper operation from remote	√
15.	Check operation of micro switch	√
16.	Check operation of gas valve	√
17.	Clean nozzles	4
18.	Proper nozzle covers in place	· ·
19.	Check fuse links and clean	· ·
20.		· ·
	Replaced fuse links	
21.	Check travel of cable nuts/S-hooks	√
22.	Piping & Conduit securely bracketed	✓
23.	Proper separation between fryers & flame	✓
24.	Proper clearance-flame to filters	✓
25.	Exhaust fan in operating order	✓
26.	All filters in place	✓
27.	Fuel shut-off in on position	✓
28.	Manual & Remote set/seals in place	✓
29.	Replace systems covers	✓
30.	System operational & seals in place	✓
31.	Slave system operational	
32.	Clean cylinder & mount	✓
33.	Fan warning sign on hood	
34.	Personnel instructed in manual operation of system	✓
35.	Proper hand portable extinguishers	
36.	Portable extinguishers properly serviced	✓
37.	Service & Certification tag on system	✓
38.	Note Discrepancies or Deficiencies Below	✓

Comments

- KITCHEN REQUIRES A K-CLASS EXTINGUISHER.

On this date, this range hood fire supporession system was inspected and operationally tested in accoredance with the fire suppression system reaquirements of NFPA17 or 17A, 96 and the manufacturer's manual, with the results indicted above.

VICTOR IABONI (CFAA #:19-911358)		NOV 15, 2012	11:00	Х		
Service Technician	Permit No.	Date	Time	AM	PM	Customer's Authorized



180 Trowers Rd Unit 16 Vaughan, Ontario L4L 8A6

Brantford: (519) 756-8962 Toronto: (416) 665-6555 Woodbridge: (905) 851-9119 Toll free: 1-877-243-9664 Website: www.crownfire.ca

Agent



180 Trowers Rd Unit 16 Vaughan, Ontario L4L 8A6 Brantford: (519) 756-8962 Toronto: (416) 665-6555 Woodbridge: (905) 851-9119 Toll free: 1-877-243-9664 Website: www.crownfire.ca

Fire Extinguisher / Fire Hose report

Customer Name: LJ KUSINA

Address: 7690 MARKHAM ROAD

City: MARKHAM

Contact:

Technician: VICTOR IABONI

Inspection Date: NOVEMBER 16, 2012

Site:

Lengend

R/C Re-Charge

6YR 6YR Maintenance

H/T Hydro-Static
 Testing

I/R Inspect & Re-Rack

P Pulled For Service

Condemned

С

No.#	Hose Location	Size & Type	Manufacture	Extinguisher #	Manufacture Date	Last H-Test	Next H-Test	Next 6 Year	Remarks
1	@ HOOD	10LB ABC	WILL	1993	2004	N/A	2016	N/A	6 YEAR
2	FRONT ENTRANCE	5LB ABC	KIDDE	457546	2010	N/A	2022	2016	ОК
3	KITCHEN								REQUIRED



180 Trowers Rd Unit 16 Vaughan, Ontario L4L 8A6 Brantford: (519) 756-8962 Toronto: (416) 665-6555 Woodbridge: (905) 851-9119 Toll free: 1-877-243-9664 Website: www.crownfire.ca

Emergency lighting / Exit Sign Report

Customer Name: LJ JUSINA

Address: 7690 MARKHAM

ROAD

City: MARKHAM

Contact:

Technician: VICTOR IABONI

Inspection Date: NOVEMBER 16, 2012

Site:

Lengend
- Less / Greater
P Pass
F Fail
RB Requires
Batteries
NR Unit Needs
Replacing

Emergency Lighting Annual Inspection Form

Type:	(U) = Emergency Light Unit	C) = Comb	o Unit	(R) = Remote Head		(X) = Exit Sign	
Unit Type	Location	Time	Pass or Fail	Unit Voltage	Unit Watts	# Of	Size Of Batteries
С	FRONT STORE	30	PASS	6V	36W	1	6V 5.5AH
		MIN					
С	AT WASHROOM	30	PASS	6V	36W	1	6V
		MIN					
R	MEN\'S WASHROOM						
R	WOMEN\'S WASHROOM						
R	KITCHEN						
R	BACK OF KITCHEN						

Remarks

- UNABLE TO FIND BATTERY UNIT. OWNER DID NOT KNOW. POSSIBLY REMOVED. MUST RETURN TO INVESTIGATE.

Records Must Be Available Upon Fire Departments Request for Min 2 Years