

Deficiencies & Recommendations

Customer Name: MENU FOODS OPERATING LTD.

Address: 7535 FINANCIAL DRIVE





City: BRAMPTON

Technician 1: WILL

Technician 2: DFGS

Inspection Date: AUGUST 8, 2012

Summary

		Yes	No
A.	System in trouble on arrival		
B.	Does System Require Fire Watch		
C.	System left clear and operational		
D.	Has Customer & Fire Department been notified		

Deficiencies & Recommendations

Customer Name: MENU FOODS OPERATING LTD.

Address: 8 FALCONER DRIVE

City: STREETSVILLE

Technician 1: WILL

Technician 2: DFSG

Inspection Date: AUGUST 7, 2012

Summary

		Yes	No
A.	System in trouble on arrival	✓	
B.	Does System Require Fire Watch		✓
C.	System left clear and operational		✓
D.	Has Customer & Fire Department been notified		✓

Fire Extinguisher / Fire Hose report

Customer Name: MENU FOODS
OPERATING LTD.

Address: 7535 FINANCIAL DRIVE

City: BRAMPTON

Contact: SDG

Technician: WILL

Inspection Date: MAY

Site: ddfgdsdfg

Lengend

R/C	Re-Charge
6YR	6YR Maintenance
H/T	Hydro-Static Testing
I/R	Inspect & Re-Rack
P	Pulled For Service
C	Condemned

No. #	Hose Location	Size & Type	Manufacture	Extinguisher #	Manufacture Date	Last H-Test	Next H-Test	Next 6 Year	Remarks
1	TRUCK DRIVER ENTRANCE	10LB ABC	PY	4956	1993	05	17	23	OK
H1	ADJ TO TRUCK DRIVER ENTRANCE	75'	HOSE	1 1/2	10		15		OK
2	FORKLIFT E5300W	5LB ABC	AMX	997894	10		22	16	OK
3	LUNCH ROOM	10LB ABC	BUCK	79518	05		17	23	OK
4	LUNCH ROOM	10LB ABC	PY	4932	93	05	17	23	OK
5	PUSH DOLLEY TRUCK	2.5LB ABC	SF	470920	05		17	11	6 YR
6	BATTERY CHARGE STATION	10LB CO2	AMX	736147	07		12		HT
7	BY ELEC PANEL AT CHARGE STATION	10LB ABC	BUCK	81138	05		17	23	OK
8	EAST CENTER PILLAR ON WALL	10LB ABC	BUCK	81168	05		17	23	OK
9	SOUTH EAST COLUMN/PILLAR	10LB ABC	BUCK	81148	05		17	23	OK
10	SOUTH CENTRE PILLAR	10LB ABC	AMX	811	98	11	23	17	OK
11	SOUTH WEST CENTRE PILLAR	10LB ABC	BUCK	81151	05		17	23	OK
12	SOUTH WEST CORNER PILLAR	10LB ABC	KIDDE	675385	05		17	23	OK
13	WEST PILLAR ON WALL	10LB ABC	FLAG	959791	05		17	23	OK
14	NORTH WEST CORNER BY ELEC	10LB ABC	SF	24456	00	11	23	17	OK
15	NORTH BAY DOOR #3	10LB ABC	BUCK	81179	05		17	23	OK
H2	PILLAR ADJ TO BAY DOOR #3	75'	HOSE	1 1/2	10		15		OK
16	NORTH BAY DOOR #1	10LB ABC	FLAG	960903	03		15	21	OK
17	SOUTH WEST WEST CENTRE PILLAR	10LB ABC	SF	518294	05		17	23	OK
18	CENTRE PILLAR	10LB ABC	BUCK	280366	07		19	25	OK
19	FORKLIFT E5301W	5LB ABC	AMX	997903	10		22	16	OK
20	NORTH CENTRE PILLAR	10LB ABC	BUCK	81152	05		17	23	OK
21	SOUTH EAST CENTRE PILLAR	10LB ABC	BUCK	79812	05		17	23	OK
H4	SOUTH EAST	75'	HOSE	1 1/2	10		15		OK
22	FORKLIFT E5303W	5LB ABC	AMX	997897	10		22	16	OK
23	OFFICE	10LB ABC	AMX	86784	99	11	23	17	OK
24	SPARES UNDER SINK	2.5LB ABC	SENTRY	309781	08		20	14	OK
25	SPARES UNDER SINK	2.5LB ABC		462305	08		20	14	OK
26	SPARES UNDER SINK	2.5LB ABC		209705	08		20	14	OK

Fire Extinguisher / Fire Hose report

Customer Name: MENU FOODS
OPERATING LTD.

Address: 8 FALCONER DRIVE

City: STREETSVILLE

Contact: BUM

Technician: WILL

Inspection Date: MAY 2013

Site: BUM

Legend

R/C	Re-Charge
6YR	6YR Maintenance
H/T	Hydro-Static Testing
I/R	Inspect & Re-Rack
P	Pulled For Service
C	Condemned

No. #	Hose Location	Size & Type	Manufacture	Extinguisher #	Manufacture Date	Last H-Test	Next H-Test	Next 6 Year	Remarks
42	UPSTAIRS COMPUTER EGRESS DOOR	5LB ABC	SF	451836	06		18	24	REFURB
32	EXT IN GARBAGE ROOM	5LB ABC	AMX	924187	05		17	23	REFURB
22	EXT #10	5LB ABC	SF	451825	06		18	24	REFURB
17	EXT #40	5LB ABC	FLAG	613022	05		12	23	REFURB
45	2NS FL. SERVER ROOM	5LB ABC	AMX	613616	12		24	18	NEW
9	EXT #45	10LB ABC	FLAG	22246	99	12	24	18	REFURB
25	EXT #33	10LB ABC	BUCK	79519	05		17	23	REFURB
24	EXT #41	10LB ABC	SF	95619	99	12	24	18	REFURB
1	EXT #46	10LB ABC	AMX	630125	07		19	13	OK
H1	N EAST WALL	75'	HOSE	1 1/2	99	09	12		HT
2	EXT #42	5LB ABC	AMX	897714	11		23	17	OK
H2	S/E PILLAR	75'	HOSE	1 1/2	91	10	13		OK
3	SHIPPING COLUMN	10LB ABC	PY	140	93	07	19	13	OK
4	EXT #39	10LB ABC	AMX	942526	10		22	16	OK
5	EXT #35	10LB ABC	FLAG	68997	93	07	19	13	OK
6	EXT #43	10LB ABC	AMX	942022	10		22	16	OK
H3	ADJ TO SHIPPING DOOR #1	75'	HOSE	1 1/2	02		07		HT
7	EXT #44	10LB ABC	AMX	62189	96	08	20	14	OK
8	FORKLIFT ES302W	5LB ABC	AMX	997926	10		22	16	OK
9	EXT #45	10LB ABC	FLAG	179462	93	98	10	16	HT
10	ES30SW FORKLIFT	5LB ABC	AMX	997929	10		22	16	OK
11	FORKLIFT ES304W	5LB ABC	AMX	997930	10		22	16	OK
12	EXT 38	10LB ABC	BUCK	65076	03		15	21	OK
H4	ON FIRE EXT PILLAR #38	75'	HOSE	1 1/2	10		15		OK
13	ADJ TO NL 40-11	10LB ABC	FLAG	552378	91	07	19	13	OK
14	MAITENANCE FORKLIFT MODEL #E502	5LB ABC	AMX	997944	10		22	16	OK
15	FORKLIFT CHARGING STATION EXT #47	10LB CO2	AMX	736130	07		12		HT
16	EXT #37	10LB ABC	SF	36659	01		13	19	OK
17	EXT #40	5LB ABC	FLAG	114928	99		11	17	HT
18	EXT BESIDE SORTING WRAPPING	5LB ABC	AMX	997943	10		22	16	OK
19	FORKLIFT #E5308W	2.5 LB ABC	SF	539367	10		22	16	OK
20	FORKLIFT #E537W	5LB ABC	AMX	997933	10		22	16	OK
21	PILLAR ADJ TO PALLETIZER	10LB ABC	DIA	508236	90	02	14	20	OK

22	BESIDE NH 41-11	5LB ABC	AMX	997938	10		22	16	OK
23	EXT #34	10LB ABC	PY	343218	88	01	13	19	OK
24	EXT #41	10LB ABC	SF	531451	06		18	12	6 YR
H6	FIRE EXT PILLAR #41	75'	HOSE	1 1/2	10		15		OK
25	FIRE EXT #33	10LB ABC	BUCK	78885	05		17	11	6 YR
26	EXT #4	5LB CO2	AMX	493295	10		15		OK
H7	PILLAR ADJ TO SHIPPING DOOR #9	75'	HOSE	1 1/2	10		15		OK
27	O/S ELECTRICAL RM MAIN EXT #10	5LB ABC	SF	717216	03		15	21	RC
28	I/S ELECTRICAL RM IN MEAT AREA	10LB ABC	SF	531422	06		18	12	6 YR
29	MAIN ENTRANCE FROM GRAIN TO MEAT	10LB ABC	FLAG	62693	95	09	21	15	OK
30	ENTRANCE FROM MEAT ROOM TO COOLER	10LB ABC	SF	531439	06		18	12	6 YR
31	EXT #1	5LB ABC	AMX	130938	98	11	23	17	OK
32	EXT IN GARBAGE ROOM	10LB ABC	SF	417964	93		05	11	CONDEMN H-TEST
33	EXT #3	10LB ABC	PY	4603	94	06	18	12	6YR
34	TUNNEL ROOM TO RIGHT OF MAIN DOOR	10LB ABC	BUCK	81143	05		17	11	6YR
35	EXT #22	10LB ABC	SF	27602	01		13	19	OK
36	KITCHEN MEX NEXT TO GARBAGE ROOM	19LB ABC	SF	36606	01		13	19	OK
37	OFFICE LUNCH ROOM	GLB ABC	SF	202743	03		15	21	OK
38	MAIN RECEPTION AREA	5LB ABC	SF	43776	98	09	21	15	OK
39	COPY ROOM #1	5LB CO2	AMX	766	93	08	13		OK
40	COPY ROOM #2	10LB ABC	AMX	545760	06		18	12	6YR
41	ENTRANCE TO LOBBY BY BOARD ROOM	GLB ABC	SF	746639	04		16	22	OK
42	UPSTAIRS COMPUTER EGRESS DOOR	5LB ABC	SF	96999	00		12	18	HT
43	END OF HALLWAY ON 2ND FL	5LB ABC	SF	236168	07		19	13	OK
44	2ND FL O/S MENS W/R	5LB CO2	AMX	205	93	08	13		OK
45	2ND FL. SERVER ROOM	5LB ABC	SF	150851	97		09	15	HT
46	LAB 2ND FL.	5LB ABC	BUCK	74628	06		18	24	OK
47	MENS LOCKER RM	10LB ABC	BUCK	81322	05		17	11	6 YR
48	EXT #24	10LB ABC	AMX	628787	07		19	13	OK
49	PRODUCTION LUNCH ROOM	5LB ABC	AMX	997942	10		22	16	OK
50	EXT #29	5LB ABC	BUCK	766666	08		20	14	OK
51	EXT #26	5LB ABC	SF	57814	99		11	17	HT
52	EXT #25	10LB ABC	AMX	314521	91	03	15	21	OK
53	PILLAR ADJ TO CRONES LABELER	10LB ABC	SF	51468	01		13	19	OK
54	EXT #23	5LB ABC	AMX	997945	10		22	16	OK
55	EXT #18	5LB CO2	AMX	765	93	08	13		OK
56	EXT #19	10LB ABC	SF	17516	99		11	17	HT
57	EXT #28	10LB ABC	SF	531455	06		18	12	6YR
H8	ON EXT PILLAR #28	75'	HOSE	1 1/2	10		15		OK
58	IN CANNING AREA O/S MAINT DOOR	5LB ABC	AMX	177636	99	11	23	17	OK
59	EXT #17	5LB ABC	PY	87929	95	07	19	13	OK
60	O/S MAINT LOCKER RM	10LB ABC	AMX	971022	08		20	14	OK
61	EXT #12	10LB ABC	PY	169	90	06	18	12	6YR

62	EXT DOOR BY EXT THE LATHE #11	10LB ABC	SF	531447	06		18	12	6YR
63	EXT #14	10LB ABC	PY	1821	93	07	19	13	OK
64	EXT #7 RACK EXT DOOR BY STEEL	GLB ABC	FLAG	333429	08		20	14	OK
65	EXT #16 BY EXT STORAGE	10LB ABC	SF	531549	06		18	12	6YR
66	EXT STORAGE	10LB ABC	FLAG	99565	96	07	19	13	RC
67	EXT STORAGE	10LB ABC	SF	44398	07		13	19	RC
68	EXT STORAGE	5LB ABC	KIDDE	836849	09		21	15	OK
69	EXT STORAGE	5LB ABC	FLAG	274668	99	10	22	16	RC
70	EXT STORAGE	GLB ABC	FLAG	225765	98	11	23	17	OK
71	EXT STORAGE	5LB ABC	AMX	220152	2005		17	23	RC
72	EXT STORAGE	5LB ABC	AMX	841786	10		22	16	OK
73	EXT STORAGE	5LB ABC	SF	725545	03		15	21	OK
74	WELDER	5LB ABC	SF	362140	05		17	23	OK
75	MAINT. MEX MECH STORAGE ON SHELF	5LB CO2	SENTRY	2698	96	06	11		HT
76	EXT #9	5LB CO2	AMX	206	93	08	13		OK
77	EXT #15	10LB CO2	AMX	230269	09		14		OK
78	EXT #31	5LB ABC	AMX	997937	10		22	16	OK
79	EXT #27	10LB ABC	BUCK	81991	05		17	23	OK