

Notes

FIRE LEGEND

- Wall Fire Rating Minimum of 30 Minutes
- Wall Fire Rating Minimum of 60 Minutes
- Floor and Ceiling Void Cavity Barrier 30 minutes
- Compartment floor Cavity Barrier 30 minutes
- FD30S 30 min Fire Door with Smoke seal (S)
- 30 min cavity Barrier
- 60 min cavity Barrier
- Travel Distance
- Refuge call point
- Final Fire Exit

P01	18/02/2019	Draft Issue to Client
Rev	Date	Description

Key Plan

Project Status

Strategic Design Advisor Phase 1

Client



Project

DEOP

Defence Infrastructure Organisation, Kingston Road,
Sutton Coldfield, B75 7RL

Project Description / Site

Defence Estate Organisation Programme

SiteName

Project Address

n/a

Building Type

Drawing Title

GROUND FLOOR
FIRE STRATEGY

Originator Logo



Drawn By ST Date 12.02.19

Checked By Date

Approved By Date

Drawing Number

WHIT10104500-MAC-B304-GF-DR-A-1002

Sheet No. 1 of 3 Scale As indicated Orig. Sheet Size @ A1 Rev. P01

Data Security Classification

OFFICIAL SENSITIVE

Suitability

A3