





ANALYTICAL LABORATORY
4669 SHEPHERD TRAIL
ROCKFORD, IL 61103-1294
analyticalabs@evoqua.com

CERTIFICATE OF ANALYSIS

Analysis No: 101532



Branch Org. Code: 013
PO Number:



Supply/Source:
Sample Point: Well Water
Description: Well (Deep)

CATIONS	RESULT	UNITS	ANIONS	RESULT	UNITS
Calcium	128.402	mg CaCO ₃ / L	Fluoride	<0.100	mg CaCO ₃ / L
Magnesium	70.987	mg CaCO ₃ / L	Chloride	469.132	mg CaCO ₃ / L
Sodium	341.408	mg CaCO ₃ / L	Bromide	0.535	mg CaCO ₃ / L
Potassium	<1.800	mg CaCO ₃ / L	Nitrate	<0.200	mg CaCO ₃ / L
Aluminum	<0.025	mg/L	Phosphate	<0.400	mg CaCO ₃ / L
Barium	0.107	mg/L	Sulfate	18.431	mg CaCO ₃ / L
Copper	<0.010	mg/L			
Iron	1.326	mg/L			
Manganese	2.857	mg/L			
Strontium	0.362	mg/L			
Zinc	<0.010	mg/L			
Total Hardness	199.39	mg CaCO ₃ / L			

OTHER PARAMETERS	RESULT	UNITS	OTHER PARAMETERS	RESULT	UNITS
Total Suspended Solids	<1.00	mg/L	Reactive Silica	18.249	mg CaCO ₃ / L
Conductivity	1276	µS/cm	Turbidity	57.40	NTU
pH	6.31	-	Bicarb (HCO ₃)	75.05	mg CaCO ₃ / L
CO ₃	0.00	mg CaCO ₃ / L	OH	0.00	mg CaCO ₃ / L
Free CO ₂	83.61	mg CaCO ₃ / L	TOC	2.81	mg/L

Free CO₂: Derived from Alkalinity and pH

ANALYZED BY: Colton Nickel