

DALMIA CEMENT (B) LIMITED – CEMENT PLANT ARIYALUR



INSTRUMENTATION MANUAL

Issue No. 01Rev. No: 02Effective Date: 20.09.2017SOP/INST/013Issued By: M.RApproved By: HOD - INSTRUMENTATION

SOP for Checking of Dampers

Scope: Checking of Dampers.

Responsibility: Instrumentation technician.

Accountability: Instrumentation - Section Engineer.

PPE:

- Safety helmet
- Safety shoe
- Mask
- Goggles
- Hand gloves
- Safety belt

Tools required:

- Multimeter
- Tester
- Screw Driver
- Hand Blower

Hazard Analysis:

Risks associated Mitigating Measures

Electrocution Use Insulated hand glove



DALMIA CEMENT (B) LIMITED - CEMENT PLANT ARIYALUR



INSTRUMENTATION MANUAL

Issue No. 01	Rev. No: 02	Eff	Sective Date: 20.09.2017	SOP	/INST	/013
Issued By: M.R			Approved By: HOD - INST	RUMI	ENTAT	'ION

SOP for Checking of Dampers

Procedure:

- 1 Use nose mask, goggles.
- Carry all the necessary tools in a tool bag.
- Ensure the signal interlocks and block the interlock if necessary. 3
- If the height is more than 1.5 meters, use safety belt.
- Line clearance to be taken before attending the Dampers.
- Before starting the job, check the Damper operation in local mode for ensuring the energy isolation.
- Clean the junction box and limit switches box with blower.
- Check the limit switch contacts by using multi meter with insulated probes.
- Check the condition of Pinion gear and limit switch assembly.
- 10 Use manual wheel and declutch to ensure dosing valve full open and full close and Observe limit switches operation.
- 11 Ensure 4-20 milli amps converter output while Damper is in full close condition was 4 mA and 20 milli amps in full open condition.
- 12 Ensure torque switches operation.
- 13 Return the line clearance duly signed copy for Electrical Department.
- 14 Operate from local push button station to ensure full open and full close of Damper
- 15 Compare physical opening of Damper with % opening indicated on Damper.
- 16 Then operate from CCR by % Set point and observe feed back of Damper open/close and confirm the signal in CCR.
- 17 Retrieve all the blocked signals.
- 18 Give the clearance to operation.



Issue No. 01

DALMIA CEMENT (B) LIMITED – CEMENT PLANT ARIYALUR



SOP/INST/013

Reviewed by:

INSTRUMENTATION MANUAL

Effective Date: 20.09.2017

Analysis by:

Issued By: M.R Approved By: HOD - INSTRUMENTATION

SOP for Checking of Dampers

Emergency / Emergency Shut OFF:

Rev. No: 02

1. If any unconsciousness is there, give First aid and inform to the Safety department or Call Emergency number 3108/9865152222/9750963761.

Records/Annexure:

Job Safety Analysis

1. JSA as enclosed below.

JOB SAFETY ANALYSIS:(JSA)

Job: CHECKING OF

	DAMPERS				
Title of employee doing job: INST - TECHNICIAN	Supervisor: SECTION ENGINEER	Department: INSTRUMENTATION	Section:RAWMILL,PYR O ,CEMENT MILL &PACKING PLANT	Approved by:	
Req'd/recommended PPE: SAF	ETY HELMET, SAFETY SHOES	S, GOGGLES, DUST MASK, HAND (GLOVES		
Sequence of Basic Job Steps	Potential Hazards	Recommended Safe Job Procedure	What Could Go Wrong	Corrective Action	
1. SWITCH OFF THE ISOLATOR & TAKE THE LINE CLEARANCE.	MOVEMENT OF THE ACTUATOR WHILE CHECKING.	ENSURE THE LINE CLEARANCE IS OBTAINED.	RESULT IN ELECTROCUTED,INJU RY.	ENSURE FEEDER ISOLATION AND FOLLOW THE LOTO SYSTEM	
2. OPEN THE JUNCTION BOX & BLOWER THE TERMINAL BLOCKS.	DUST MAY COME OUT OF THE JUNCTION BOX	WEAR GOOGLES,HAND GLOVES & NOSE MASK BEFORE BLOWERING	COUGHING,EYE IRRITATION MAY OCCUR	USE GOOGLES, DUST MASK AND HAND GLOVES	
3.CHECK THE OPEN/CLOSE LIMIT & TORQUE SWITCHES BY USING MULTIMETER WITH INSULATED PROBES	LIVE SUPPLY IS EXPOSED AT THE MEASURING POINT NEARTHE PROBE	ENSURE THE PROBE IS PROPERLY INSULATED	RESULT IN ELECTROCUTED	USE INSULATED HAND GLOVES	
3. TIGHTEN THE TERMINAL BLOCKS USING SCREW DRIVER/TESTER.	LIVE SUPPLY IS EXPOSED AT THE METTALIC PART OF THE SCREW DRIVER/TESTER.	ENSURE THE METTALIC PART OF THE TESTER/SCREW DRIVER IS INSULATED PROPERLY.	RESULT IN ELECTROCUTED	USE INSULATED INSULATE THE SCREW DRIVER/TESTER USING INSULATION TAPE	
4. CHECK THE OPERATION OF THE DAMPER FROM THE CENTRAL CONTROL ROOM.	SUDDEN MOVEMENT OF ACTUATOR LEVER.	MAINTAIN 1M DISTANCE FROM THE ACTUATOR	RESULT IN INJURY,FRACTURE	STAND OPPOSITE SIDE OF THE ACTUATOR WHERE THE LEVER ACTUATES	

Date:20-09-2017