



DALMIA CEMENT (B) LIMITED – CEMENT PLANT
ARIYALUR
ELECTRICAL MANUAL

Issue No. 02	Rev. No: 01	Effective Date: 22.07.2020	ELEC/SOP/012
Issued By: M.R		Approved By: HOD - ELECTRICAL	
SOP for Lighting maintenance			

Scope : Maintenance of lighting at different locations.

Responsibility : Electricians

Accountability : Electrical Engineer

PPE:

1. Nose mask
2. Goggles
3. Cotton Gloves/LT rubber gloves
4. Safety shoes
5. Safety helmet
6. Full body harness with double lanyard as per the requirement.

Tools:

1. Test lamp
2. Suitable spanner
3. Cutting pliers
4. Screw Driver
5. MCB mini lock
6. Fiber Ladder

Hazards:

Risk Associated

Electrical Shock
Minor body injury
Fall from height

Mitigating Measures

Tested Electrical Rubber Hand Gloves
Safety shoes, gloves, helmet, goggles
Full body harness with double lanyard

Training needs:

1. Emergency preparedness
2. First aid training



**DALMIA CEMENT (B) LIMITED – CEMENT PLANT
ARIYALUR
ELECTRICAL MANUAL**

Issue No. 02	Rev. No: 01	Effective Date: 22.07.2020	ELEC/SOP/012
Issued By: M.R		Approved By: HOD - ELECTRICAL	
SOP for Lighting maintenance			

Procedure:

1. Ensure that supply of light fitting switched off and make necessary localized MCB
2. For approaching the light fitting which are in height use full body harness
3. Remove the fitting from the location and clean fitting with hand blower / cloth and while removing fitting use proper tools and PPEs like Nose mask, goggles and hand Gloves.
4. Ensure any hole on roof top sheet to be closed.
5. **Check / replace (if necessary) the accessories like driver unit, LED chip, Glass , while doing replacement handle the accessories firmly and avoid the fall of accessories.**
6. Follow the periodic checklist for false ceiling fitting.
7. Check and tight the connections of the accessories in the fitting with proper tools.
8. Check and tight the connections of the panel / switch board in the panel with proper tools.
9. Ensure closing of dummy cable entries.

Emergency / Emergency Shut OFF:

1. If any injuries or electrical shock is there, give First aid and inform to the Safety department or Call Emergency number 3108/9865152222/9750963761.

Records/Annexure:

1. JSA as enclosed below.



DALMIA CEMENT (B) LIMITED – CEMENT PLANT ARIYALUR ELECTRICAL MANUAL

Issue No. 02	Rev. No: 01	Effective Date: 22.07.2020	ELEC/SOP/012
Issued By: M.R		Approved By: HOD - ELECTRICAL	
SOP for Lighting maintenance			

JOB SAFETY ANALYSIS :(JSA)

Job Safety Analysis	Job: Lighting maintenance	Date:	Analysis by:	Reviewed by:
Title of employee doing job: Electrician	Supervisor: Section Engineer	Department: Electrical	Section: Plant	Approved by:
Reqd./recommended PPE: Nose mask, Goggles, Cotton Gloves, Safety shoes, Safety helmet, Full body harness with double lanyard.				
Sequence of Basic Job Steps	Potential Hazards	Recommended Safe Job Procedure	What Could Go Wrong	Corrective Action
Put on PPE,				
Removing fitting	Tools slip	Use suitable tools	Tool may be damaged	Tool box talk Periodic replacement
	Body injury	Wear safety helmet, safety shoes , hand gloves	Tools and material may fall on human body	Periodic replacement
	Electrical shock	Use Insulated tools	Insulation Damaged	Inspect before use. Periodic replacement
	Fall from height	Use safety belt with double lanyard	Defective safety belt	Check the belt condition before use / Check the inspection validity
Cleaning of fitting	Irritation of eye	Wear goggles	Damaged goggles/non standard goggles/ Not wearing goggle	Periodic replacement / Proper training/ Follow SOP
	Inhalation of Dust	Wear Nose mask	Damaged nose mask/Not wearing Nose mask	Periodic replacement/ Proper training/ Follow SOP
Replacement of driver & LED strip	Cut injury	Use hand gloves	Damaged LED / failed driver can cause injury	Handle with care / use hand gloves without fail.
Check the termination tightness of all accessories	Body injury	Use proper tools	Nonstandard /damaged tools	Training for tools handling/ Periodic replacement
Check the termination tightness of all accessories Check the termination tightness of panel MCB and replace if required	Body injury Body injury	Wear safety helmet, safety shoes , hand gloves	Tools and material may fall on human body	Without PPE don't perform the job
		Use proper tools	Nonstandard /damaged tools	Training for tools handling/ Periodic replacement
Check the termination tightness of panel MCB and replace if required	Body injury	Wear safety helmet, safety shoes , hand gloves	Tools and material may fall on human body	Without PPE don't perform the job



**DALMIA CEMENT (B) LIMITED – CEMENT PLANT
ARIYALUR
ELECTRICAL MANUAL**

Issue No. 02	Rev. No: 01	Effective Date: 22.07.2020	ELEC/SOP/012
Issued By: M.R		Approved By: HOD - ELECTRICAL	
SOP for Lighting maintenance			

--	--	--	--	--