



**DALMIA CEMENT (B) LIMITED – CEMENT PLANT
ARIYALUR
ELECTRICAL MANUAL**

Issue No. 02	Rev. No: 00	Effective Date: 01.11.2019	INST/SOP/027
Issued By: M.R		Approved By: HOD- INSTRUMENTATION	
SOP for Trouble shooting in Live Panel			

Scope : Trouble shooting in live panel for control scheme only

Responsibility : Engineer/Electricians

Accountability : Electrical Manager

PPE:

1. Nose mask
2. Goggles
3. Safety shoes (Electrical)
4. Safety helmet
5. Rubber hand gloves

Tools:

1. Test lamp
2. Insulated tools
3. Multimeter
4. Line Tester

Hazards:

Risk Associated

Electrical Shock

Minor body injury

Mitigating Measures

Electrical Safety Gloves

Safety shoes, gloves, helmet, goggles

Training needs:

1. Emergency preparedness
2. First aid training

Procedure:

1. Use proper PPE.
2. Only Use electrical safety shoes for trouble shooting in live panel and stand on rubber mat.
3. Use only insulated hand tools.
4. Use electrical hand gloves wherever required.
5. Only qualified Technician / Engineer personnel work on live panels.



**DALMIA CEMENT (B) LIMITED – CEMENT PLANT
ARIYALUR
ELECTRICAL MANUAL**

Issue No. 02	Rev. No: 00	Effective Date: 01.11.2019	INST/SOP/027
Issued By: M.R		Approved By: HOD- INSTRUMENTATION	
SOP for Trouble shooting in Live Panel			

6. Do not carry out the work in Live Panel if Place / person are in wet condition.
7. Be alert and keep yourself beside the panel during opening the panel cover
8. After opening the live panel inspect and ensure that there are no bare live power conductor are in exposed. If Any power conductor in exposed, take LOTO and do necessary arrangement for cover the same.
9. For testing the control supply are tightening the terminal point use the line tester or connector in straight position, don't put in inclined position.
10. After finishing the Job, close all panel doors / covers properly.

Emergency / Emergency Shut OFF:

1. If any injuries or electrical shock are there, give First aid and inform to the Safety department or Call Emergency number 3108/9865152222/9750963761.



**DALMIA CEMENT (B) LIMITED – CEMENT PLANT
ARIYALUR
ELECTRICAL MANUAL**

Issue No. 02	Rev. No: 00	Effective Date: 01.11.2019	INST/SOP/027
Issued By: M.R		Approved By: HOD- INSTRUMENTATION	
SOP for Trouble shooting in Live Panel			

Records/Annexure:

1. JSA as enclosed below.

JOB SAFETY ANALYSIS:(JSA)

Job Safety Analysis	Job: Trouble shooting in live panel	Date: 20.09.2017	Analysis by: Section engineer	Reviewed by: Section head
Title of employee doing job: Engineer / Electrician	Supervisor: Section Engineer	Department: Electrical	Section: Plant	Approved by: HOD
Sequence of Basic Job Steps	Potential Hazards	Recommended Safe Job Procedure	What Could Go Wrong	Corrective Action
Opening of live panel cover	Body injury	Use suitable tools	Tool may be damaged	Inspect before use
Trouble shooting	Panel flash over and Burned injury	Keep your self beside the panel Wear safety Goggles	Not follow the procedure Damaged	Tool box talk Periodic replacement
	Short circuit.	Use Insulated tools	Insulation may damaged	Inspect before use
	Panel flash over and Burned injury	Testing tools to be hold straight	Not follow the procedure	Tool box talk
		Wear safety Goggles Power conductor to be cover by shroud.	Damaged Failed to inspect or cover.	Periodic replacement Inspect before start the job.



**DALMIA CEMENT (B) LIMITED – CEMENT PLANT
ARIYALUR
ELECTRICAL MANUAL**

Issue No. 02	Rev. No: 00	Effective Date: 01.11.2019	INST/SOP/027
Issued By: M.R		Approved By: HOD- INSTRUMENTATION	
SOP for Trouble shooting in Live Panel			

--	--	--	--	--